



CROFTON COMMUNITY SCHOOL

PO Box 429, North Highway 121
Crofton, Nebraska 68730
Jr./Sr. High (402) 388-2440 Elementary (402) 388-4357
FAX # (402) 388-4265

MARK WRAGGE
Superintendent

JOHNNIE OSTERMEYER
Secondary Principal

SARAH HIGGINS
Elementary Principal

PROJECT and PLAN DISCUSSION

1. ES gym roof –not enough slope when built—led to water sitting and rusting on top of the behlen roof panels
 - a. Creating slope
 - b. Deciding—Slope all one direction? Or split the slope in half?
 - c. Considerations—Weight load—insulation, snow
2. New structure enclosed early September
3. Asbestos in Title I classroom and on water and heating pipe joints —ESI abated it
4. ESI powerwashing West classrooms now, moving North
 - a. North classrooms next
5. New Kindergarten classrooms –Slugging the concrete block
 - a. Withstand a lot of wind
6. Corner of existing building—existing damage to concrete block
7. Track Project—Concrete work is done and the new Pole Vault Pit is delivered. Just need the rubberized surfacing done