



May 30, 2025

FACILITY ID: 999148

Nancy Tellez, Clerk  
City of Crete  
PO Box 86  
Crete NE 68333-0086

Re: PWS – City of Crete – W-39-2024 – **Approval To Place Into Service** – Burlington Estates Addition  
– Willow Lane & Jasmine Road (CDG No. 2023-0242)

Dear Ms. Tellez:

The Department has received the engineer's correspondence of May 30, 2025 concerning placement of the above-mentioned constructed water main into service.

Based upon the justification provided for placement of the water main into service, certification of the completed water main in accordance with the plans and specifications approved earlier by the Department, and microbiological test results showing the absence of coliform bacteria, the request for placement of the water main into service is hereby granted.

A final inspection of the project will be conducted by the Department at a later date.

If you have any questions, please feel free to contact me at 402/471-1004 or vince.kuppig@nebraska.gov. You may also contact Cyril Martinmaas, Engineering Section Supervisor, at 402/471-0522 or cyril.martinmaas@nebraska.gov.

Sincerely,

Vince Kuppig, Engineer  
Permitting & Engineering Division  
Nebraska Department of Environment and Energy

xc: Justin Crow, P.E., Civil Design Group (ec)  
Jesse Yager, Water Operator (ec)  
Darcie Ross, Ross Plumbing (ec)  
Eric Cox, NDEE (ec)