

**Public Works Committee Meeting**  
**Tuesday, August 15, 2023 5:00 PM**  
**Crete City Hall**  
**243 E 13th Street**  
**Crete, NE 68333**

**1. Open Meeting**

- In accordance with Nebraska law, a copy of the Open Meetings Act can be found in the back of the Council Chambers.
- Items listed on the agenda may be considered in any order.

**2. Roll Call**

- Attendance of members will be recorded to determine the presence of a quorum for official actions.

**3. Items of Business**

- The Committee may discuss or limit discussion on, hear testimony in favor of or in opposition to, or take action to provide a recommendation to the City Council on any matter presented under this title.
- 3.A. Consider a recommendation to the City Council on the Contractor's Application for Payment from Constructors, Inc. for Project No. 23-015 in the amount of \$232,336.90.
- 3.B. Consider a recommendation to the City Council on adopting Resolution 2023-16: A resolution authorizing the Mayor to sign the Nebraska Board of Public Roads Classifications and Standards Municipal Annual Certification of Program Compliance.
- 3.C. Consider a recommendation to the City Council on the amended Utility Payment Agreement And Waiver Of Notice Policy
- 3.D. Consider a recommendation to the City Council on the Substation Transformer and Switchgear bids.
- 3.E. Discussion on fence brochure information.

**4. Officers' Reports**

- Reports may be given by the Mayor, Officers, Departments, or Councilmembers concerning the current operations of the City.
- No action can be taken on matters presented under this title except to answer any questions or to refer the matter for further action.

**5. Adjournment**

**Disclaimers & Notices**

- The Council may enter into closed session to discuss any matter on this agenda when it is determined that a closed session is clearly necessary for the protection of the public interest or the prevention of needless injury to the reputation of an individual (if such individual has not requested a public meeting) or as otherwise allowed by law. Any closed session shall be limited to the subject matter for which the closed session was called. If the motion to close passes, then immediately prior to the closed session the Mayor shall restate on the record the limitation of the subject matter of the closed session.
- The City of Crete assures that no person shall on the grounds of race, color, national origin, age, disability, handicap or sex, be excluded from participation in, be denied the benefits of, or be otherwise subjected to discrimination under any program or activity of the City receiving Federal financial assistance. To report discrimination, contact the City Clerk's office.
- The complete agenda with attachments is available at [www.crete.ne.gov](http://www.crete.ne.gov).

**Contractor's Application for Payment**

<b>Owner:</b> <u>City of Crete, Nebraska</u>	<b>Owner's Project No.:</b> _____
<b>Engineer:</b> <u>JEO Consulting Group, Inc.</u>	<b>Engineer's Project No.:</b> <u>220169.00</u>
<b>Contractor:</b> <u>Constructors, Inc.</u>	<b>Contractor's Project No.:</b> <u>23-015</u>
<b>Project:</b> <u>2022 Street Improvements (Street Improvement Districts 2022-01 to 2022-07)</u>	
<b>Contract:</b> <u>2022 Street Improvements (Street Improvement Districts 2022-01 to 2022-07)</u>	
<b>Application No.:</b> <u>3</u>	<b>Application Date:</b> <u>7/31/2023</u>
<b>Application Period:</b> From <u>5/20/2023</u> to <u>7/31/2023</u>	

1. Original Contract Price	\$ 1,905,856.85
2. Net change by Change Orders	\$ 52,980.34
3. Current Contract Price (Line 1 + Line 2)	\$ 1,958,837.19
4. Total Work completed and materials stored to date (Sum of Column G Lump Sum Total and Column J Unit Price Total)	\$ 1,278,102.37
5. Retainage	
a. <u>5%</u> X \$ 1,278,102.37 Work Completed =	\$ 63,905.12
b. <u>5%</u> X \$ - Stored Materials =	\$ -
c. Total Retainage (Line 5.a + Line 5.b)	\$ 63,905.12
6. Amount eligible to date (Line 4 - Line 5.c)	\$ 1,214,197.25
7. Less previous payments (Line 6 from prior application)	\$ 981,860.35
8. Amount due this application	\$ 232,336.90
9. Balance to finish, including retainage (Line 3 - Line 4 + Line 5.c)	\$ 744,639.94

**Contractor's Certification**

The undersigned Contractor certifies, to the best of its knowledge, the following:

(1) All previous progress payments received from Owner on account of Work done under the Contract have been applied on account to discharge Contractor's legitimate obligations incurred in connection with the Work covered by prior Applications for Payment;

(2) Title to all Work, materials and equipment incorporated in said Work, or otherwise listed in or covered by this Application for Payment, will pass to Owner at time of payment free and clear of all liens, security interests, and encumbrances (except such as are covered by a bond acceptable to Owner indemnifying Owner against any such liens, security interest, or encumbrances); and

(3) All the Work covered by this Application for Payment is in accordance with the Contract Documents and is not defective.

**Contractor:** SHAWN ROU CONSTRUCTORS INC.

**Signature:** \_\_\_\_\_ **Date:** 8-4-23

<p><b>Recommended by Engineer</b></p> <p>By: _____</p> <p>Title: <u>Project Manager</u></p> <p>Date: <u>8/1/23</u></p>	<p><b>Approved by Owner</b></p> <p>By: _____</p> <p>Title: _____</p> <p>Date: _____</p>
--	---

<p><b>Approved by Funding Agency</b></p> <p>By: _____</p> <p>Title: _____</p> <p>Date: _____</p>	<p>By: _____</p> <p>Title: _____</p> <p>Date: _____</p>
--	---

**Progress Estimate - Unit Price Work**

**Contractor's Application for Payment**

<b>Owner:</b>	City of Crete, Nebraska	<b>Owner's Project No.:</b>	
<b>Engineer:</b>	JEO Consulting Group, Inc.	<b>Engineer's Project No.:</b>	220169.00
<b>Contractor:</b>	Constructors, Inc.	<b>Contractor's Project No.:</b>	23-015
<b>Project:</b>	2022 Street Improvements (Street Improvement Districts 2022-01 to 2022-07)		
<b>Contract:</b>	2022 Street Improvements (Street Improvement Districts 2022-01 to 2022-07)		

<b>Application No.:</b>	3	<b>Application Period:</b>	From 05/19/23 to 07/31/23	<b>Application Date:</b>	07/31/23
-------------------------	---	----------------------------	---------------------------	--------------------------	----------

A Bid Item No.	B Description	C Contract Information			F Work Completed			I Materials Currently Stored (not in G) (\$)	J Work Completed and Materials Stored to Date (H + I) (\$)	K % of Value of Item (J / F) (%)	L Balance to Finish (F - J) (\$)
		D Item Quantity	E Units	E Unit Price (\$)	F Value of Bid Item (C X E) (\$)	G Estimated Quantity Incorporated in the Work	H Value of Work Completed to Date (E X G) (\$)				
<b>Original Contract</b>											
<b>GROUP A – OAK AVENUE (SOUTH) &amp; 18TH STREET (WEST) (SID 2022-06)</b>											
1	Mobilization	1	LS	\$44,479.57	44,479.57	1.00	44,479.57		44,479.57	100%	-
2	Bonding and Insurance	1	LS	\$481.85	481.85	1.00	481.85		481.85	100%	-
3	Clearing and Grubbing	1	LS	\$1,385.32	1,385.32	1.00	1,385.32		1,385.32	100%	-
4	Remove Tree	10	EA	\$3,922.27	39,222.70	10.00	39,222.70		39,222.70	100%	-
5	Remove Pavement	170	SY	\$10.84	1,842.80	170.00	1,842.80		1,842.80	100%	-
6	Remove Concrete Sidewalk	663	SF	\$3.01	1,995.63	663.00	1,995.63		1,995.63	100%	-
7	Remove Storm Sewer Structure (< 6' deep)	1	EA	\$1,806.94	1,806.94	1.00	1,806.94		1,806.94	100%	-
8	Remove Storm Sewer Pipe	173	LF	\$13.49	2,333.77	173.00	2,333.77		2,333.77	100%	-
9	Adjust Valve Box to Grade	4	EA	\$1,927.40	7,709.60		-		-	0%	7,709.60
10	Replace Curb Stop Box	1	EA	\$2,770.65	2,770.65		-		-	0%	2,770.65
11	Earthwork Measured in Embankment (Established Quantity)	750	CY	\$21.68	16,260.00	750.00	16,260.00		16,260.00	100%	-
12	7" Concrete Pavement	2,350	SY	\$66.87	157,144.50		-		-	0%	157,144.50
13	6" Concrete Driveway	119	SY	\$78.62	9,355.78		-		-	0%	9,355.78
14	4" Concrete Sidewalk	4,751	SF	\$8.49	40,335.99		-		-	0%	40,335.99
15	Detectable Warning Panels	56	SF	\$26.77	1,499.12		-		-	0%	1,499.12
16	Subgrade Preparation	2,350	SY	\$5.59	13,136.50		-		-	0%	13,136.50
17	Gravel Surface Course	2	TONS	\$68.97	137.94		-		-	0%	137.94
18	Concrete Header	2	EA	\$736.78	1,473.56		-		-	0%	1,473.56
19	Concrete Collar	1	EA	\$655.91	655.91		-		-	0%	655.91
20	Curb Inlet	3	EA	\$7,690.03	23,070.09		-		-	0%	23,070.09
21	Curb Inlet w/ Manhole	2	EA	\$8,819.32	17,638.64		-		-	0%	17,638.64
22	Storm Sewer Junction Box (4'x4')	1	EA	\$7,724.34	7,724.34		-		-	0%	7,724.34
23	18" RCP Flared End Section	1	EA	\$993.10	993.10		-		-	0%	993.10
24	15" PVC Pipe, SDR 35"	68	LF	\$59.11	4,019.48		-		-	0%	4,019.48
25	18" RCP, Class III	204	LF	\$62.15	12,678.60		-		-	0%	12,678.60
26	24" Round Equivalent (RE) RCP, Class III	6	LF	\$95.47	572.82		-		-	0%	572.82
27	Temporary Traffic Control Measures	1	LS	\$4,259.36	4,259.36		-		-	0%	4,259.36
28	Reset Sign and Post	2	EA	\$144.88	289.76		-		-	0%	289.76
29	6" Topsoil	2,350	SY	\$6.02	14,147.00		-		-	0%	14,147.00
30	Silt Fence, High Porosity	100	LF	\$7.36	736.00		-		-	0%	736.00
31	Curb Inlet Sediment Filter	1	EA	\$175.72	175.72		-		-	0%	175.72
32	Hydro-Seeding, Fertilizer and Mulch	0.5	ACRE	\$27,801.96	13,900.98		-		-	0%	13,900.98
<b>GROUP B – 18<sup>TH</sup> STREET (EAST) (SID 2022-02)</b>											
1	Mobilization	1	LS	\$29,810.75	29,810.75	1.00	29,810.75		29,810.75	100%	-
2	Bonding and Insurance	1	LS	\$481.85	481.85	1.00	481.85		481.85	100%	-
3	Clearing and Grubbing	1	LS	\$1,385.32	1,385.32	1.00	1,385.32		1,385.32	100%	-
4	Remove Tree	6	EA	\$3,922.27	23,533.62	6.00	23,533.62		23,533.62	100%	-
5	Remove Pavement	100	SY	\$10.84	1,084.00	100.00	1,084.00		1,084.00	100%	-
6	Remove Concrete Sidewalk	372	SF	\$3.01	1,119.72	372.00	1,119.72		1,119.72	100%	-
7	Remove Storm Sewer Pipe	55	LF	\$16.23	892.65	55.00	892.65		892.65	100%	-
8	Adjust Valve Box to Grade	3	EA	\$1,927.41	5,782.23	3.00	5,782.23		5,782.23	100%	-
9	Earthwork Measured in Embankment (Established Quantity)	250	CY	\$21.68	5,420.00	250.00	5,420.00		5,420.00	100%	-
10	7" Concrete Pavement	1,535	SY	\$67.44	103,520.40	1,535.00	103,520.40		103,520.40	100%	-
11	6" Concrete Driveway	188	SY	\$78.63	14,782.44	154.00	12,109.02		12,109.02	82%	2,673.42
12	4" Concrete Sidewalk	2,448	SF	\$8.81	21,566.88	2,448.00	21,566.88		21,566.88	100%	-
13	Modular Block Retaining Wall	55	SF	\$101.11	5,561.05	55.00	5,561.05		5,561.05	100%	-
14	Detectable Warning Panels	48	SF	\$36.49	1,751.52	48.00	1,751.52		1,751.52	100%	-

**Progress Estimate - Unit Price Work**

**Contractor's Application for Payment**

<b>Owner:</b>	City of Crete, Nebraska	<b>Owner's Project No.:</b>	
<b>Engineer:</b>	JEO Consulting Group, Inc.	<b>Engineer's Project No.:</b>	220169.00
<b>Contractor:</b>	Constructors, Inc.	<b>Contractor's Project No.:</b>	23-015
<b>Project:</b>	2022 Street Improvements (Street Improvement Districts 2022-01 to 2022-07)		
<b>Contract:</b>	2022 Street Improvements (Street Improvement Districts 2022-01 to 2022-07)		

**Application No.:** 3      **Application Period:** From 05/19/23 to 07/31/23      **Application Date:** 07/31/23

A Bid Item No.	B Description	C Contract Information			F Work Completed			I Materials Currently Stored (not in G) (\$)	J Work Completed and Materials Stored to Date (H + I) (\$)	K % of Value of Item (J / F) (%)	L Balance to Finish (F - J) (\$)
		D Item Quantity	E Units	E Unit Price (\$)	F Value of Bid Item (C X E) (\$)	G Estimated Quantity Incorporated in the Work	H Value of Work Completed to Date (E X G) (\$)				
15	Subgrade Preparation	1,535	SY	\$5.59	8,580.65	1,535.00	8,580.65		8,580.65	100%	-
16	Gravel Surface Course	2	TONS	\$68.97	137.94	2.00	137.94		137.94	100%	-
17	Concrete Header	4	EA	\$429.79	1,719.16	4.00	1,719.16		1,719.16	100%	-
18	Temporary Traffic Control Measures	1	LS	\$3,093.88	3,093.88	1.00	3,093.88		3,093.88	100%	-
19	Reset Sign and Post	5	EA	\$145.02	725.10		-		-	0%	725.10
20	6" Topsoil	1,535	SY	\$6.02	9,240.70	1,535.00	9,240.70		9,240.70	100%	-
21	Silt Fence, High Porosity	100	LF	\$7.36	736.00		-		-	0%	736.00
22	Curb Inlet Sediment Filter	1	EA	\$175.72	175.72	1.00	175.72		175.72	100%	-
23	Hydro-Seeding, Fertilizer and Mulch	0.25	ACRE	\$27,803.44	6,950.86	0.25	6,950.86		6,950.86	100%	-
<b>GROUP C – LINDEN AVENUE (SID 2022-03)</b>											
1	Mobilization	1	LS	\$29,340.47	29,340.47	1.00	29,340.47		29,340.47	100%	-
2	Bonding and Insurance	1	LS	\$481.85	481.85	1.00	481.85		481.85	100%	-
3	Clearing and Grubbing	1	LS	\$1,385.32	1,385.32	1.00	1,385.32		1,385.32	100%	-
4	Remove Tree	4	EA	\$3,922.27	15,689.08	4.00	15,689.08		15,689.08	100%	-
5	Remove Pavement	18	SY	\$10.84	195.12	18.00	195.12		195.12	100%	-
6	Remove Storm Sewer Structure (< 6' deep)	1	EA	\$1,806.94	1,806.94	1.00	1,806.94		1,806.94	100%	-
7	Remove Storm Sewer Pipe	5	LF	\$27.58	137.90	5.00	137.90		137.90	100%	-
8	Earthwork Measured in Embankment (Established Quantity)	121	CY	\$31.23	3,778.83	121.00	3,778.83		3,778.83	100%	-
9	7" Concrete Pavement	939	SY	\$66.68	62,612.52	939.00	62,612.52		62,612.52	100%	-
10	4" Concrete Sidewalk	1,335	SF	\$7.26	9,692.10	1,335.00	9,692.10		9,692.10	100%	-
11	Modular Block Retaining Wall	10	SF	\$101.09	1,010.90		-		-	0%	1,010.90
12	Subgrade Preparation	939	SY	\$5.59	5,249.01	939.00	5,249.01		5,249.01	100%	-
13	Temporary Traffic Control Measures	1	LS	\$3,093.88	3,093.88	1.00	3,093.88		3,093.88	100%	-
14	6" Topsoil	939	SY	\$6.02	5,652.78	939.00	5,652.78		5,652.78	100%	-
15	Silt Fence, High Porosity	100	LF	\$7.36	736.00		-		-	0%	736.00
16	Curb Inlet Sediment Filter	1	EA	\$174.90	174.90	1.00	174.90		174.90	100%	-
17	Hydro-Seeding, Fertilizer and Mulch	0.25	ACRE	\$27,803.44	6,950.86	0.25	6,950.86		6,950.86	100%	-
<b>GROUP D – 21ST STREET (SID 2022-05)</b>											
1	Mobilization	1	LS	\$29,202.59	29,202.59	1.00	29,202.59		29,202.59	100%	-
2	Bonding and Insurance	1	LS	\$481.85	481.85	1.00	481.85		481.85	100%	-
3	Clearing and Grubbing	1	LS	\$1,385.32	1,385.32	1.00	1,385.32		1,385.32	100%	-
4	Remove Tree	4	EA	\$3,922.27	15,689.08	4.00	15,689.08		15,689.08	100%	-
5	Remove Pavement	373	SY	\$10.84	4,043.32	373.00	4,043.32		4,043.32	100%	-
6	Remove Concrete Sidewalk	2,317	SF	\$3.01	6,974.17	2,317.00	6,974.17		6,974.17	100%	-
7	Adjust Valve Box to Grade	4	EA	\$1,927.40	7,709.60	4.00	7,709.60		7,709.60	100%	-
8	Earthwork Measured in Embankment (Established Quantity)	69	CY	\$21.68	1,495.92	69.00	1,495.92		1,495.92	100%	-
9	7" Concrete Pavement	1,341	SY	\$69.01	92,542.41	1,341.00	92,542.41		92,542.41	100%	-
10	6" Concrete Driveway	50	SY	\$78.61	3,930.50	50.00	3,930.50		3,930.50	100%	-
11	4" Concrete Sidewalk	3,318	SF	\$10.42	34,573.56	3,318.00	34,573.56		34,573.56	100%	-
12	Detectable Warning Panels	112	SF	\$36.49	4,086.88	112.00	4,086.88		4,086.88	100%	-
13	Subgrade Preparation	1,341	SY	\$5.58	7,482.78	1,341.00	7,482.78		7,482.78	100%	-
14	Gravel Surface Course	2	TONS	\$68.97	137.94		-		-	0%	137.94
15	Concrete Header	2	EA	\$532.11	1,064.22	2.00	1,064.22		1,064.22	100%	-
16	Trench Drain	1	EA	\$4,336.00	4,336.00	1.00	4,336.00		4,336.00	100%	-
17	Temporary Traffic Control Measures	1	LS	\$3,093.88	3,093.88	1.00	3,093.88		3,093.88	100%	-
18	Reset Sign and Post	1	EA	\$145.65	145.65		-		-	0%	145.65
19	6" Topsoil	1,110	SY	\$6.02	6,682.20	1,110.00	6,682.20		6,682.20	100%	-
20	Silt Fence, High Porosity	100	LF	\$7.36	736.00		-		-	0%	736.00
21	Hydro-Seeding, Fertilizer and Mulch	0.25	ACRE	\$27,803.44	6,950.86		-		-	0%	6,950.86

**Progress Estimate - Unit Price Work**

**Contractor's Application for Payment**

<b>Owner:</b>	City of Crete, Nebraska	<b>Owner's Project No.:</b>	
<b>Engineer:</b>	JEO Consulting Group, Inc.	<b>Engineer's Project No.:</b>	220169.00
<b>Contractor:</b>	Constructors, Inc.	<b>Contractor's Project No.:</b>	23-015
<b>Project:</b>	2022 Street Improvements (Street Improvement Districts 2022-01 to 2022-07)		
<b>Contract:</b>	2022 Street Improvements (Street Improvement Districts 2022-01 to 2022-07)		

**Application No.:** 3      **Application Period:** From 05/19/23 to 07/31/23      **Application Date:** 07/31/23

A Bid Item No.	B Description	C Contract Information			F Work Completed			I Materials Currently Stored (not in G) (\$)	J Work Completed and Materials Stored to Date (H + I) (\$)	K % of Value of Item (J / F) (%)	L Balance to Finish (F - J) (\$)
		D Item Quantity	E Units	E Unit Price (\$)	F Value of Bid Item (C X E) (\$)	G Estimated Quantity Incorporated in the Work	H Value of Work Completed to Date (E X G) (\$)				
<b>GROUP E – KINGWOOD AVENUE (2022-04)</b>											
1	Mobilization	1	LS	\$28,884.99	28,884.99	1.00	28,884.99		28,884.99	100%	-
2	Bonding and Insurance	1	LS	\$481.85	481.85	1.00	481.85		481.85	100%	-
3	Clearing and Grubbing	1	LS	\$1,385.32	1,385.32	1.00	1,385.32		1,385.32	100%	-
4	Remove Tree	1	EA	\$3,922.27	3,922.27	1.00	3,922.27		3,922.27	100%	-
5	Remove Concrete Sidewalk	23	SF	\$6.02	138.46	23.00	138.46		138.46	100%	-
6	Adjust Valve Box to Grade	2	EA	\$1,927.41	3,854.82	2.00	3,854.82		3,854.82	100%	-
7	Replace Curb Stop Box	1	EA	\$2,770.65	2,770.65	1.00	2,770.65		2,770.65	100%	-
8	Earthwork Measured in Embankment (Established Quantity)	42	CY	\$21.68	910.56	42.00	910.56		910.56	100%	-
9	7" Concrete Pavement	924	SY	\$65.41	60,438.84	924.00	60,438.84		60,438.84	100%	-
10	4" Concrete Sidewalk	1,745	SF	\$9.76	17,031.20	1,745.00	17,031.20		17,031.20	100%	-
11	Detectable Warning Panels	40	SF	\$36.49	1,459.60	40.00	1,459.60		1,459.60	100%	-
12	Subgrade Preparation	924	SY	\$5.58	5,155.92	924.00	5,155.92		5,155.92	100%	-
13	Temporary Traffic Control Measures	1	LS	\$3,093.88	3,093.88	1.00	3,093.88		3,093.88	100%	-
14	6" Topsoil	924	SY	\$6.02	5,562.48	924.00	5,562.48		5,562.48	100%	-
15	Silt Fence, High Porosity	300	LF	\$7.36	2,208.00		-		-	0%	2,208.00
16	Curb Inlet Sediment Filter	2	EA	\$174.98	349.96	2.00	349.96		349.96	100%	-
17	Hydro-Seeding, Fertilizer and Mulch	0.25	ACRE	\$27,803.44	6,950.86	0.25	6,950.86		6,950.86	100%	-
<b>GROUP F – OAK AVENUE (NORTH) (SID 2022-07)</b>											
1	Mobilization	1	LS	\$29,880.87	29,880.87	1.00	29,880.87		29,880.87	100%	-
2	Bonding and Insurance	1	LS	\$481.85	481.85	1.00	481.85		481.85	100%	-
3	Clearing and Grubbing	1	LS	\$1,385.32	1,385.32	1.00	1,385.32		1,385.32	100%	-
4	Remove Tree	4	EA	\$3,922.27	15,689.08	4.00	15,689.08		15,689.08	100%	-
5	Adjust Valve Box to Grade	3	EA	\$1,927.41	5,782.23		-		-	0%	5,782.23
6	Earthwork Measured in Embankment (Established Quantity)	97	CY	\$21.68	2,102.96	97.00	2,102.96		2,102.96	100%	-
7	7" Concrete Pavement	1,265	SY	\$68.14	86,197.10		-		-	0%	86,197.10
8	6" Concrete Driveway	42	SY	\$78.59	3,300.78		-		-	0%	3,300.78
9	4" Concrete Sidewalk	4,161	SF	\$9.28	38,614.08		-		-	0%	38,614.08
10	Detectable Warning Panels	80	SF	\$36.49	2,919.20		-		-	0%	2,919.20
11	Subgrade Preparation	1,265	SY	\$5.59	7,071.35		-		-	0%	7,071.35
12	Gravel Surface Course	1	TONS	\$69.95	69.95		-		-	0%	69.95
13	Concrete Header	1	EA	\$327.45	327.45		-		-	0%	327.45
14	Adjust Hydrant to Grade	1	EA	\$2,891.10	2,891.10		-		-	0%	2,891.10
15	Temporary Traffic Control Measures	1	LS	\$3,093.88	3,093.88		-		-	0%	3,093.88
16	Reset Sign and Post	2	EA	\$144.88	289.76		-		-	0%	289.76
17	6" Topsoil	1,265	SY	\$6.02	7,615.30		-		-	0%	7,615.30
18	Silt Fence, High Porosity	400	LF	\$7.36	2,944.00		-		-	0%	2,944.00
19	Curb Inlet Sediment Filter	3	EA	\$175.22	525.66		-		-	0%	525.66
20	Hydro-Seeding, Fertilizer and Mulch	0.25	ACRE	\$27,803.44	6,950.86		-		-	0%	6,950.86
<b>GROUP G – 23RD STREET (WEST) (SID 2022-07)</b>											
1	Mobilization	1	LS	\$41,531.98	41,531.98	1.00	41,531.98		41,531.98	100%	-
2	Bonding and Insurance	1	LS	\$481.85	481.85	1.00	481.85		481.85	100%	-
3	Clearing and Grubbing	1	LS	\$1,385.32	1,385.32	1.00	1,385.32		1,385.32	100%	-
4	Remove Tree	3	EA	\$3,922.27	11,766.81	3.00	11,766.81		11,766.81	100%	-
5	Remove Storm Sewer Structure (< 6' deep)	1	EA	\$1,806.94	1,806.94	1.00	1,806.94		1,806.94	100%	-
6	Remove Storm Sewer Pipe	15	LF	\$12.47	187.05	15.00	187.05		187.05	100%	-
7	Earthwork Measured in Embankment (Established Quantity)	399	CY	\$21.68	8,650.32	399.00	8,650.32		8,650.32	100%	-
8	7" Concrete Pavement	971	SY	\$64.65	62,775.15		-		-	0%	62,775.15
9	6" Concrete Driveway	73	SY	\$78.62	5,739.26		-		-	0%	5,739.26



**Progress Estimate - Unit Price Work**

**Contractor's Application for Payment**

Owner:	City of Crete, Nebraska	Owner's Project No.:	
Engineer:	JEO Consulting Group, Inc.	Engineer's Project No.:	220169.00
Contractor:	Constructors, Inc.	Contractor's Project No.:	23-015
Project:	2022 Street Improvements (Street Improvement Districts 2022-01 to 2022-07)		
Contract:	2022 Street Improvements (Street Improvement Districts 2022-01 to 2022-07)		

Application No.: 3 Application Period: From 05/19/23 to 07/31/23 Application Date: 07/31/23

A	B	C	D	E	F	G	H	I	J	K	L
Bid Item No.	Description	Contract Information				Work Completed		Materials Currently Stored (not in G) (\$)	Work Completed and Materials Stored to Date (H + I) (\$)	% of Value of Item (J / F) (%)	Balance to Finish (F - J) (\$)
		Item Quantity	Units	Unit Price (\$)	Value of Bid Item (C X E) (\$)	Estimated Quantity Incorporated in the Work	Value of Work Completed to Date (E X G) (\$)				
<b>Change Orders</b>											
CO #1	See Attached Change Order for Item Breakdown	1.00	LS	52,980.34	52,980.34	1.00	52,980.34		52,980.34	100%	-
					-		-		-		-
					-		-		-		-
					-		-		-		-
					-		-		-		-
					-		-		-		-
					-		-		-		-
					-		-		-		-
					-		-		-		-
					-		-		-		-
					-		-		-		-
					-		-		-		-
					-		-		-		-
					-		-		-		-
					-		-		-		-
					-		-		-		-
					-		-		-		-
					-		-		-		-
					-		-		-		-
				<b>Change Order Totals</b>	\$ 52,980.34		\$ 52,980.34	\$ -	\$ 52,980.34	100%	\$ -
<b>Original Contract and Change Orders</b>											
				<b>Project Totals</b>	\$ 1,958,837.19		\$ 1,278,102.37	\$ -	\$ 1,278,102.37	65%	\$ 680,734.82



# NEBRASKA

Good Life. Great Journey.

DEPARTMENT OF TRANSPORTATION

July 28, 2023

**Notice to file the Annual Certification of Program Compliance and Signing Resolution with the Nebraska Board of Public Roads Classifications and Standards (NBCS) by October 31, 2023.**

**Please make this an agenda item for your next City Council / Village Board meeting return to the NBCS by October 31, 2023.**

**To avoid the suspension of Highway-User Revenue** to your municipality please complete the enclosed **MUNICIPAL ANNUAL CERTIFICATION OF PROGRAM COMPLIANCE** and **SIGNING RESOLUTION** and **return them to the NBCS by October 31, 2023.** Reference Neb. Rev. Stat. §§39-2120 and 39-2121(1).

Penalties for failure to comply can be found in the following State Statutes:

- Failure to comply with the provisions of Neb. Rev. Stat. §39-2115.
- Failure to comply with the provisions of Neb. Rev. Stat. §39-2119.
- Failure to file the Municipal Annual Certification of Program Compliance with the NBCS, Neb. Rev. Stat. §39-2121(2).
- Filing of a materially false Municipal Annual Certification of Program Compliance, Neb. Rev. Stat. §39-2121(3).
- Construction below minimum standards without the prior approval of the NBCS, Neb. Rev. Stat. §39-2121(3).

**Note: While the signature of the City Street Superintendent is optional on the certification, the NBCS strongly recommends that the superintendent sign this certification if said municipality has a superintendent.**

Please let me know if you have any questions. Email: [lemoyne.schulz@nebraska.gov](mailto:lemoyne.schulz@nebraska.gov)  
Phone: (402) 479-4436

Sincerely,

  
LeMoyne D. Schulz  
Secretary for the Board

LDS/2023

xc: File

## Attachments (2)

Vicki Kramer, Director  
Department of Transportation

Board of Public Roads Classifications and Standards  
1400 Nebraska Parkway  
PO Box 94759  
Lincoln, NE 68509-4759  
[dot.nebraska.gov](http://dot.nebraska.gov)

OFFICE 402-479-4436  
[ndot.bishelp@nebraska.gov](mailto:ndot.bishelp@nebraska.gov)



Roger A. Figard  
Lincoln

Barbara J. Keegan  
Alliance

John F. Krager, III  
Omaha

Russell Kreachbaum, Jr.  
Central City

James A. Litchfield  
Wakefield

Brandie Neemann  
Lincoln

Steven D. Ramos  
Norfolk

Timothy W. Weander  
Omaha

Edward R. Wootton, Sr.  
Bellevue

LeMoyne D. Schulz  
Secretary – ex officio

**Do not recreate or revise the pages of this document**, as revisions and recreations will not be accepted. Failure to **return both pages of the original document** by the filing deadline (October 31, 2023) may result in the suspension of Highway Allocation funds until the documents are filed.

**RESOLUTION**

**SIGNING OF THE  
MUNICIPAL ANNUAL CERTIFICATION OF PROGRAM COMPLIANCE  
2023**

Resolution No. 2023-16

**Whereas:** State of Nebraska Statutes, sections 39-2115, 39-2119, 39-2120, 39-2121, and 39-2520(2), requires an annual certification of program compliance to the Nebraska Board of Public Roads Classifications and standards; and

**Whereas:** State of Nebraska Statute, section 39-2120 also requires that the annual certification of program compliance by each municipality shall be signed by the Mayor or Village Board Chairperson and shall include the resolution of the governing body of the municipality authorizing the signing of the certification.

**Be it resolved** that the Mayor  Village Board Chairperson  of CRETE  
(Check one box) (Print name of municipality)  
is hereby authorized to sign the Municipal Annual Certification of Program Compliance.

Adopted this 15TH day of AUGUST, 2023 at CRETE Nebraska.  
(Month)

City Council/Village Board Members

TOM CRISMAN  
ASHLEY NEWMYER  
DAN PAPIK  
\_\_\_\_\_  
\_\_\_\_\_

KYLE FRANS  
DALE STREHLE  
ANTHONY FITZGERALD  
\_\_\_\_\_  
\_\_\_\_\_

City Council/Village Board Member \_\_\_\_\_  
Moved the adoption of said resolution  
Member \_\_\_\_\_ Seconded the Motion  
Roll Call: \_\_\_\_\_ Yes \_\_\_\_\_ No \_\_\_\_\_ Abstained \_\_\_\_\_ Absent  
Resolution adopted, signed, and billed as adopted.

Attest:

\_\_\_\_\_  
(Signature of Clerk)

**Do not recreate or revise the pages of this document, as revisions and recreations will not be accepted. Failure to return both pages of the original document by the filing deadline (October 31, 2023) may result in the suspension of Highway Allocation funds until the documents are filed.**

**MUNICIPAL  
ANNUAL CERTIFICATION OF PROGRAM COMPLIANCE  
TO  
NEBRASKA BOARD OF PUBLIC ROADS CLASSIFICATIONS  
AND STANDARDS  
2023**

In compliance with the provisions of the State of Nebraska Statutes, sections 39-2115, 39-2119, 39-2120, 39-2121, and 39-2520(2), requiring annual certification of program compliance to the Board of Public Roads

Classifications and Standards, the City  Village  of CRETE  
(Check one box) (Print name of municipality)

hereby certifies that it:

- ✓ has developed, adopted, and included in its public records the plans, programs, or standards required by sections 39-2115 and 39-2119;
- ✓ meets the plans, programs, or standards of design, construction, and maintenance for its highways, roads, or streets;
- ✓ expends all tax revenue for highway, road, or street purposes in accordance with approved plans, programs, or standards, including county and municipal tax revenue as well as highway-user revenue allocations;
- ✓ uses a system of revenue and costs accounting which clearly includes a comparison of receipts and expenditures for approved budgets, plans, programs, and standards;
- ✓ uses a system of budgeting which reflects uses and sources of funds in terms of plans, programs, or standards and accomplishments;
- ✓ uses an accounting system including an inventory of machinery, equipment, and supplies;
- ✓ uses an accounting system that tracks equipment operation costs;
- ✓ has included in its public records the information required under subsection (2) of section 39-2520; and
- ✓ **has included in its public records a copy of this certification and the resolution of the governing body authorizing the signing of this certification by the Mayor or Village Board Chairperson.**

\_\_\_\_\_  
Signature of Mayor  Village Board Chairperson  (Required) (Date)

\_\_\_\_\_  
Signature of City Street Superintendent (Optional) (Date)

**Return the completed original signing resolution and annual certification of program compliance by October 31, 2023 to:**

Nebraska Board of Public Roads Classifications and Standards  
PO Box 94759  
Lincoln NE 68509





ACCOUNT #: \_\_\_\_\_

**AGREEMENT AND WAIVER OF NOTICE**

I, \_\_\_\_\_, hereby represent that I am currently a domestic subscriber at \_\_\_\_\_ of the City of Crete Utility System and that I have a delinquent bill for electric, water and sewer service in the amount of \$\_\_\_\_\_ **\$2/day**.

I understand that I will be charged **\$2.00** per day until paid in full. **Must pay in Cash, Cashier's check, Credit Card and/or Money Order (no checks allowed).**

I further acknowledge that I represent all other users of the domestic service at the above location and that I have received notice of discontinuance of service and hereby understand that if agreed payment is not made my utility service will be discontinued.

I hereby agree to make payment to the City of Crete for my delinquent utility bill in the following manner:

Amount of Bill:	\$ _____
Reconnect Fee (if any):	\$ _____
Late Fees (\$2.00/day):	\$ _____
Total Amount Due:	\$ _____
<b>Date Due (By 3:00 p.m.)</b>	

I further understand that in consideration for the extension of time to pay my delinquent utility bill that I hereby waive any further notice of discontinuance of service that may be required under S70-1601, et. Seq., R.R.S., 1943, and hereby understand that if I do not fulfill the terms of this agreement the City of Crete will be allowed to disconnect my service without any further notice being required.

Reason for Waiver: \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_

Date: \_\_\_\_\_

**X** \_\_\_\_\_

Customer Signature

\_\_\_\_\_

\_\_\_\_\_

Witness

Customer Phone Number

FOR OFFICE USE ONLY

**Hardship reason (check one):**

- Medical Expense
- Loss of Income (Job, SSI, Child Support and/or ETC – to be determined)
- Certain expenses to repair casualty losses to a principal residence (such as losses from fires, earthquakes, or floods)
- Possible foreclosure or eviction
- Burial or funeral expenses
- Life altering events \_\_\_\_\_
- Other \_\_\_\_\_
- Not Approved – Reason \_\_\_\_\_

- Primary Customer – Check account and make sure ID matches name on account
- Reoccurring – Check to see prior waivers on account in the last year # \_\_\_\_\_  
When was last waiver on account \_\_\_\_\_

- |  |             |                      |
|--|-------------|----------------------|
| <input type="checkbox"/> Payment made on account as agreed         | Date: _____ | Circle Payment Type: |
| <input type="checkbox"/> Disconnection for nonpayment              | Date: _____ | Cash                 |
| <input type="checkbox"/> Reconnected (additional \$40.00 + waiver) | Date: _____ | Cashier's Chk        |
| <input type="checkbox"/> Forwarded for collection                  | Date: _____ | Credit Card          |
|  |             | Money Order          |

Finance Director approval signature and date:

\_\_\_\_\_

City Administrator/Office Manager/City Clerk approval signature and date:

\_\_\_\_\_



July 7, 2023

City of Crete  
Attn: Tom Ourada  
243 East 13<sup>th</sup> Street  
Crete, NE

RE: Doane Substation Medium Voltage Switchgear  
Crete, Nebraska  
Olsson Project No. 022-02597

Mr. Ourada,

On June 29, 2023 at 10:00 am, two bids were opened for the Doane Substation Medium Voltage Switchgear project. Two bids were received for the 15kV Switchgear and one bid was received for the 35kV Switchgear.

Switchgear	Harold K. Scholz Co. Ralston, NE	Malloy Electric Sioux Falls, SD
15kV	\$962,125.00	Option 1: \$1,215,668.49 Option 2: \$1,324,657.53
Lead Time	52-54 weeks	Option 1: 92-94 weeks Option 2: 76-78 weeks
35kV	No Bid	\$1,997,364.38

Harold K. Scholz Company had the following note on their Bid: Price includes 7.5% Sales Tax and Price does NOT include concrete, concrete pads, power cable, power cable terminations or grounding.

Harold K. Scholz was the low bidder with a shorter Lead Time than Malloy Electric.

Harold K. Scholz Company provided a 5% bid bond as a bid guaranty in accordance with the contract documents.

All bidders acknowledged Addendums No. 1 & 2.

Olsson recommends that Harold K. Scholz Company, with the lowest Bid for the 15kV bid of \$962,125.00, be awarded the contract to complete the referenced work.

Sincerely,

John Ledesma

Encl: Bid Tab



July 7, 2023

City of Crete  
Attn: Tom Ourada  
243 East 13<sup>th</sup> Street  
Crete, NE

RE: Doane Substation Transformer  
Crete, Nebraska  
Olsson Project No. 022-02597

Mr. Ourada,

On June 29, 2023 at 10:30 am, two bids were received and opened for the Doane Substation Transformer.

Virginia XFMR Roanoke, VA	Malloy Electric Sioux Falls, SD
\$876,669.00	\$1,450,666.67
Lead Time: 40-50 weeks	Delivery: 72 weeks

Virginia XFMR was the low bidder with a shorter Lead Time than Malloy Electric.

Virginia XFMR provided a 5% bid bond as a bid guaranty in accordance with the contract documents.

All bidders acknowledged Addendum No. 1.

Olsson recommends that Virginia XFMR, with the lowest Bid for the Transformer bid of \$876,669.00, be awarded the contract to complete the referenced work.

Sincerely,

John Ledesma

Encl: Bid Tab

# BID FORM FOR PROCUREMENT CONTRACT

The terms used in this Bid with initial capital letters have the meanings stated in the Instructions to Bidders, the General Conditions, and the Supplementary Conditions.

## ARTICLE 1—BUYER AND BIDDER

1.01 This Bid is submitted to:

**City of Crete, Crete, Nebraska**

1.02 The undersigned Bidder proposes and agrees, if this Bid is accepted, to enter into a Procurement Contract with Buyer in the form included in the Procurement Bidding Documents, and to furnish the Goods and Special Services as specified or indicated in the Procurement Bidding Documents, for the prices and within the times indicated in this Bid, and in accordance with the other terms and conditions of the Procurement Bidding Documents.

## ARTICLE 2—BASIS OF BID

2.01 *Lump Sum Bids*

A. Bidder will furnish the Goods and Special Services in accordance with the Procurement Contract Documents for the following Procurement Contract Price(s) for Doane Substation Medium Voltage Switchgear:

1. Lump Sum Bid Price (Base Bid and Alternates) Price Includes 7.5% Sales tax (\$67,125)  
Price Does NOT Include Concrete,  
Concrete Pads, Power Cable, Power  
Cable Terminations or Grounding
- Base Bid 15kV Switchgear:

BASE BID LUMP SUM	\$ 962,125.00
-------------------	---------------

Alternate Bid 35kV Switchgear:

ALTERNATE BID LUMP SUM	\$ No Bid
------------------------	-----------

## ARTICLE 3—TIME OF COMPLETION

3.01 Bidder agrees that the furnishing of Goods and Special Services will conform to the schedule of Procurement Contract Times set forth in Article 2 of the Procurement Agreement.

3.02 Bidder accepts the provisions of the Procurement Agreement as to liquidated damages.

## ARTICLE 4—ATTACHMENTS TO THIS BID

4.01 The following documents are attached to and made a condition of this Bid:

- A. Required Bid security in the form prescribed in the Instructions to Bidders.
- B. Evidence of authority to do business in the state of the Project; or a written covenant to obtain such authority within the time for acceptance of Bids.

- C. Equipment Data Sheets.
- D. Required Bidder Qualification Statement with supporting data.
- E. Technical information required for comparative evaluation as described in Instruction to Bidders, and more specifically in Specifications.

**ARTICLE 5—BIDDER’S ACKNOWLEDGMENTS**

- 5.01 Bidder accepts all terms and conditions of the Instructions to Bidders. This Bid will remain subject to acceptance for 60 days after the Bid opening, or for such longer period that Bidder may agree to in writing upon request of Buyer.
- 5.02 Bidder has examined and carefully studied the Procurement Bidding Documents, the related data identified in the Procurement Bidding Documents, and the following Addenda, receipt of which is hereby acknowledged:

Addendum No.	Addendum Date
1	5/19/23
2	5/25/23

**ARTICLE 6—BIDDER’S REPRESENTATIONS AND CERTIFICATIONS**

6.01 *Bidder’s Representations*

- A. In submitting this Bid, Bidder represents that:
  - 1. Bidder has examined and carefully studied the Procurement Contract Documents.
  - 2. If required by the Instructions to Bidders to visit the Point of Destination and the site where the Goods are to be installed or Special Services will be provided, or if, in Bidder’s judgment, any observable local or site conditions may affect the delivery, cost, progress, or furnishing of the Goods and Special Services, then Bidder has visited the Point of Destination and site where the Goods are to be installed or Special Services will be provided (as applicable) and become familiar with and is satisfied as to the observable local and site conditions that may affect delivery, cost, progress, and furnishing of the Goods and Special Services.
  - 3. Bidder is familiar with and is satisfied as to all Laws and Regulations that may affect the cost, progress, and performance of Seller's obligations under the Procurement Contract.
  - 4. Bidder has carefully studied, considered, and correlated the information known to Bidder with respect to the effect of such information on the cost, progress, and performance of Seller's obligations under the Procurement Contract.
  - 5. Bidder has given Engineer written notice of all conflicts, errors, ambiguities, or discrepancies that Bidder has discovered in the Procurement Contract Documents, and the written resolution (if any) thereof by Engineer is acceptable to Bidder.
  - 6. The Procurement Contract Documents are generally sufficient to indicate and convey understanding of all terms and conditions for performance of Seller's obligations under the Procurement Contract.

7. The submission of a Bid will constitute an incontrovertible representation by Bidder that Bidder has complied with every requirement of the Bidding Requirements, that without exception the Bid (including all Bid prices) is premised upon furnishing the Goods and Special Services as required by the Procurement Contract Documents.

6.02 *Bidder's Certifications*

A. Bidder certifies that:

1. This Bid is genuine and not made in the interest of or on behalf of any undisclosed individual or entity and is not submitted in conformity with any collusive agreement or rules of any group, association, organization, or corporation;
2. Bidder has not directly or indirectly induced or solicited any other Bidder to submit a false or sham Bid;
3. Bidder has not solicited or induced any individual or entity to refrain from bidding; and
4. Bidder has not engaged in corrupt, fraudulent, collusive, or coercive practices in competing for the Procurement Contract. For the purposes of this Paragraph 6.02.A.4:
  - a. "corrupt practice" means the offering, giving, receiving, or soliciting of anything of value likely to influence the action of a public official in the bidding process;
  - b. "fraudulent practice" means an intentional misrepresentation of facts made (a) to influence the bidding process to the detriment of Buyer, (b) to establish bid prices at artificial non-competitive levels, or (c) to deprive Buyer of the benefits of free and open competition;
  - c. "collusive practice" means a scheme or arrangement between two or more Bidders, with or without the knowledge of Buyer, a purpose of which is to establish bid prices at artificial, non-competitive levels; and
  - d. "coercive practice" means harming or threatening to harm, directly or indirectly, persons or their property to influence their participation in the bidding process.

This Bid is offered by:

Bidder:

Harold K. Scholz Company

*(typed or printed name of organization)*

By: Ross Scholz

*(individual's signature)*

Date: 6/29/23

*(date signed)*

Name:

*Ross Scholz*

*(typed or printed)*

Title: President

*(typed or printed)*

*(If Bidder is a corporation, a partnership, or a joint venture, attach evidence of authority to sign.)*

Attest:

*Brandon Christensen*

*(individual's signature)*

Title: Project Manager/ Estimator

*(typed or printed)*

Address for giving notices:

7800 Serum Ave, Ralston NE, 68127

Designated Representative:

Name: Ross Scholz

*(typed or printed)*

Title: President

*(typed or printed)*

Address:

7800 Serum Ave, Ralston NE, 68127

Phone: 402-339-7600

Email: Ross@hkscholz.com

License No.:

Classification:

Limitation:

### BID BOND

Any singular reference to Bidder, Surety, Owner or other party shall be considered plural where applicable.

**BIDDER (Name and Address):**

Harold K Scholz Company  
7800 Serum Ave Ralston, NE 68127

**SURETY (Name, and Address of Principal Place of Business):**

Universal Surety Company  
1010 Lincoln Mall Suite #101 Lincoln, NE 68508

**OWNER (Name and Address):**

City of Crete, P.O. Box 243, E 13, Crete, NE 68333

**BID**

Bid Due Date: 05/31/2023  
Description (Project Name— Include Location):  
Doane Substation Medium Voltage Switchgear

**BOND**

Bond Number:  
Date: 05/31/2023  
Penal sum Five Percent (5% of Bid Estimate) \$

(Words)

(Figures)

Surety and Bidder, intending to be legally bound hereby, subject to the terms set forth below, do each cause this Bid Bond to be duly executed by an authorized officer, agent, or representative.

**BIDDER**

Harold K Scholz Company (Seal)

Bidder's Name and Corporate Seal

By:

Signature

Print Name

Title

Attest:

Signature

Title

**SURETY**

Universal Surety Company (Seal)

Surety's Name and Corporate Seal

By:

Signature (Attach Power of Attorney)

Charlotte Ahrenholtz

Print Name

Attorney-In-Fact

Title

Attest:

Signature

Title

Note: Addresses are to be used for giving any required notice.

Provide execution by any additional parties, such as joint venturers, if necessary.

1. Bidder and Surety, jointly and severally, bind themselves, their heirs, executors, administrators, successors, and assigns to pay to Owner upon default of Bidder the penal sum set forth on the face of this Bond. Payment of the penal sum is the extent of Bidder's and Surety's liability. Recovery of such penal sum under the terms of this Bond shall be Owner's sole and exclusive remedy upon default of Bidder.
2. Default of Bidder shall occur upon the failure of Bidder to deliver within the time required by the Bidding Documents (or any extension thereof agreed to in writing by Owner) the executed Agreement required by the Bidding Documents and any performance and payment bonds required by the Bidding Documents.
3. This obligation shall be null and void if:
  - 3.1 Owner accepts Bidder's Bid and Bidder delivers within the time required by the Bidding Documents (or any extension thereof agreed to in writing by Owner) the executed Agreement required by the Bidding Documents and any performance and payment bonds required by the Bidding Documents, or
  - 3.2 All Bids are rejected by Owner, or
  - 3.3 Owner fails to issue a Notice of Award to Bidder within the time specified in the Bidding Documents (or any extension thereof agreed to in writing by Bidder and, if applicable, consented to by Surety when required by Paragraph 5 hereof).
4. Payment under this Bond will be due and payable upon default of Bidder and within 30 calendar days after receipt by Bidder and Surety of written notice of default from Owner, which notice will be given with reasonable promptness, identifying this Bond and the Project and including a statement of the amount due.
5. Surety waives notice of any and all defenses based on or arising out of any time extension to issue Notice of Award agreed to in writing by Owner and Bidder, provided that the total time for issuing Notice of Award including extensions shall not in the aggregate exceed 120 days from the Bid due date without Surety's written consent.
6. No suit or action shall be commenced under this Bond prior to 30 calendar days after the notice of default required in Paragraph 4 above is received by Bidder and Surety and in no case later than one year after the Bid due date.
7. Any suit or action under this Bond shall be commenced only in a court of competent jurisdiction located in the state in which the Project is located.
8. Notices required hereunder shall be in writing and sent to Bidder and Surety at their respective addresses shown on the face of this Bond. Such notices may be sent by personal delivery, commercial courier, or by United States Registered or Certified Mail, return receipt requested, postage pre-paid, and shall be deemed to be effective upon receipt by the party concerned.
9. Surety shall cause to be attached to this Bond a current and effective Power of Attorney evidencing the authority of the officer, agent, or representative who executed this Bond on behalf of Surety to execute, seal, and deliver such Bond and bind the Surety thereby.
10. This Bond is intended to conform to all applicable statutory requirements. Any applicable requirement of any applicable statute that has been omitted from this Bond shall be deemed to be included herein as if set forth at length. If any provision of this Bond conflicts with any applicable statute, then the provision of said statute shall govern and the remainder of this Bond that is not in conflict therewith shall continue in full force and effect.
11. The term "Bid" as used herein includes a Bid, offer, or proposal as applicable.

# UNIVERSAL SURETY COMPANY

Lincoln, Nebraska

## POWER OF ATTORNEY

### KNOW ALL MEN BY THESE PRESENTS:

That the **UNIVERSAL SURETY COMPANY**, a corporation of the State of Nebraska having its principal office in the City of Lincoln, Nebraska, pursuant to the following Bylaw, which was adopted by the Board of Directors of the said Company on July 23, 1981, to wit:

"Article V-Section 6. **RESIDENT OFFICERS AND ATTORNEYS-IN-FACT.** The President or any Vice President, acting with any Secretary or Assistant Secretary, shall have the authority to appoint Resident Vice Presidents and Attorneys-In-Fact, with the power and authority to sign, execute, acknowledge and deliver on its behalf, as Surety: Any and all undertakings of suretyship and to affix thereto the corporate seal of the corporation. The President or any Vice President, acting with any Secretary or Assistant Secretary, shall also have the authority to remove and revoke the authority of any such appointee at any time."

does hereby make, constitute and appoint

Robert W. Hansen, Jr. or Charlotte Ahrenholtz, Omaha, Nebraska

its true and lawful Attorney(s)-in-Fact, to make, execute, seal and deliver for and on its behalf, as Surety:  
Any and all undertakings of suretyship

And the execution of such bonds or undertakings in pursuance of these presents, shall be as binding upon said Company, as fully and amply, to all intents and purposes, as if they had been duly executed and acknowledged by the regularly elected officers of the Company at its offices in Lincoln, Nebraska, in their own persons.

The following Resolution was adopted at the Regular Meeting of the Board of Directors of the **UNIVERSAL SURETY COMPANY**, held on July 23, 1981:  
"RESOLVED, That the signatures of officers of the Company and the seal of the Company may be affixed by facsimile to any Power of Attorney executed in accordance with Article V-Section 6 of the Company Bylaws: and that any such Power of Attorney bearing such facsimile signatures, including the facsimile signature of a certifying Assistant Secretary and facsimile seal shall be valid and binding upon the Company with respect to any bond, undertaking or contract of suretyship to which it is attached."

All authority hereby conferred shall remain in full force and effect until terminated by the Company.  
IN WITNESS WHEREOF, **UNIVERSAL SURETY COMPANY** has caused these presents to be signed by its President and its corporate seal to be hereunto affixed this 19th day of September, 20 22.

*Carol J. Clark*

UNIVERSAL SURETY COMPANY

*Curt L. Hartter*




State of Nebraska } Secretary/Treasurer  
County of } ss. Lancaster  
By

President

On this 19th day of September, 20 22, before me personally came Curtis L. Hartter, to me known, who being by me duly sworn, did depose and say that (s)he resides in the County of Lancaster, State of Nebraska; that (s)he is the President of the **UNIVERSAL SURETY COMPANY**, the corporation described in and which executed the above instrument; that (s)he knows the seal of the said corporation; that the seal affixed to the said instrument is such corporate seal; that it was so affixed by order of the Board of Directors of said corporation; that (s)he signed (his) (her) name by like order; and that Bylaw, Article V-Section 6, adopted by the Board of Directors of said Company, referred to in the preceding instrument, is now in force.

*Tara Martin*



My Commission Expires February 16, 2026.

Notary Public

I, Philip C. Abel, Director of **UNIVERSAL SURETY COMPANY**, do hereby certify that the above and foregoing is a true and correct copy of a Power of Attorney executed by said **UNIVERSAL SURETY COMPANY**, which is still in full force and effect.

Signed and sealed at the City of Lincoln, Nebraska this 31st day of May, 20 23.

*Philip C. Abel*

Director



The Harold K. Scholz Company has been in business since 1972, is located in Ralston, NE and fabricates, installs and services power plant and substation switchgear in NE, IA, KS, MO, MN, and SD.

Our NE Sales Tax Exemption No: 1973215


**VCP-W**  
Medium-voltage vacuum circuit breaker

# Reliable circuit protection with improved maintenance and flexibility



**EATON**  
*Powering Business Worldwide*





## Improved medium-voltage protection **VCP-W vacuum circuit breakers**

The Eaton medium-voltage VCP-W circuit breaker is renowned for its ease of handling and maintenance. This OEM-friendly product is ideal for short-circuit protection and has numerous design variations to ensure all possible applications are supported. Eaton's patented flexible conductor system features fewer moving parts, which reduces friction and wear associated with rolling/sliding designs, and increases product lifespan. The VCP-W circuit breaker is the standard in reliability, control and protection for electrical equipment and circuits.




### New features

- Drop-in replacement for current VCP-W circuit breaker
- Simplified pole unit design with 89% fewer parts
- Partial discharge free
- Longer vacuum interrupter life (over 30K operations)



### Standards

- IEEE® C37.04-2018
- IEEE C37.09-2018



### Improved pole unit design

Eaton's simplified pole unit design incorporates patented conductors and has 89% fewer parts than the legacy VCP-W. The vacuum interrupters can be replaced in the field without special tooling or having to change the entire pole unit, thus reducing maintenance and labor costs.



### Improved drive rod design

Eaton's adjustable drive rod design enables the quick modification of vacuum interrupter compression in the field and eliminates the need to replace pole units that exhibit low compression due to contact erosion from high mechanism operations.

**Technical data**

5/15 kV VCP-W vacuum circuit breaker types rated on symmetrical current rating basis, per ANSI standards

Identification	Rated values ①②			Insulation level			Short-circuit ratings (reference C37.04-2018 and C37.09-2018 except where noted)							
	Maximum voltage (V)	Nominal three-phase MVA class	Rated voltage range factor	Power frequency withstand voltage (1 min.)	Lightning impulse withstand voltage (1.2 x 50 µs)	Rated continuous current at 60 Hz	Symmetrical interrupting current (I)	%dc component	Asymmetrical interrupting current (It)	Closing and latching current	Short-time withstand current	Interrupting time	Interrupting time (cycles at 60 Hz)	No-load (mechanical endurance)
Drawout circuit breaker type	kV rms		K	kV rms	kV peak	A rms ③	kA rms sym	% ④	kA rms asym total ⑤	kA peak ⑥	kA rms ⑥	ms	Cycles ⑦	⑧
5VCP-W25	4.76	N/A	1	19	60	1200	25	43	29	65	25	83/50	5/3	10,000
	4.76	N/A	1	19	60	2000	25	43	29	65	25	83/50	5/3	10,000
	4.76	N/A	1	19	60	3000	25	43	29	65	25	83/50	5/3	10,000
5VCP-W32	4.76	N/A	1	19	60	1200	31.5	43	37	82	31.5	83/50	5/3	10,000
	4.76	N/A	1	19	60	2000	31.5	43	37	82	31.5	83/50	5/3	10,000
	4.76	N/A	1	19	60	3000	31.5	43	37	82	31.5	83/50	5/3	10,000
5VCP-W40	4.76	N/A	1	19	60	1200	40	43	47	104	40	83/50	5/3	10,000
	4.76	N/A	1	19	60	2000	40	43	47	104	40	83/50	5/3	10,000
	4.76	N/A	1	19	60	3000	40	43	47	104	40	83/50	5/3	10,000
5VCP-W50	4.76	N/A	1	19	60	1200	50	43	58.5	130	50	83/50	5/3	10,000
	4.76	N/A	1	19	60	2000	50	43	58.5	130	50	83/50	5/3	10,000
	4.76	N/A	1	19	60	3000	50	43	58.5	130	50	83/50	5/3	10,000
50VCP-W63 (9)	4.76	N/A	1	19	60	1200	63	55	80	164	63	83/50	5/3	10,000
	4.76	N/A	1	19	60	2000	63	55	80	164	63	83/50	5/3	10,000
	4.76	N/A	1	19	60	3000	63	55	80	164	63	83/50	5/3	10,000
8VCP-W40	8.25	N/A	1	36	95	1200	40	43	47	104	40	83/50	5/3	10,000
	8.25	N/A	1	36	95	2000	40	43	47	104	40	83/50	5/3	10,000
	8.25	N/A	1	36	95	3000	40	43	47	104	40	83/50	5/3	10,000
8VCP-W50	8.25	N/A	1	36	95	1200	50	43	58.5	130	50	83/50	5/3	10,000
	8.25	N/A	1	36	95	2000	50	43	58.5	130	50	83/50	5/3	10,000
	8.25	N/A	1	36	95	3000	50	43	58.5	130	50	83/50	5/3	10,000
15VCP-W25	15	N/A	1	36	95	1200	25	43	29	65	25	83/50	5/3	10,000
	15	N/A	1	36	95	2000	25	43	29	65	25	83/50	5/3	10,000
	15	N/A	1	36	95	3000	25	43	29	65	25	83/50	5/3	10,000
15VCP-W32	15	N/A	1	36	95	1200	31.5	43	37	82	31.5	83/50	5/3	10,000
	15	N/A	1	36	95	2000	31.5	43	37	82	31.5	83/50	5/3	10,000
	15	N/A	1	36	95	3000	31.5	43	37	82	31.5	83/50	5/3	10,000
15VCP-W40	15	N/A	1	36	95	1200	40	43	47	104	40	83/50	5/3	10,000
	15	N/A	1	36	95	2000	40	43	47	104	40	83/50	5/3	10,000
	15	N/A	1	36	95	3000	40	43	47	104	40	83/50	5/3	10,000
15VCP-W50	15	N/A	1	36	95	1200	50	43	58.5	130	50	83/50	5/3	10,000
	15	N/A	1	36	95	2000	50	43	58.5	130	50	83/50	5/3	10,000
	15	N/A	1	36	95	3000	50	43	58.5	130	50	83/50	5/3	10,000
150VCP-W63 ⑨	15	N/A	1	36	95	1200	63	55	80	164	63	83/50	5/3	10,000
	15	N/A	1	36	95	2000	63	55	80	164	63	83/50	5/3	10,000
	15	N/A	1	36	95	3000	63	55	80	164	63	83/50	5/3	10,000

5/15 kV VCP-W vacuum circuit breaker types rated on symmetrical current rating basis, per ANSI standards (continued)

Identification	Rated values ①②			Insulation level			Short-circuit ratings (reference C37.04-2018 and C37.09-2018 except where noted)							
	Maximum voltage (V)	Nominal three-phase MVA class	Rated voltage range factor	Power frequency withstand voltage (1 min.)	Lightning impulse withstand voltage (1.2 x 50 µs)	Rated continuous current at 60 Hz	Symmetrical interrupting current (I)	%dc component	Asymmetrical interrupting current (It)	Closing and latching current	Short-time withstand current	Interrupting time	Interrupting time (cycles at 60 Hz)	No-load (mechanical endurance)
Drawout circuit breaker type	kV rms		K	kV rms	kV peak	A rms ③	kA rms sym	% ④	kA rms asym total ④	kA peak ⑤	kA rms ⑥	ms	Cycles ⑦	⑧
5VCP-W250	4.76	250	1	19	60	1200	36	40	41	97	36	83/50	5/3	10,000
	4.76	250	1	19	60	2000	36	40	41	97	36	83/50	5/3	10,000
	4.76	250	1	19	60	3000	36	39	41	97	36	83/50	5/3	10,000
5VCP-W350	4.76	350	1	19	60	1200	49	40	56	132	49	83/50	5/3	10,000
	4.76	350	1	19	60	2000	49	40	56	132	49	83/50	5/3	10,000
	4.76	350	1	19	60	3000	49	39	56	132	49	83/50	5/3	10,000
8VCP-W500	8.25	500	1	36	95	1200	41	40	47	108	41	83/50	5/3	10,000
	8.25	500	1	36	95	2000	41	40	47	108	41	83/50	5/3	10,000
	8.25	500	1	36	95	3000	41	39	47	111	41	83/50	5/3	10,000
15VCP-W500	15	500	1	36	95	1200	23	41	26	62	23	83/50	5/3	10,000
	15	500	1	36	95	2000	23	41	26	62	23	83/50	5/3	10,000
	15	500	1	36	95	3000	23	39	26	62	23	83/50	5/3	10,000
15VCP-W750	15	750	1	36	95	1200	36	40	41	97	36	83/50	5/3	10,000
	15	750	1	36	95	2000	36	40	41	97	36	83/50	5/3	10,000
	15	750	1	36	95	3000	36	39	41	97	36	83/50	5/3	10,000
15VCP-W1000	15	1000	1	36	95	1200	48	40	55	130	48	83/50	5/3	10,000
	15	1000	1	36	95	2000	48	40	55	130	48	83/50	5/3	10,000
	15	1000	1	36	95	3000	48	39	55	130	48	83/50	5/3	10,000

- ① All circuit breakers are tested at 60 Hz and cannot be applied at 50 Hz per C37.09-2018. If 50 Hz is required, use VCP-W Legacy breaker offering. Contact Eaton for required ratings.
- ② All breakers in this chart are UL Listed.
- ③ 3000 A rated breakers can be fan-cooled for use in 4000 A rated switchgear.
- ④ All breakers tested to C37.09-2018 meet the requirements for the last pole to clear during asymmetrical T100a tests defined by Table 3 of the standard, and can safely be applied at the rated asymmetrical interrupting current and %dc offset as calculated by the equations within C37.09-2018 and C37.04-2018. Ratings are based on a dc time constant of 45 ms (corresponding to X/R of 17 for 60 Hz) and determined using the circuit breaker minimum opening time plus the assumed minimum relay time of 1/2 cycle (8.33 ms for 60 Hz).
- ⑤ These breakers were tested to (2.6 \* I) for close and latch.
- ⑥ Duration of short-time current and maximum permissible tripping delay are both 2 seconds for all circuit breakers listed in this table, as required in C37.04-2018 and C37.09-2018.
- ⑦ All circuit breakers are available as 3 or 5 cycle breakers.
- ⑧ Each operation consists of one closing plus one opening.
- ⑨ These circuit breakers do not come with the upgraded pole units and were tested to earlier versions of the IEEE standards and can be applied at 50 Hz with no derating.

### Standard features

- C2 class capacitor switch ratings
- Tin-plated pole units for resilience in harsh environment applications
- Maintenance-free Eaton vacuum interrupters with visual contact erosion indicators
- Glass polyester insulators
- Epoxy insulators (included with type VCP-WSE breakers)
- Trip-free interlocks that prevent moving a closed circuit breaker into or out of the connect position
- Provisions for manual charging of closing spring
- Operations counter
- Closing spring charged/discharged indicator
- Circuit breaker open/closed indicator
- Spring charging motor, close coil, trip coil, latch check switch, and anti-pump relay
- Cut-out visual wipe spring indicator
- Primary and secondary fully automatic disconnects
- Ground contact finger assembly
- Auxiliary switch with 2A/3B spare contacts

### Benefits

- Premium control wires and terminals provide reliable control and protection for electrical equipment and circuits, and are capable of being operated manually under full load conditions
- Front-accessible mechanism allows for easy access to the mechanism and user-friendly control components
- Unlike sliding or rolling designs, Eaton's flexible conductors have no moving parts to wear out and are maintenance-free—resulting in longer circuit breaker life
- Spiral contact design provides a self-induced magnetic effect that moves the arc root around the contact periphery, preventing hot spots and minimizing contact erosion
- Mechanically and electrically trip-free stored energy mechanism design ensures breaker contacts will not close or touch during a trip or close command; for added user safety, the closing springs will discharge automatically when the breaker is withdrawn from or inserted into its compartment

### Order entry

VCP-W circuit breakers are now fully configurable with a 15-digit catalog number and will come with a QR code that can be used to view breaker-specific information online.



CAT NO: VWEAEBAGCCXRXXX

FOR REPLACEMENT BREAKER,  
USE CAT.NO. FOR ORDER ENTRY

KIJHYDMSLPOQKIHDK  
DJUHWK



61A 702CH01



VCP-W circuit breakers—  
one of the **most trusted**  
medium-voltage breakers  
for over 50 years



# We make what matters work.\*

\* At Eaton, we believe that power is a fundamental part of just about everything people do. Technology, transportation, energy and infrastructure—these are things the world relies on every day. That's why Eaton is dedicated to helping our customers find new ways to manage electrical, hydraulic and mechanical power more efficiently, safely and sustainably. To improve people's lives, the communities where we live and work, and the planet our future generations depend upon. Because that's what really matters. And we're here to make sure it works.

See more at [Eaton.com/whatmatters](https://www.eaton.com/whatmatters)



For more information,  
call 1-877-ETN-CARE (1-877-386-2273)  
or scan the QR code to visit [our website](https://www.eaton.com/whatmatters)

**Eaton**  
1000 Eaton Boulevard  
Cleveland, OH 44122  
United States  
[Eaton.com](https://www.eaton.com)

© 2022 Eaton  
All Rights Reserved  
Printed in USA  
Publication No. BR131001EN / Z26134  
March 2022

Eaton is a registered trademark.

All other trademarks are property  
of their respective owners.

Follow us on social media to get the  
latest product and support information.



# Metal-Clad Switchgear— VacClad-W—Medium Voltage Drawout Vacuum Breakers

## Contents

### Metal-Clad Vacuum Breaker Switchgear—VacClad-W—Medium Voltage

General Description . . . . .	5.1-1
5 and 15 kV Switchgear—36.00-Inch Wide . . . . .	5.1-4
5 kV Switchgear—26.00-Inch Wide . . . . .	5.1-8
27 kV Switchgear—36.00-Inch Wide . . . . .	5.1-9
38 kV Switchgear—42.00-Inch Wide . . . . .	5.1-10
Arc-Resistant Switchgear . . . . .	5.2-1
Partial Discharge Sensing and Monitoring for Switchgear . . . . .	5.3-1
Technical Data . . . . .	5.4-1
Circuit Breakers . . . . .	5.4-1
Switchgear . . . . .	5.4-13
Standard Metal-Clad Switchgear Assembly Ratings . . . . .	5.4-15
Arc-Resistant Switchgear Assembly Ratings . . . . .	5.4-16
Surge Protection . . . . .	5.4-17
Control Equipment . . . . .	5.4-22
Control Schematics . . . . .	5.4-24
Relays—Device Numbers, Type and Function . . . . .	5.4-26
Main-Tie-Main Arrangements . . . . .	5.4-29
Layout Dimensions . . . . .	5.5-1
5 and 15 kV (Standard Metal-Clad) . . . . .	5.5-1
27 kV (Standard Metal-Clad) . . . . .	5.5-11
38 kV (Standard Metal-Clad) . . . . .	5.5-15
5 and 15 kV (Arc-Resistant Metal-Clad) . . . . .	5.5-19
27 kV (Arc-Resistant Metal-Clad) . . . . .	5.5-30
38 kV (Arc-Resistant Metal-Clad) . . . . .	5.5-34
Arc Exhaust Chamber (Plenum) Room Layouts . . . . .	5.5-38
<b>Transfer Switches—Medium Voltage . . . . .</b>	<b>See Tab 12</b>

### Specifications

See Eaton's *Product Specification Guide*, available on CD or on the Web.

CSI Format: . . . . .	1995	2010
	<b>Section 16346</b>	<b>Sections 26 13 26</b>



*VacClad-W Metal-Clad Switchgear*

---

*This page intentionally left blank.*

**General Description**

**Application Description**

Eaton's VacClad-W metal-clad switchgear with Type VCP-W vacuum breakers provides centralized control and protection of medium voltage power equipment and circuits in industrial, commercial and utility installations involving generators, motors, feeder circuits, and transmission and distribution lines.

VacClad-W switchgear is available in maximum voltage ratings from 4.76 kV through 38 kV, and interrupting ratings as shown below. VacClad-W offers a total design concept of cell, breaker and auxiliary equipment, which can be assembled in various combinations to satisfy user application requirements. Two-high breaker arrangements are standard up to 15 kV. One-high arrangements can be furnished when required.

**Ratings**

**Maximum Voltages:**

4.76 kV, 8.25 kV, 15 kV, 27 kV, 38 kV

**Interrupting Ratings:**

4.76 kV: Up to 63 kA  
8.25 kV: Up to 63 kA  
15.0 kV: Up to 63 kA  
27.0 kV: Up to 40 kA  
38.0 kV: Up to 40 kA

**Continuous Current—Circuit Breakers:**

1200A, 2000A, 3000A (5 and 15 kV)  
4000A Forced cooled (5 and 15 kV)  
1200A, 2000A, (27 kV)  
600A, 1200A, 1600A, 2000A,  
2500A (38 kV)  
3000A Forced cooled (38 kV)

**Continuous Current—Main Bus:**

1200A, 2000A, 3000A (5 and 15 kV)  
4000A (5 and 15 kV)  
1200A, 2500A (27 kV)  
1200A, 2000A, 2500A, 3000A (38 kV)

**Note:** Continuous currents above 4000A, contact Eaton.

**Certifications**


- UL and CSA listings are available



*Typical Indoor Assembly with a Breaker Withdrawn on Rails*



*VCP-W Breaker Element*



*Cut-Away View of Vacuum Interrupter (Enlarged to Show Detail)*

**Advantages**

Eaton's Electrical Sector has been manufacturing metal-clad switchgear for over 50 years, and vacuum circuit breakers for over 30 years. Tens of thousands of Eaton vacuum circuit breakers, used in a wide variety of applications, have been setting industry performance standards for years.

With reliability as a fundamental goal, Eaton engineers have simplified the VacClad-W switchgear design to minimize problems and gain trouble-free performance. Special attention was

given to material quality and maximum possible use was made of components proven over the years in Eaton switchgear.

Maintenance requirements are minimized by the use of enclosed long-life vacuum interrupters. When maintenance or inspection is required, the component arrangements and drawers allow easy access. VacClad-W's light weight simplifies handling and relocation of the breakers.

## General Description

## Standards

Eaton's VacClad-W switchgear meets or exceeds ANSI/ IEEE C37.20.2 and NEMA® SG-5 as they apply to metal-clad switchgear. The assemblies also conform to Canadian standard CSA®-C22.2 No. 31-04, and EEMAC G8-3.2. Type VCP-W vacuum circuit breakers meet or exceed all ANSI and IEEE standards applicable to AC high voltage circuit breakers rated on symmetrical current basis.

## Seismic Qualification




5

Refer to **Tab 1** for information on seismic qualification for this and other Eaton products.

Metal-Clad Switchgear  
Compartmentalization

Medium voltage metal-clad switchgear equipment conforming to C37.20.2 is a compartmentalized design, wherein primary conductors are fully insulated for the rated maximum voltage of the assembly, and all major primary circuit components are isolated from each other by grounded metal barriers. This type of construction minimizes the likelihood of arcing faults within the equipment and propagation of fault between the compartments containing major primary circuits.

The C37.20.2 metal-clad switchgear equipment is designed to withstand the effects of short-circuit current in a bolted fault occurring immediately downstream from the load terminals of the switchgear. The bolted fault capability is verified by short-time and momentary short-circuit withstand current testing on complete switchgear, as well as by fault making (close and latch) testing on the switching devices as shown in **Figure 5.1-1**.



**Figure 5.1-1. Metal-Clad Switchgear Short-Circuit and Momentary Withstand Tests**

The short-time current withstand tests demonstrate electrical adequacy of busses and connections against physical damage while carrying the short-circuit current for a given duration. The momentary current withstand tests demonstrate the mechanical adequacy of the structure, busses and connections to withstand electro-magnetic forces with no breakage of insulation. It should be noted that design testing of standard metal-clad switchgear does not involve any internal arcing faults.


## Features—Vacuum Circuit Breaker

- High power laboratory tests prove VCP-W breakers are capable of 50 to 200 full fault current interruptions
- V-Flex (stiff-flexible) current transfer from the vacuum interrupter moving stem to the breaker primary disconnecting contact is a non-sliding/non-rolling design, which eliminates maintenance required with the sliding/rolling type transfer arrangements. The V-Flex system provides excellent electrical and thermal transfer, and long vacuum interrupter life.
- Easy inspection and accessibility is afforded by a front-mounted stored energy operating mechanism. The same basic mechanism is used on all ratings, which requires a minimum investment in spare parts


- All VCP-W circuit breakers are horizontal drawout design, which provides connect, test and disconnect position. A latch secures the breaker in the connected and disconnected/test position. 5/15/27 kV breakers can be fully withdrawn on extension rails for inspection and maintenance without the need for a separate lifting device. 38 kV circuit breaker is designed to roll directly on the floor
- All breaker functions, indicators and controls are grouped on an easily accessible panel on front of the breaker
- Trip-free interlocks prevent moving a closed circuit breaker into or out of the connected position
- Breaker cannot be electrically or mechanically closed when in the intermediate position
- Closing springs automatically discharge before moving the circuit breaker into or out of the enclosure
- Breaker frame remains grounded during levering and in the connected position
- Coding plates are provided to ensure only correct breaker rating can be installed in cell
- Quality Assurance Certificate is included with each circuit breaker
- Easy-to-see contact erosion indicator is provided as standard on the vacuum interrupter moving stem. Only periodic visual inspection is required to verify that the contacts have not worn out
- A simple visual means, T-cutout, is provided to verify by simple visual inspection that the loading springs are applying proper pressure to the contacts when the breaker is closed
- Corona-free design increases circuit breaker reliability and in-service life by maintaining insulation integrity
- Vacuum interrupters with copper-chrome contacts provide superior dielectric strength and very low chop current
- High-strength, high-impact, track-resistant glass polyester on 5/15 kV and cycloaliphatic epoxy on 27/38 kV is used for primary insulation and support as standard

**General Description**

**Type VCP-W Vacuum Circuit Breakers**




*Type VCP-W 5/15 kV Circuit Breaker*




*Cut-away View of Vacuum Interrupter (Enlarged to Show Detail)*


**5**



*Type VCP-W 27 kV Circuit Breaker—Side View*



*Type VCP-W 38 kV Circuit Breaker—Front View*



*Type VCP-W 38 kV Circuit Breaker—Rear View*

**Type VCP-W Circuit Breaker—Features**



## General Description—Switchgear

### Features—Switchgear Assembly

#### VacClad is a Metal-Clad Design

Eaton's VacClad switchgear is an integrated assembly of drawout vacuum circuit breakers, bus and control devices coordinated electrically and mechanically for medium voltage circuit protection and control. The metal-clad integrity provides maximum circuit separation and safety.

- All circuit breakers are equipped with self-aligning and self-coupling primary and secondary disconnecting devices, and arranged with a mechanism for moving it physically between connected and disconnected positions
- All major primary components, such as circuit breaker, voltage transformer, control power transformer, and buses are completely enclosed and grounded by metal barriers. A metal barrier in front of the circuit breaker and auxiliary drawer ensures that, when in the connected position, no live parts are exposed by opening the compartment door
- Automatic shutters cover primary circuit elements when the removable element is in the disconnected, test or removed position
- All primary bus conductors and connections are insulated with track-resistant fluidized bed epoxy coating for rated maximum voltage of the assembly
- Mechanical interlocks are provided to maintain a proper and safe operating sequence
- Instruments, meters, relays, secondary control devices and their wiring are isolated, where necessary, by grounded metal barriers from all primary circuit elements

#### VacClad is Corona Free

Corona emissions within the standard VacClad switchgear assemblies have been eliminated or reduced to very low levels by special fabrication and assembly techniques, such as rounding and buffing of all sharp copper edges at the joints, employing star washers for bolting metal barriers, and using specially crafted standoff insulators for primary bus supports. By making switchgear assemblies corona-free, Eaton has made its standard switchgear more reliable.


### Circuit Breaker Compartment

- The mechanism for levering the breaker is a unique cell mounted design. It incorporates all the safety interlocks to render the breaker mechanically and electrically trip-free during the levering procedure
- A silver-plated copper ground bus provided on the levering pan assembly is engaged by a spring loaded ground contact on the circuit breaker to ensure that the circuit breaker remains grounded throughout its travel


### Type VCP-W Metal-Clad Switchgear Assembly (5/15 kV Shown)



Front View



Circuit Breaker Compartment



Circuit Breaker Compartment Shown with Shutters Opened for Illustration

**General Description—Switchgear**


**Circuit Breaker Compartment  
(Continued)**

- Each circuit breaker compartment is provided with steel shutters (breaker driven) that automatically rotate into position to cover the insulating tubes and stationary cell studs to prevent accidental contact with live primary voltage, when the breaker is withdrawn from the connected position
- Current transformers installed over the primary insulating tubes, located behind the steel shutters, are front accessible. Up to four standard accuracy current transformers can be installed per phase. Front accessibility permits adding or changing the transformers when the unit is de-energized without breaking high voltage connections and primary insulation
- Code plates ensure that only correct breaker rating can be installed in cell

- Control power transformer drawer is mechanically interlocked with the transformer secondary main breaker that requires the main breaker to be opened, so that the primary circuit is disconnected only under no-load when the drawer is withdrawn

- Grounding straps are provided in each drawer to automatically ground and discharge primary fuses when the drawer is withdrawn

**Type VCP-W Metal-Clad Switchgear Assembly (5/15 kV Shown)**




**Drawout Auxiliaries**

**Auxiliary Compartments**


5/15 kV VacClad design permits up to four auxiliary drawers in one vertical unit (only two shown in the photo). These drawers can be used for installing voltage or control power transformers, or primary fuses. Each drawer can also be configured for use as a battery tray.

- Each auxiliary drawer is a horizontal drawout design that can be fully withdrawn on extension rails similar to the breaker, thus allowing front access to auxiliary equipment to permit easy testing and fuse replacement
- A safety shutter (operated by the drawer) is included in each auxiliary drawer compartment. It automatically operates when the auxiliary drawer is withdrawn to protect workmen from accidental contact with the stationary primary contacts
- Each auxiliary drawer can accommodate two voltage transformers, connected line-to-line (open delta); three voltage transformers, connected line-to-ground; or single-phase control power transformer up to 15 kVA, 15 kV with their associated primary fuses. Three-phase control power transformer, or single-phase transformers larger than 15 kVA can be fixed mounted within the structure, with their primary fuses installed in the auxiliary drawer



**VT Drawer Shown Fully Withdrawn on Rails**

**CPT Drawer Shown Fully Withdrawn on Rails**



**VT/CPT Compartment with VT/CPT Drawer Removed—Inside View**


## General Description—Switchgear

### Rear Compartments


Rear of each structure is segregated into main bus and cable compartments by grounded metal barriers, as required for a given application. Access to main bus and power cable connections is provided from the rear through removable bolted covers or optional rear hinged doors. Cable trough (chimney) is provided to segregate upper and lower compartment power cables as required.

- All primary buses (main bus and line and load runbacks) are 100% conductivity copper, and insulated for rated maximum voltage of the assembly by flame retardant, track-resistant fluidized epoxy coating. The bolted bus joints are silver- or optionally tin-plated for positive contact and low resistance, with each joint insulated with easily installed boots. Bus supports between the adjacent units are made of high-impact, high-strength, track-resistant glass polyester at 5 and 15 kV, and cycloaliphatic epoxy at 27 and 38 kV
- Adequate space is available for cable termination, bus duct connection, installation of zero sequence current transformers, and surge arresters. In two-high arrangement, power cables for each circuit are separated by metal barriers
- A bare copper ground bus is provided in the rear of each structure, which extend the entire length of the switchgear
- All control wiring is isolated from primary circuit elements by grounded metal-conduit or braided metal jacket, with the exception of short lengths of wire such as at instrument transformer terminals


### Type VCP-W Metal-Clad Switchgear Assembly (5/15 kV Shown)




**Breaker Shown in the Connected Position**



**Breaker Shown in the Test/  
Disconnected Position**



**Breaker Shown in the Fully  
Withdrawn Position**



**Main Bus Details**

## Roll-on-the-Floor Breaker Option




*Roll-on-the-Floor Switchgear Compartment*

An optional direct roll-in breaker designed for use in upper and lower compartment of 5/15 kV indoor and outdoor walk-in aisle switchgear is available for all 5/15 kV VCP-W, VCP-WC and VCP-WG circuit breakers. Breaker is fitted with special wheel kit, and compartment interface is modified to allow circuit breaker to be rolled directly from the floor into the switchgear compartment, or from switchgear compartment onto the floor without a need for external lifting device or dolly. The circuit breaker can be supplied with all four fixed wheels or can be supplied with two swivel-type wheels on the front and two fixed wheels on the rear. In 2-high construction, the roll-on-the-floor breaker option is available for breakers in upper or lower compartments, however, removal of upper breaker requires external lifter and lift pan, which are optional accessories.

When using a 1200 or 2000A circuit breaker in the lower compartment, the compartment above the breaker can be left blank or used of auxiliaries, such as VTs or single-phase CPT, or primary fuses for three-phase or larger than 15 kVA single-phase CPTs. When using 3000A circuit breaker in the lower compartment, the compartment above the breaker is left blank for ventilation. The design is rated for application in Seismic Zone 4 environment. It can also be supplied with UL or CSA label for certain ratings. Contact Eaton for ratings available with UL/CSA label. The overall dimensions of the 5/15 kV indoor and outdoor walk-in aisle structures with the roll-on-the-floor breaker option are the same as the standard structures that use standard non roll-on-the-floor circuit breakers.



*VCP-W Direct Roll-in Breaker with Fixed Wheels*




*VCP-W Direct Roll-in Breaker with Swivel Wheels on Front*

## General Description


### 26.00-Inch (660.4 mm) Wide 5 kV 250 MVA Switchgear



Fully Withdrawn Breaker



Automatic Shutters



Fused PT Drawer

### Application Description

This narrow width VacClad-W MV Metal-Clad switchgear was designed for use in instances where floor space requirements would not allow the industry standard 36.00-inch (914.4 mm) wide switchgear. Typical applications include not only new construction but also replacement switchgear for installations previously equipped with 26.00-inch (660.4 mm) wide air-break devices. This line of switchgear has also been used where 5 kV, 1200A, 250 MVA applications are commonplace, such as generator and control applications.

### Ratings

The 26.00-inch (660.4 mm) wide switchgear line is designed for use with Eaton's Type VCPW-ND "Narrow Design" vacuum circuit breakers rated 4.76 kV, 60 kV BIL, 250 MVA, 1200A maximum, with rated main bus of 1200 or 2000A. For installations requiring 2000A main breakers with 1200A feeders, lineups can be built with standard 36.00-inch (914.4 mm) wide main breaker cubicles and 26.00-inch (660.4 mm) wide feeders.

### Configurations

#### 26.00-Inch (660.4 mm) Wide Standard Model

The 26.00-inch (660.4 mm) wide design is flexible. Available configurations include breaker over breaker, one or two auxiliary drawers over breaker, breaker over one or two auxiliary drawers, or up to four auxiliary drawers in one vertical section. The standard height and depth are 95.00-inch (2413.0 mm) and 96.25-inch (2444.8 mm) respectively. A breaker over auxiliary, or auxiliary over breaker combination can be supplied in reduced depth of 86.25-inch (2190.8 mm). The depth of breaker over breaker combination can also be reduced to 86.25-inch (2190.8 mm) if power cables for top breaker enter from the top and the cables for bottom breaker enter from the bottom.

The main bus location and connections in the standard 95.00-inch (2413.0 mm) high 26.00-inch (660.4 mm) wide design are 100% compatible with standard 95.00-inch (2413.0 mm) high 36.00-inch (914.4 mm) wide vertical sections. As a result, additions to existing Eaton 5 kV, 250 MVA 36.00-inch (914.4 mm) wide VCP-W installations can be simply and rapidly performed without costly system modifications and transition sections. Refer to **Pages 5.5-7** and **5.5-8** for available configurations, dimensions and weights.

#### 26.00-Inch (660.4 mm) Wide Low Profile Model

In addition to the floor space saving offered by the standard 26.00-inch (660.4 mm) wide model, a further saving in the height and depth of the switchgear is also available. Where height and depths are an issue, such as an outdoor powerhouse or in a mobile power container, the standard 95.00-inch (2413.0 mm) high unit can be reduced to an 80.00-inch high (2032.0 mm), 72.00-inch (1828.9 mm) deep low profile model. Main bus rating available in the 80.00-inch (2032.0 mm) high x 72.00-inch (1828.9 mm) deep low profile model is limited to 1200A maximum. It is not compatible in size or location with standard 26.00-inch (660.4 mm) wide or 36.00-inch (914.4 mm) wide, 95.00-inch (2413.0 mm) high VCP-W units.

The low profile model is designed to house breaker over auxiliary or auxiliary over breaker, or auxiliary over auxiliary. In order to provide maximum vertical space for power cable terminations, auxiliary over breaker configuration should be used for customer's top entrance cables, and breaker over auxiliary configuration should be used for customer's bottom entrance cables. Auxiliary compartments are designed to accommodate one or two auxiliary drawers. That is, up to four auxiliary drawers can be installed in an auxiliary over auxiliary configuration. A set of two line-to-line or three line-to-ground connected voltage transformers, or a single-phase control power transformer up to 15 kVA can be installed in each auxiliary drawer. Because of the reduced depth, control devices cannot be located on breaker compartment door. All control devices should be located on the auxiliary compartment doors. Refer to **Pages 5.5-9** for available configurations, dimensions and weights.

For all 26.00-inch (660.4 mm) wide configurations, multifunction microprocessor-based relays and meters, such as Eaton's Digitrip® 3000 and IQ meters are recommended for reduced panel space.

**General Description**

**27 kV Metal-Clad Switchgear**

**Application Description**

Eaton's 27 kV nominal metal-clad switchgear is used for applications at system voltages higher than 15 kV, up to and including 27 kV. It is designed for use with Type VCP-W, horizontal drawout vacuum circuit breakers.

**Ratings**


- Maximum rated voltage: 27 kV rms  
**Note:** Eaton tested to 28.5 kV.
- BIL withstand: 125 kV peak
- Maximum symmetrical interrupting: 16 kA, 22 kA, 25 kA, 40 kA rms
- Continuous current:  
Circuit breakers—1200A, 2000A  
Switchgear main bus—  
One-high design: 1200A, 2000A  
Two-high design: 1200A, 2000A, 2500A, 2700A

**Features and Configurations**


27 kV metal-clad switchgear design is an extension of Eaton's 5 and 15 kV VacClad design. It has same footprint and overall space envelop, and it incorporates all features and advantages of the 5 and 15 kV VacClad design, with the exception of some modifications required for 27 kV application.

- Uses horizontal drawout type VCP-W 125 kV BIL rated vacuum circuit breakers
- A cycloaliphatic epoxy insulation material is used throughout the switchgear housings and the circuit breakers for phase-to-ground and phase-to-phase primary bus supports. For decades, cycloaliphatic epoxy insulation has demonstrated its outstanding electrical and mechanical characteristics in harsh outdoor applications. The use of this insulation system with the 27 kV design ensures a comfortable margin of safety at higher voltages
- All primary bus conductors are insulated for full 28.5 kV by fluidized epoxy coating. All buses are fabricated from 100% conductivity copper. Bus joints are silver- or tin-plated as required, and covered with pre-formed insulating boots to maintain metal-clad integrity
- Available configurations include: auxiliary over breaker, and auxiliary over auxiliary. Each auxiliary or breaker requires one-half vertical space


- Each auxiliary drawer can accommodate two voltage transformers connected line-to-line, or three voltage transformers connected line-to-ground, which can be withdrawn for easy maintenance and replacement of primary fuses
- When required by an application, a single-phase control power transformer up to 37.5 kVA, or a three-phase control power transformer up to 75 kVA can be fixed mounted in the front bottom compartment, with the primary fuses in an auxiliary drawer located in the upper compartment. When the control power transformer is located remotely from the switchgear, but fed through primary fuses located in the switchgear, the fuses are installed in an auxiliary drawer. The primary fuse drawer is key interlocked with the control power transformer secondary main breaker to ensure that it is opened first, and transformer load is disconnected, before the fuse drawer can be withdrawn
- 27 kV metal-clad switchgear is available in general purpose, ventilated, indoor or outdoor aisleless type enclosure
- Two-high 27 kV arrangements with breaker-over-breaker are available in indoor type enclosure
- **Roll-on-the-floor configurations are available**



**27 kV VCP-W Circuit Breaker—Side View**



**27 kV Switchgear—Front View**



**27 kV Switchgear—Rear View**

## General Description

### 38 kV Metal-Clad Switchgear

#### Application Description

Eaton's VacClad switchgear family is designed for use in applications with distribution voltages up to 38 kV maximum. Typical applications include not only new construction but also replacement for older air-break, minimum oil or SF6 switchgear. The circuit breaker and switchgear will meet industry requirements for greater safety, quality, superior reliability and minimal maintenance while providing higher insulation levels in less space than other breaker types, thus reducing overall switchgear size for significant space savings.

5



#### Ratings

- Maximum rated voltage: 38 kV rms
- BIL withstand: 150 and 170 kV peak
- Maximum symmetrical interrupting with K = 1: 16 kA, 25 kA, 31.5 kA, 40 kA rms, and 35 kA rms (21 kA rating with K = 1.65)
- Continuous current:  
Circuit breakers—up to 2500A  
Switchgear main bus—up to 3000A

#### Features—38 kV Vacuum Circuit Breaker

- Corona-free design increases circuit breaker reliability and in-service life by maintaining insulation integrity
- Superior cycloaliphatic epoxy insulation—a void-free insulating material with outstanding electrical and mechanical characteristics, such as track resistance, dielectric strength, and fungus resistance, even in harsh industrial environment—is used throughout the circuit breaker as primary phase-to-phase and phase-to-ground insulation
- Axial-magnetic, copper-chrome contacts are used in 38 kV vacuum interrupters to provide superior dielectric strength, better performance characteristics, and lower chop current
- High power laboratory tests prove VCP-W breakers are capable of 50 to 200 full fault current interruptions
- V-Flex (stiff-flexible) current transfer from the vacuum interrupter moving stem to the breaker primary disconnecting contact is a non-sliding/non-rolling design, which eliminates maintenance required with the sliding/rolling type transfer arrangements. The V-Flex system provides excellent electrical and thermal transfer, and long vacuum interrupter life

- Easy inspection and accessibility is afforded by front mounted stored energy operating mechanism. The same basic mechanism is used on all ratings, which requires a minimum investment in spare parts
- All 38 kV circuit breakers are horizontal drawout design, which provide connect, test and disconnect position. A latch secures the breaker in the connected and disconnected/test position. The circuit breaker is designed to roll directly on the floor



**Features—38 kV Vacuum  
Circuit Breaker (Continued)**

- All breaker controls and indicators are functionally grouped on the front control panel and include: main contact status, closing spring status, port for manual spring charging, close and trip button, and mechanical operations counter
- Clearly visible contact erosion indicator on the front of the breaker
- Trip-free interlocks prevent moving a closed circuit breaker into or out of the connected position
- Breaker cannot be electrically or mechanically closed when in the intermediate position
- Closing springs automatically discharge before moving the circuit breaker into or out of the enclosure
- Breaker frame remains grounded during levering and in the connected position
- Coding plates are provided to ensure only correct breaker rating can be installed in cell
- Quality Assurance Certificate is included with each circuit breaker

Provision for Padlocking Shutter in Closed Position



Breaker Levering Pan Assembly

TOC Switch

MOC Switch


**38 kV Switchgear—Circuit Breaker  
Compartment**

**Features—38 kV  
Switchgear Assembly**

Like the circuit breaker described above, the 38 kV switchgear assembly is a corona-free metal-clad design. It incorporates many features and advantages of 5, 15 and 27 kV VacClad design, with additional modifications required for 38 kV application.

- Industry-leading cycloaliphatic epoxy supports are used for primary phase-to-phase and phase-to-ground insulation throughout, providing 170 kV BIL and 80 kV (1 minute) power frequency withstand capability
- All primary bus conductors are insulated for full 38 kV by fluidized epoxy coating. All buses are fabricated from 100% conductivity copper. Bus joints are silver- or tin-plated as required, and covered with Eaton's pre-formed insulating boots to maintain metal-clad integrity


Control Compartment      Control Devices



Breaker Compartment

**38 kV Switchgear—Control Compartment**

Ground Bus      Secondary Disconnect      MOC Switch  
Beneath this Cover



Guide Rail

Racking Screw and Moving Block Assembly

Code Plates


Provision for Padlocking

Breaker Pan Assembly

**Breaker Levering Pan Assembly**

- Circuit breaker compartment is designed to interface with Type VCP-W 38 kV circuit breaker. It includes floor-mounted breaker pan assembly (levering assembly) with all safety interlocks required by the metal-clad design. Cell mounted guide rails accurately guide the breaker into the cell during levering, and ensure correct alignment of the circuit breaker primary disconnects with the cell primary contacts when breaker reaches connected position
- Coding plates are provided to ensure only correct breaker rating can be installed in the cell
- Automatic steel shutters cover cell primary contacts when circuit breaker is withdrawn from its connected position, to prevent persons from accidentally touching the stationary primary cell contacts. Each shutter can be padlocked in the closed or open position. It can also be manually latched open as required for maintenance

Steel Shutter      Shutter Latch (Manual)      Primary Contact Housing



Stationary Primary Contacts


Shutter Latch (Manual)

Steel Shutter

**Breaker Compartment (Shutter Shown Open for Illustration)**

## General Description—38 kV Switchgear

### Features—38 kV Switchgear Assembly (Continued)



*VT/CPT Primary Fuse Drawer (Shown with Door Open)*

- A separate control compartment is provided for installation of protection, metering and control devices. No devices are located on circuit breaker compartment door
- Rear of the switchgear is divided in main bus and cable compartments, isolated from each other by grounded metal barriers. Sufficient space is available for customer's top or bottom entry power cables. Bus duct terminations can also be supplied. A bare copper ground bus is provided along the entire lineup, with an extension in each cable compartment for termination of power cable shields

### 38 kV, 170 kV BIL Design

- Line side current transformer bushings are included as standard. Bus side current transformer bushings are only included when bus side current transformers are supplied
- Ring-type current transformers are installed over bus or line side primary insulating bushings as required. They are accessible from the rear of the unit. Maximum two sets of standard accuracy or one set of high accuracy current transformers can be installed on the bus side; and three sets of standard accuracy or one set of standard, and one set of high accuracy transformers can be installed on the line side
- Voltage and control power transformers (VTs and CPTs), when required, are stationary mounted

inside the cubicle, with their primary fuses installed in a drawout auxiliary drawer


- Each primary fuse drawer is provided with a levering mechanism for moving the drawer within its compartment between connected and disconnected positions, with the compartment door closed. The levering mechanism is mechanically interlocked with the compartment door such that the door cannot be opened, and access to the primary fuses cannot be gained, until the drawer is levered out to the disconnected position. A colored flag visible through a small viewing window on the compartment door indicates the position of the drawer inside the compartment as follows:
  - Red Color—drawer is in the fully connected position
  - Green Color—drawer is in the fully disconnected position
  - Orange Color—drawer is in-between connected and disconnected position
- Also provided are grounding straps to automatically discharge the fuses as they are pulled from the fuse holders
- On VT fuse drawers, a cell switch automatically disconnects the secondary circuit before the primary fuses are disconnected as the drawer is withdrawn
- On CPT fuse drawers, the compartment door is key interlocked with the CPT main secondary circuit

breaker such that the access to the drawer levering mechanism is blocked until the secondary main breaker is opened


### 38 kV, 150 kV BIL Design

- This design is similar to 38 kV, 170 kV BIL design described previously, except main bus is oriented differently and the design is provided with drawout VT with integral fuses, and front accessible CTs. Each 38 kV 150 kV BIL indoor structure is 42.00-inch (1066.8 mm) wide x 95.00-inch (2413 mm) high x 124.36-inch (3158.8 mm) deep. The 150 kV BIL assembly uses the same 38 kV circuit breakers as in 170 kV BIL assemblies. The breakers are interchangeable between the two designs
- Voltage transformers are equipped with integral top-mounted primary fuses and installed in an auxiliary compartment. Two auxiliary compartments can be provided in one vertical section. Each auxiliary compartment can be supplied with 1, 2 or 3 VTs, and can be connected to bus or line, as required for a given application. The VTs assembly is located behind a fixed bolted panel, and provided with mechanism for moving it between connected and disconnected position. The VT assembly is interlocked with the fixed bolted panel such that the panel cannot be removed unless the VTs are withdrawn to disconnected position. A shutter assembly covers the primary stabs when VTs are withdrawn to disconnected position. A mechanism is also provided to automatically discharge VT primary fuses as the VTs are withdrawn from connected to disconnected position
- Ring type current transformers are installed over bus or line side primary insulating bushings, located behind the steel shutters, in the breaker compartment. In this design, the CTs are easily accessible from the front, after removal of the circuit breaker. The front accessibility permits adding or changing the CTs when the equipment is de-energized, but without removal of high voltage joints or primary insulation. The design allows installations of two sets of standard or one set of high accuracy CTs on each side of the circuit breaker
- As of this update, the 38 kV, 150 kV BIL design cannot be supplied for applications that require a CPT, or primary fuse drawer for a remote CPT. Contact Eaton for availability


**Features—38 kV Switchgear Assembly (Continued)**



**38 kV Switchgear Assembly—Rear View**



**Main Bus**



Ring Type Current Transformers  
**Rear Compartment (Partial)**

---

*This page intentionally left blank.*

## General Description

Arc-Resistant Metal-Clad  
Switchgear Medium VoltageArc-Resistant Switchgear  
with Plenum Installed

## Application Description

Eaton has been manufacturing arc-resistant metal-clad switchgear since 1990. Eaton was the first major North American manufacturer to design, test and manufacture arc-resistant switchgear in accordance with EEMAC G14.1. We now offer Type 2 and 2B arc-resistant switchgear assemblies, designed and tested in accordance with the IEEE C37.20.7, with Type VCP-W drawout vacuum circuit breakers.

Eaton's VacClad-W metal-clad arc-resistant switchgear with Type VCP-W vacuum circuit breakers can be configured in various combinations of breakers and auxiliaries to satisfy user's application requirements. One-high and two-high arrangements can be provided when required.

Arc-Resistant Switchgear—  
Accessibility Types

Arc-resistant switchgear performance is defined by its accessibility type in accordance with IEEE test guide C37.20.7 as follows:

Type 1—Switchgear with arc-resistant designs or features at the freely accessible front of the equipment only.

Type 2—Switchgear with arc-resistant designs or features at the freely accessible exterior (front, back and sides) of the equipment only. (Type 2 incorporates Type 1.)

Type 2B—Switchgear with Type 2 accessibility plus arc-resistant in front of the instrument/control compartment with the instrument/control compartment door opened. (Type 2B incorporates Type 2.)

Eaton's 5/15 kV switchgear is designed and tested for IEEE Type 2B accessibility, and 27 and 38 kV switchgear is designed and tested to IEEE Type 2.

Arc-resistant features are intended to provide an additional degree of protection to the personnel performing normal operating duties in close proximity to the equipment while the equipment is operating under normal conditions. The normal operating conditions for proper application of arc-resistant switchgear designs are as follows:

- All doors and covers providing access to high voltage components are properly closed and latched
- Pressure relief devices are free to operate
- The fault energy available to the equipment does not exceed the rating of the equipment (short-circuit current and duration)
- There are no obstructions around the equipment that could direct the arc fault products into an area intended to be protected
- The equipment is properly grounded

The user should also refer to documents such as NFPA 70E, for safety training and safe work practices and methods of evaluating safe work distances from energized equipment based on the potential flash hazard, and use proper PPE when working on or near energized equipment with the door/cover opened or not properly secured.

## Standards

## Switchgear Assembly

Eaton's VacClad-W metal-clad arc-resistant switchgear meets or exceeds the following standards and test guides:

## North American Documents

- IEEE C37.20.2—Standards for Metal-Clad Switchgear
- IEEE C37.20.7—Guide for Testing Metal-Enclosed Switchgear for Internal Arcing Faults

## Canadian Documents

- CSA C22.2 No. 31-04—Switchgear Assemblies
- EEMAC G8-3.2—Metal-Clad and Station Type Cubicle Switchgear
- EEMAC G14-1—Procedure for testing the resistance of metal-clad switchgear under conditions of arcing due to an internal fault. The G14-1 was the first North American testing guide introduced in 1987

## Circuit Breakers


The Type VCP-W and VCP-WC vacuum circuit breakers, used in VacClad-W arc-resistant switchgear, meet or exceed all ANSI and IEEE standards applicable to AC high voltage circuit breakers rated on symmetrical current basis, including but not limited to: C37.04, C37.06, and C37.09. Also available are type VCP-WG vacuum circuit breakers conforming to IEEE standard C37.013 for AC high voltage generator circuit breakers.

## Third-Party Certification

5 and 15 kV arc-resistant metal-clad switchgear assemblies can be provided with CSA (Canada or USA) or UL (USA only) listing. Contact Eaton for available ratings.

Arc-Resistant Metal-Clad  
Switchgear

Arc-resistant metal-clad switchgear also conforms to C37.20.2 and is tested as such for short time and momentary short-circuit withstand for through bolted fault as noted on **Page 5.1-2**. In addition, the enclosure is also tested in accordance with IEEE guide C37.20.7 for withstand against the effects of internal arcing faults as shown in **Figure 5.2-1**.

Figure 5.2-1. Arc-Resistant Switchgear  
Enclosure Internal Arcing Short-Circuit  
Withstand Test

Internal arcing faults are those faults occurring in air, phase-to-phase or phase-to-ground, within the confines of the switchgear enclosure. Arcing faults can occur within a switchgear compartment as a result of insulation failure or human error. The arcing fault produces a tremendous release of heat energy at the point of the fault, which heats and expands the air volume

## General Description

within the enclosure, and may decompose or vaporize materials exposed to an arc or involved in its path. The effects of this type of fault vary depending on enclosure volume, arc duration, arc voltage, and available short-circuit current. If the switchgear is not designed and tested to withstand effects of internal arcing faults, its parts could blow away along with discharge of hot decomposed matter, gaseous or particulate, causing injury to personnel that may be present in its vicinity. Arc-resistant switchgear is designed to channel and control effects of the arcing fault and its enclosure is tested for withstand against such fault in accordance with IEEE guide C37.20.7.

5

## Medium Voltage Vacuum Circuit Breaker Features and Ratings

VacClad-W metal-clad arc-resistant switchgear is designed for use with Eaton's state-of-the-art medium voltage vacuum type VCP-W (standard ANSI), VCP-WC (extra capability), and VCP-WG (generator) circuit breakers. Refer to **Tables 5.4-1B, 5.4-2 and 5.4-3** for complete list of available ratings.

## Arc-Resistant Enclosure and Arc Exhaust

VacClad-W arc-resistant switchgear is designed to withstand effects of internal arcing faults up to its rated arc short-circuit current and duration. The arc-withstand capability of the switchgear enclosure is achieved by use of reinforced heavier gauge steel where needed, smart latching of doors and covers, and top-mounted built-in pressure relief system. Following are standard design features built into each arc-resistant switchgear assembly.

- The formed steel compartment design provides sealed joints under fault conditions. This prevents smoke and gas from escaping to other compartments, a condition that can occur with switchgear compartments designed with conventional flat bolted panels
- Integral, pressure release flap vents mounted on top of each individual vertical section provide for controlled upward release of arc created overpressure, fire, smoke, gases and molten material out of the assembly without affecting structural integrity, and protect personnel who might be present in the vicinity of the switchgear
- The structure roof, including the pressure release flap vents, is drip proof. The design is made strong such that the roof can be "walked-on" when the gear is completely de-energized (for example, during installation)
- Since arc pressure is vented out through the top of each individual vertical section, the equipment damage is confined to individual structures, minimizing damage to adjacent structures

## Circuit Breaker Compartment

- The levering mechanism is mechanically interlocked with the compartment door such that the door cannot be opened until the circuit breaker is opened and levered out to the test/disconnect position. This interlocking ensures that the levering of the circuit breaker into or out from the connected position is done with compartment door closed and latched, with no exposure to potential arc flash
- Easy access and viewing ports are provided on the door to allow operator to carry out all normal functions with the door closed and latched, with no exposure to potential arc flash. Those functions include: Breaker levering, manual charging of closing springs, manual opening and closing of the circuit breaker, viewing of open/close status of the breaker main contacts, viewing of charged/discharged status of the closing springs, viewing of mechanical operations counter, and breaker position

## Auxiliary Compartments

VacClad arc-resistant 5/15 and 38 kV designs permit maximum of two auxiliary drawers in one vertical section. The 27 kV design permits maximum of only one auxiliary drawer per vertical section.

- Each auxiliary drawer is equipped with cell-mounted levering mechanism. The mechanism is mechanically interlocked with its compartment door such that the door cannot be opened and access to auxiliary drawer cannot be gained until the drawer is first levered out to the disconnected position. This interlocking ensures that the levering of the auxiliary drawer into or out from the connected position is done with compartment door closed and latched, with no exposure to potential arc flash

- A viewing window is provided on the door and on front panel of the drawer to allow viewing of the drawer position and the primary fuses
- In 5/15 kV designs, each auxiliary drawer can also accommodate a single-phase CPT rated up to 15 kVA, with primary fuses, or the drawer can also be configured as a fuse drawer with two or three primary fuses, and connected to a fixed mounted CPT (single-phase or three-phase 45 kVA maximum) in the rear of the structure
- In 27 kV designs, an auxiliary drawer can be configured as a fuse drawer with two primary fuses and connected to a fixed-mounted CPT (single-phase 25 kVA maximum) in the rear of the structure
- In 38 kV designs, fuse drawer can be provided with two primary fuses and connected to a fixed-mounted CPT (single-phase 25 kVA maximum) in the rear of the structure. Please note that in 38 kV designs, a fuse drawer requires a full vertical section, because it occupies the same compartment space as required for a circuit breaker

## Control Compartments

The control compartment doors can be opened to access control wiring without having to de-energize the primary circuit. The control compartments have been tested to provide arc-resistant protection with its door opened under normal operating condition. Please note the control compartment door should be opened only for access to control wiring when needed, and should remain closed at all other times.

## Relay Box on Breaker Compartment Door in 5/15 kV Switchgear

When needed for additional relays/instruments/controls, a relay box mounted on the breaker compartment door provides ample space for individual breaker relaying and controls. An access to control wiring or device terminals that are enclosed within the relay box does not require opening of the circuit breaker compartment door.


## Arc Exhaust Wall and Arc Exhaust Chamber (Plenum)

Refer to **Page 5.5-38**.

**General Description**

**5**

**5/15 kV Arc-Resistant Switchgear**




*Front View—Type VCP-W 5/15 kV Arc-Resistant Switchgear  
(Plenum Above the Switchgear Not shown)*



*5/15 kV Auxiliary  
Over Auxiliary*



*5/15 kV Breaker  
Over Breaker*



*Breaker Compartment*



*Breaker Shown Fully  
Withdrawn on  
Extension Rails*



*VTs Drawer—Shown  
Fully Withdrawn*



*Fuse Drawer—Shown  
Fully Withdrawn*



*Rear View 5/15 kV VCP-W  
Arc-Resistant Switchgear*



*Rear View—Breaker Over  
Breaker Cable Termination*



*Rear View—Bottom  
Cable Compartment*

**Note:** Application layouts and dimensions—refer to **Pages 5.5-19 to 5.5-29** and **Pages 5.5-38 to 5.5-40**.

## General Description

**27 kV Arc-Resistant Switchgear**

*Front View—27 kV VCP-W Arc-Resistant Switchgear  
(Plenum Above the Switchgear is Not Shown)*



*Typical 27 kV Cell—Controls in Top,  
Breaker in the Bottom*



*Rear View—Typical 27 kV  
Breaker Cable Termination*


**Note:** Application layouts and dimensions—refer to **Pages 5.5-30 to 5.5-33** and **Pages 5.5-38 to 5.5-40**.

**General Description**


**38 kV Arc-Resistant Switchgear**



*38 kV Arc-Resistant Switchgear (Shown Without Arc Plenum Above the Switchgear)*




*Circuit Breaker Compartment*




*Circuit Breaker Compartment Shown with Breaker Removed*

**5**



*Front View—VT Over VT*



*VT Tray—Side View (Shown Removed)*



*Rear Assembly*

Control Compartment

Main Bus Cover

VT Drawer

Primary Cable Termination

Main Bus (Shown with Cover Removed)

**Note:** Application layouts and dimensions—refer to **Pages 5.5-34 to 5.5-40.**

---

*This page intentionally left blank.*

## General Description

## Partial Discharge Sensing and Monitoring for Switchgear



InsulGard Relay

## Partial Discharge Equipment



RFCT Sensor

## Partial Discharge in Switchgear

Partial discharge is a common name for various forms of electrical discharges such as corona, surface tracking, and discharges internal to the insulation. It partially bridges the insulation between the conductors. These discharges are essentially small arcs occurring in or on the surface of the insulation system when voltage stress exceeds a critical value. With time, airborne particles, contaminants and humidity lead to conditions that result in partial discharges. Partial discharges start at a low level and increase as more insulation becomes deteriorated. Examples of partial discharge in switchgear are surface tracking across bus insulation, or discharges in the air gap between the bus and a support, such as where a bus passes through an insulating window between the sections of the switchgear. If partial discharge process is not detected and corrected, it can develop into a full-scale insulation failure followed by an electrical fault. Most switchgear flashover and bus failures are a result of insulation degradation caused by various forms of partial discharges.

## Sensing and Monitoring

Eaton's Type VCP-W metal-clad switchgear (2.4–38 kV) is corona-free by design. Corona emissions within the standard VacClad switchgear assemblies have been eliminated or reduced to very low levels by special fabrication and assembly techniques, such as rounding and buffing of all sharp copper edges at the joints, employing star washers for bolting metal barriers, and using specially crafted standoff insulators for primary bus supports. By making switchgear assemblies corona-free, Eaton has made its standard switchgear more reliable. However, as indicated above, with time, airborne particles, contaminants and humidity lead to conditions that cause partial discharges to develop in switchgear operating at voltages 4000V and above. Type VCP-W switchgear can be equipped with factory-installed partial discharge sensors and partial discharge sensing relay for continuous monitoring of the partial discharges under normal operation. Timely detection of insulation degradation through increasing partial discharges can identify potential problems so that corrective actions can be planned and implemented long before permanent deterioration develops. Partial discharge detection can be the foundation of an effective predictive maintenance program. Trending of partial discharge data over time allows prediction of failures, which can be corrected before catastrophic failure occurs.

The PD sensing and monitoring system consists of Eaton's InsulGard™ Relay and PD sensors specifically developed for application in the switchgear to work with the relay.




InsulGard Relay (PD Monitoring)

Partial discharges within the switchgear compartment are detected by installation of a small donut type radio frequency current transformer (RFCT) sensor over floating stress shields of the specially designed bus or line side primary bushings. Partial discharges in customer's power cables (external discharges) are detected by installation of the RFCT around ground shields of the incoming or outgoing power cables termination.

In 38 kV switchgear (refer to **Figure 5.3-3**), one RFCT sensor is installed around primary bushing stress shield in every breaker compartment and supplied as standard for measurement of discharges internal to the switchgear compartment. Its output is wired to terminal blocks in control compartment for easy access for periodic field measurements. It can also be connected directly to optional InsulGard relay for continuous monitoring of partial discharges. Because one RFCT sensor is included in 38 kV breaker compartment, Eaton's 38 kV switchgear is "PD Sensing Ready" when received by the customer. An additional RFCT sensor for each incoming and outgoing power cable circuits can be provided as an option for measurement of external discharges.


In 5/15/27 kV switchgear (refer to **Figure 5.3-2**), primary epoxy bushings with stress shield and RFCT sensors for measurement of internal as well as external partial discharges are all optional. InsulGard relay is also optional. When specified, one set of primary epoxy bushings (located on bus side) with stress shield and associated RFCT sensor is provided at every two vertical sections. An additional RFCT sensor for each incoming and outgoing power cable circuits can be provided as required. The RFCT output signals can be connected directly to InsulGard relay for continuous monitoring of partial discharges or can be used for periodic field measurements.

**General Description—Partial Discharge Sensing and Monitoring**




**Figure 5.3-1. InsulGard Relay System**

5




**Figure 5.3-2. Typical Partial Discharge Sensor Connections (5–27 kV Switchgear)**

**Note:** Use one set of epoxy bottles with ground stress shield on bus side (either in the top or bottom compartment) at every two vertical sections. Use standard bottles at all other locations.



**Figure 5.3-3. Typical Partial Discharge Sensor Connections (38 kV Switchgear)**

Partial Discharge Sensors and Monitoring for Switchgear



5

Figure 5.3-4. How the Process Works—Sensing and Data Collection




Figure 5.3-5. How the Process Works—Data Analysis and Report (Sample)

## General Description—Communications, Protection and Supplemental Devices

### Integrated Monitoring Protection and Control

#### Communications System

Eaton's Power Xpert® System Architecture provides a fully scalable set of hardware/software solutions that can be applied in varying levels of sophistication depending upon a customer's needs. This new architecture permits backward communication compatibility to existing Eaton and other third-party equipment, as well as expanded functionality for new devices.

The Power Xpert System Architecture uses embedded Web server technology for ease of connectivity to Ethernet Local and Wide Area Networks. The architecture includes Eaton's Power Xpert Meter, Power Xpert Gateways and Power Xpert Software. Eaton's selection matrix includes a number of deployment levels, from Web browser based monitoring of a single Power Xpert Meter, through fully customized monitoring of Eaton and third-party devices in a multi-site environment.

Medium voltage VacClad-W switchgear is ideally suited for Eaton's unique Power Xpert system incorporating PowerNet devices.

Refer to **Tab 2** for more information on communication systems.

#### Protective Relays

A full scope of protective relays designed to meet all application requirements is available to provide the utmost in system and component protection. Refer to **Tab 4** for further information.

#### Supplemental Devices

##### Dummy Element (Dummy Breaker)

Dummy element is a drawout element with primary disconnects similar to a drawout circuit breaker, but consists of solid copper conductors in place of vacuum interrupters, and is designed for manual racking. It is typically used as drawout disconnect link in the primary system for circuit isolation or bypass. The device is insulated to suit the voltage rating of the switchgear and will carry required levels of short-circuit current, but it is not rated for any current interruption. It must be key interlocked with all source devices such that it can only be inserted into or

removed from its connected position only after the primary circuit in which it is to be applied is completely de-energized.

Before using a dummy element, it is recommended that each user develop detailed operating procedure consistent with safe operating practices. Only qualified personnel should be authorized to use the dummy element.

##### Ground and Test Device

The ground and test device is a drawout element that may be inserted into a metal-clad switchgear housing in place of a circuit breaker to provide access to the primary circuits to permit the temporary connection of grounds or testing equipment to the high-voltage circuits. High potential testing of cable or phase checking of circuits are typical tests which may be performed. The devices are insulated to suit the voltage rating of the switchgear and will carry required level of short-circuit current.

Before using ground and test devices, it is recommended that each user develop detailed operating procedures consistent with safe operating practices. Only qualified personnel should be authorized to use ground and test devices.

Manual and electrical ground and test devices are available. These devices include six studs for connection to primary circuits. On the manual device, selection and grounding is accomplished by cable or bus bars connection. On electrical-type devices, grounding is accomplished by an electrically operated grounding switch.

##### Standard Accessories

- One test jumper
- One levering crank
- One maintenance tool
- One lifting yoke (5–27 kV)
- One sets of rails (5–27 kV)
- One turning handle (5th wheel, 38 kV)

##### Optional Accessories

- Transport dolly (5–27 kV), (5–15 kV arc-resistant)
- Portable lifter (5–27 kV)
- Test cabinet
- Electrical levering device (5–38 kV)
- Ramp for lower breaker (5–27 kV), (5–15 kV arc-resistant)
- Manual or electrical ground and test device
- Hi-pot tester



5/15 kV Manual Type G&T Device



5/15 kV Manual G&T Device shown with Upper Terminals Grounded



5/15 kV Manual G&T Device shown with Lower Terminals Grounded

### Discussion of changes in the Rated Voltage Range Factor, K, or “K-factor” in Circuit Breaker Rating Structure

In 1997 and 2000 editions of ANSI C37.06, under Table 1, preferred values for the rated voltage range factor, K, were set to 1.0 for all indoor circuit breaker ratings. This was done because interrupting capabilities of today’s vacuum circuit breakers are better represented by  $K = 1.0$ . Unlike old air-magnetic and oil circuit breakers, today’s vacuum breakers generally do not require a reduction in interrupting current, as the operating voltage is raised to rated maximum voltage, for example from 11.5 kV up to 15 kV. The interrupting capability of vacuum circuit breakers is essentially constant over the entire range of operating voltages, up to and including its rated maximum voltage. The change was also made as a step toward harmonizing preferred ANSI ratings with the preferred ratings of IEC standards. It was further recognized that it is much simpler to select and apply circuit breakers rated on the basis of  $K = 1.0$ .

The change in the K value, however, in no way affects the ratings and capabilities of circuit breakers originally tested and rated on the basis of  $K > 1$  in the earlier editions of C37.06. Existing circuit breakers, with ratings based on  $K > 1.0$ , are still perfectly valid, meet the latest editions of the standards, and should be continued to be applied as they have been in the past. The original  $K > 1.0$  ratings are neither “obsolete” nor “inferior” to the new  $K = 1.0$  ratings; they are just different. The new 1997 and 2000 editions of ANSI standard C37.06 still include the earlier  $K > 1$  ratings as Table A1 and A1A. The change from  $K > 1.0$  to  $K = 1.0$  should be implemented by manufacturers as they develop and test new circuit breaker designs. The change does not require, recommend or suggest that manufactures re-rate and re-test existing breakers to new standard. And accordingly, Eaton continues to offer both circuit breakers rated on the traditional basis of  $K > 1.0$  just as thousands of those breakers have been applied for variety of circuit switching applications worldwide, and also as Eaton develops new breakers, they are rated and tested to the new

$K = 1$  ratings. As a leader in vacuum interruption technology, Eaton continues to provide a wide choice of modern vacuum circuit breakers so that the user can select the most economical circuit breaker that can satisfy their circuit switching application.

- **Table 5.4-1A** includes 5/15 kV circuit breakers rated on the basis of  $K = 1.0$  in accordance with revised ANSI standards
- **Table 5.4-1B** includes capabilities of traditional 5/15 kV circuit breakers rated on the basis of  $K > 1.0$
- **Table 5.4-1C** includes 27/38 kV circuit breakers rated on the basis of  $K = 1.0$
- **Table 5.4-2** includes circuit breaker designs, rated on the basis of  $K = 1.0$  with “extra capabilities” for those applications whose requirements go beyond what is usually experienced in normal distribution circuit applications
- **Table 5.4-3** includes circuit breakers for special generator applications

## Technical Data—Standard VCP-W Circuit Breakers

**Table 5.4-1A. Available 5/15 kV VCP-W Vacuum Circuit Breaker Types Rated on Symmetrical Current Rating Basis, Per ANSI Standards (Rated K = 1.0)**  
 (Continued on next page)

Identification Drawout Circuit Breaker Type	Rated Values															
	Maximum Voltage (V)	Power Frequency ①	Insulation Level			Short-Circuit Ratings (Reference C37.04-1999 and C37.06-2009 Except as Noted ①)						Transient Recovery Voltage Parameters are Based on TD-4				
			Power Frequency Withstand Voltage (1 min.)	Lightning Impulse Withstand Voltage (1.2 x 50 μs)	Continuous Current ②	Symmetrical Interrupting Current (I) ③	DC Component (% DC) ④	Asymmetrical Interrupting Current (I <sub>t</sub> ) ⑤	Closing and Latching Current (2.6 x I)	Short-Time Withstand Current ⑥	Peak Voltage (E <sub>2</sub> ) = (u <sub>c</sub> )	Time to Peak (T <sub>2</sub> = t <sub>3</sub> x 1.137)	TRV Rise Time (t <sub>3</sub> )	RRRV = u <sub>c</sub> /t <sub>3</sub> ⑦	Interrupting Time	Cycles (60 Hz)
50 VCP-W 25	4.76	60	19	60	1200 2000 3000	25	50	31	65	25	8.2	50	44	0.19	50	3
50 VCP-W 40	4.76	60	19	60	1200 2000 3000	40	50	49	104	40	8.2	50	44	0.19	50	3
50 VCP-W 50	4.76	60	19	60	1200 2000 3000	50	44	59	130	50	8.2	50	44	0.19	50	3
50 VCP-W 63	4.76	60	19	60	1200 2000 3000	63	55	80	164	63	8.2	50	44	0.19	50	3
75 VCP-W 40	8.25	60	36	95	1200 2000 3000	40	50	49	104	40	14	59	52	0.27	50	3
75 VCP-W 50	8.25	60	36	95	1200 2000 3000	50	44	59	130	50	14	59	52	0.27	50	3
150 VCP-W 25	15	60	36	95	1200 ⑧ 2000 3000	25	50	31	65	25	28 ⑧ 25.7	75	66	0.42 0.39	50	3
150 VCP-W 40	15	60	36	95	1200 2000 3000	40	50	49	104	40	25.7	75	66	0.39	50	3
150 VCP-W 50	15	60	36	95	1200 2000 3000	50	44	59	130	50	25.7	75	66	0.39	50	3
150 VCP-W 63	15	60	36	95	1200 ⑧ 2000 ⑧ 3000 ⑧	63	55	80	164	63	28 ⑧	75	66	0.42	50	3

① All circuit breakers are tested at 60 Hz; however, they can also be applied at 50 Hz with no derating.

② 4000A fan-cooled rating is available for 3000A circuit breakers.

③ Because the voltage range factor K = 1, the short-time withstand current and the maximum symmetrical interrupting current are equal to the rated symmetrical interrupting current.

④ Based on the standard DC time constant of 45 ms (corresponding to X/R of 17 for 60 Hz) and the minimum contact parting time as determined from the minimum opening time plus the assumed minimum relay time of 1/2 cycle (8.33 ms for 60 Hz).

⑤ The asymmetrical interrupting current, I total, is given by  $I_t = I \times \text{Sqrt}(1 + 2 \times \%DC \times \%DC)$  kA rms asymmetrical total.

⑥ Duration of short-time current and maximum permissible tripping delay are both 2 seconds for all circuit breakers listed in this table, as required in C37.04-1999, C37.06-2000 and C37.06-2009.

⑦ RRRV can also be calculated as  $= 1.137 \times E_2/T_2$ .

⑧ These circuit breakers were tested to the preferred TRV ratings specified in C37.06-2000.

**Table 5.4-1A. Available VCP-W Vacuum Circuit Breaker Types Rated on Symmetrical Current Rating Basis, Per ANSI Standards (Rated K = 1.0)  
(Continued)**

Identification Drawout Circuit Breaker Type	Rated Values												
	Continuous Current	Operating Duty	Mechanical Endurance	Capacitance Current Switching Capability (Reference C37.04a-2003, C37.06-2009 and C37.09a-2005)								Out-of-Phase Switching	
				Cable-Charging Current		Isolated Shunt Capacitor Bank Current		Back-to-Back Capacitor Switching				Voltage = 1.44 x V	Current = 0.25 x I
Units	A rms	Duty Cycle	No-Load Operations ⑨⑩	Class	A rms	Class	A rms	Class	A rms	kA Peak	kHz		
50 VCP-W 25	1200 2000 3000	O—0.3s—CO—3m—CO	10,000	C2	3–10	C2	75–630 75–1000 75–1600	C2	75–630 75–1000 75–1600	6	0.8 0.5 0.3	7	6.3
50 VCP-W 40	1200 2000 3000	O—0.3s—CO—3m—CO	10,000	C2	3–10	C2	75–630 75–1000 75–1600	C2	75–630 75–1000 75–1600	6	0.8 0.5 0.3	7	10
50 VCP-W 50	1200 2000 3000	O—0.3s—CO—3m—CO	10,000	C2	3–10	C2	75–630 75–1000 75–1600	C2	75–630 75–1000 75–1600	6	0.8 0.5 0.3	7	12.5
50 VCP-W 63	1200 2000 3000	O—0.3s—CO—3m—CO	10,000	C2	7.5–25	C2	75–630 75–1000 75–1600	C2	75–630 75–1000 75–1600	6	0.8 0.5 0.3	7	15.8
75 VCP-W 40	1200 2000 3000	O—0.3s—CO—3m—CO	10,000	C2	7.5–25	C2	75–630 75–1000 75–1600	C2	75–630 75–1000 75–1600	6	0.8 0.5 0.3	12	10
75 VCP-W 50	1200 2000 3000	O—0.3s—CO—3m—CO	10,000	C2	7.5–25	C2	75–630 75–1000 75–1600	C2	75–630 75–1000 75–1600	6	0.8 0.5 0.3	12	12.5
150 VCP-W 25	1200 2000 3000	O—0.3s—CO—3m—CO	10,000	C2	7.5–25	C2 C2 C1	75–630 75–1000 75–1600	C2 C2 C1	75–630 75–1000 75–1600	6	0.8 0.5 0.3	22	6.3
150 VCP-W 40	1200 2000 3000	O—0.3s—CO—3m—CO	10,000	C2	7.5–25	C2 C2 C1	75–630 75–1000 75–1600	C2 C2 C1	75–630 75–1000 75–1600	6	0.8 0.5 0.3	22	10
150 VCP-W 50	1200 2000 3000	O—0.3s—CO—3m—CO	10,000	C2	7.5–25	C2 C2 C1	75–630 75–1000 75–1600	C2 C2 C1	75–630 75–1000 75–1600	6	0.8 0.5 0.3	22	12.5
150 VCP-W 63	1200 2000 3000	O—0.3s—CO—3m—CO	10,000	C2	7.5–25	C2	75–630 75–1000 75–1600	C2	75–630 75–1000 75–1600	6	0.8 0.5 0.3	22	15.8

⑨ Each operation consists of one closing plus one opening.

⑩ All 40 and 50 kA circuit breakers exceed required 5000 no-load operations; all 63 kA circuit breakers exceed the required 2000 no-load ANSI operations.

Technical Data—Standard VCP-W Circuit Breakers

Table 5.4-1B. Available 5/15 kV VCP-W Vacuum Circuit Breaker Types Rated on Symmetrical Current Rating Basis, Per ANSI Standards (Rated K > 1) ①②

Identification		Rated Values													Related Required Capabilities					Asymmetry Factor for VCP-W Breakers S ⑩
Circuit Breaker Type	Nominal Voltage Class kV Class	Nominal 3-Phase MVA Class MVA Class	Voltage		Insulation Level		Current		Rated Transient Recovery Voltage			Rated Interrupting Time Cycles	Rated Permissible Tripping Delay Sec.	Rated Reclosing Time ms	Rated Maximum Voltage Divided by K V/K kV rms	Current Values				
			Rated Maximum Voltage V kV rms	Rated Voltage Range Factor K ③	Power Frequency Withstand Voltage (1 min.) kV rms	Lightning Impulse Withstand Voltage (1.2 x 50 μs) kV Crest	Rated Continuous Current at 60 Hz Amp ④	Rated Short-Circuit Current (at Rated Maximum kV) I ③ kA rms	Rated Crest Voltage E2 kV Crest	Rated Time to Crest T2 μS	Rate of Rise of Recovery Voltage ⑤ kV/μS					Maximum Sym. Interrupting Capability KI kA rms	3-Second Short-Time Current Carrying Capability KI kA rms	Closing and Latching Capability (Momentary) ⑨		
															2.7 K Times Rated Short-Circuit Current ③	2.7 K Times Rated Short-Circuit Current 2.7 KI kA Crest	1.6 K Times Rated Short-Circuit Current 1.6 KI ⑩			
50 VCP-WND 250	4.16	250	4.76	1.24	19	60	1200	29	8.9	50	0.2	5	2	300	3.85	36	36	97	58	1.2
50 VCP-W 250	4.16	250	4.76	1.24	19	60	1200 2000 3000	29	8.9	50	0.2	5	2	300	3.85	36	36	97	58	1.2
50 VCP-W 350	4.16	350	4.76	1.19	19	60	1200 2000 3000	41	8.9	50	0.2	5	2	300	4.0	49	49	132	78	1.2
75 VCP-W 500	7.2	500	8.25	1.25	36	95	1200 2000 3000	33	15.5	60	0.29	5	2	300	6.6	41	41	111	66	1.2
150 VCP-W 500	13.8	500	15	1.30	36	95	1200 2000 3000	18	28	75	0.42	5	2	300	11.5	23	23	62	37	1.2
150 VCP-W 750	13.8	750	15	1.30	36	95	1200 2000 3000	28	28	75	0.42	5	2	300	11.5	36	36	97	58	1.2
150 VCP-W 1000	13.8	1000	15	1.30	36	95	1200 2000 3000	37	28	75	0.42	5	2	300	11.5	48	48	130	77	1.2

5

① For capacitor switching, refer to Tables 5.4-1A and 5.4-2.

② 5 and 15 kV circuit breakers are UL listed.

③ For three-phase and line-to-line faults, the symmetrical interrupting capability at an operating voltage

$$I_{sc} = \frac{V}{V_o} \text{ (Rated Short-Circuit Current)}$$

But not to exceed KI.

Single line-to-ground fault capability at an operating voltage

$$I_{sc} = 1.15 \frac{V}{V_o} \text{ (Rated Short-Circuit Current)}$$

But not to exceed KI.

The above apply on predominately inductive or resistive three-phase circuits with normal-frequency line-to-line recovery voltage equal to the operating voltage.

④ 4000A continuous rating is available for 5/15 kV. 3000A continuous rating is available for 38 kV. Contact Eaton for details.

⑤  $RRRV = 1.137 \frac{E_2}{T_2}$

⑥ 3-cycle rating available, refer to Tables 5.4-1A and 5.4-2.

⑦ Tripping may be delayed beyond the rated permissible tripping delay at lower values of current in accordance with the following formula:

$$T \text{ (seconds)} = Y \left( \frac{\text{(K Times Rated Short-Circuit Current)}}{\text{Short-Circuit Current Through Breaker}} \right)^2$$

The aggregate tripping delay on all operations within any 30-minute period must not exceed the time obtained from the above formula.

⑧ For reclosing service, there is **No derating** necessary for Eaton's VCP-W family of circuit breakers. **R = 100%**. Type VCP-W breaker can perform the O-C-O per ANSI C37.09; O-0.3s-CO-15s-CO per IEC 56; and some VCP-Ws have performed O-0.3s-CO-15s-CO-15s-CO-15s-CO; **all with no derating**. Contact Eaton for special reclosing requirements.

⑨ For higher close and latch ratings, refer to Table 5.4-2.

⑩ Included for reference only.

⑪ Asymmetrical interrupting capability = "S" times symmetrical interrupting capability, both at specified operating voltage.

Table 5.4-1C. Available 27/38 kV VCP-W Vacuum Circuit Breaker Types Rated on Symmetrical Current Rating Basis, Per ANSI Standards ①②

Identification		Rated Values											Related Required Capabilities							
Circuit Breaker Type	Nominal Voltage Class kV Class	Nominal 3-Phase MVA Class MVA Class	Voltage		Insulation Level		Current		Rated Transient Recovery Voltage			Rated Interrupting Time Cycles	Rated Permissible Tripping Delay Sec.	Rated Reclosing Time ms	Current Values				Asymmetry Factor for VCP-W Breakers S	
			Rated Maximum Voltage V kV rms	Rated Voltage Range Factor K ③	Power Frequency Withstand Voltage (1 min.) kV rms	Lightning Impulse Withstand Voltage (1.2 x 50 μs) kV Crest	Rated Continuous Current at 60 Hz Amp	Rated Short-Circuit Current (at Rated Maximum kV) kA rms	Rated Crest Voltage kV Crest	Rated Time to Crest μs	Rate of Rise of Recovery Voltage ⑤ kV/μs				Rated Maximum Voltage Divided by K V/K kV rms	Maximum Sym. Interrupting Capability KI kA rms	3-Second Short-Time Current Carrying Capability KI kA rms	Closing and Latching Capability (Momentary) ④		
											Rated Maximum Voltage Divided by K V/K kV rms	K Times Rated Short-Circuit Current ③ KI kA rms	2.7 K Times Rated Short-Circuit Current 2.7 KI kA Crest	1.6 K Times Rated Short-Circuit Current 1.6 KI ⑩ kA rms asym.						
270 VCP-W 750	27	—	27	1.0	60	125	1200 2000	16	51	105	0.55	5	2	300	27	16	16	43	26	1.2
270 VCP-W 1000	27	—	27	1.0	60	125	1200 2000	22	51	105	0.55	5	2	300	27	22	22	60	35	1.2
270 VCP-W 1250	27	—	27	1.0	60	125	1200 2000	25	51	105	0.55	5	2	300	27	25	25	68	40	1.2
270 VCP-W 40	27	—	27	1.0	60	125	1200 2000	40	51	105	0.55	5	2	300	27	40	40	108	64	1.2
380 VCP-W 16	34.5	—	38	1.0	80	170 ⑫	1200 2000	16	71	125	0.64	5	2	300	38	16	16	43	26	1.2
380 VCP-W 21	34.5	—	38	1.65	80	170 ⑫	1200 2000	21	71	125	0.64	5	2	300	23	35	35	95	56	1.2
380 VCP-W 25	34.5	—	38	1.0	80	170 ⑫	1200 2000	25	71	125	0.64	5	2	300	38	25	25	68	40	1.2
380 VCP-W 32	34.5	—	38	1.0	80	170 ⑫	1200 2000 2500	31.5	71	125	0.64	5	2	300	38	31.5	31.5	85	51	1.2
380 VCP-W 40	34.5	—	38	1.0	80	170 ⑫	1200 2000 2500	40	71	125	0.64	5	2	⑮	38	40	40	108	64	1.2

① For capacitor switching, refer to Table 5.4-2.

② 27 and 38 kV breakers are not UL listed.

③ For three-phase and line-to-line faults, the symmetrical interrupting capability at an operating voltage

$$I_{sc} = \frac{V}{V_0} \text{ (Rated Short-Circuit Current)}$$

But not to exceed KI.

Single line-to-ground fault capability at an operating voltage

$$I_{sc} = 1.15 \frac{V}{V_0} \text{ (Rated Short-Circuit Current)}$$

But not to exceed KI.

The above apply on predominately inductive or resistive three-phase circuits with normal-frequency line-to-line recovery voltage equal to the operating voltage.

④ 4000A continuous rating is available for 5/15 kV. 3000A continuous rating is available for 38 kV. Contact Eaton for details.

$$\textcircled{5} \text{ RRRV} = 1.137 \frac{E_2}{T_2}$$

⑥ 3-cycle rating available, refer to Table 5.4-2.

⑦ Tripping may be delayed beyond the rated permissible tripping delay at lower values of current in accordance with the following formula:

$$T \text{ (seconds)} = Y \left( \frac{(K \text{ Times Rated Short-Circuit Current})^2}{\text{Short-Circuit Current Through Breaker}} \right)$$

The aggregate tripping delay on all operations within any 30-minute period must not exceed the time obtained from the above formula.

⑧ For reclosing service, there is **No derating** necessary for Eaton's VCP-W family of circuit breakers. **R = 100%**. Type VCP-W breaker can perform the O-C-O per ANSI C37.09; O-0.3s-CO-15s-CO per IEC 56; and some VCP-Ws have performed O-0.3s-CO-15s-CO-15s-CO-15s-CO; **all with no derating**. Contact Eaton for special reclosing requirements.

⑨ For higher close and latch ratings, refer to Table 5.4-2.

⑩ Included for reference only.

⑪ Asymmetrical interrupting capability = "S" times symmetrical interrupting capability, both at specified operating voltage.

⑫ ANSI standard requires 150 kV BIL. All 38 kV ratings are tested to 170 kV BIL.

⑮ Type 380 VCP-W 40 circuit breaker is not rated for rapid reclosing.

**Technical Data—Extra Capability VCP-WC Circuit Breakers**

**Industry Leader VCP-WC**

Introducing the VCP-WC extra capability medium voltage drawout circuit breaker. Designed to provide all the industry-leading features expected of the VCP-W, plus extra capabilities for those application requirements that go beyond what is usually experienced. The performance enhancement features of the VCP-WC make it an ideal choice for capacitor switching duty, high altitude applications, transformer secondary fault protection, locations with concentrations of rotating machinery or high operating endurance requirements, just to mention a few. Consider these capability enhancements:

- Definite purpose capacitor switching
- Higher close and latch
- Faster rate of rise of recovery voltage
- Higher short-circuit current
- Higher mechanical endurance
- Higher insulation level


- Higher voltage ratings with K=1
- 3-cycle interrupting time
- Higher switching life
- Designed and tested to ANSI standards and higher
- WR fixed retrofit configuration available

**Vacuum Circuit Breaker Design Leadership**

Eaton is a world leader in vacuum interrupter and vacuum circuit breaker technology, offering VCP-WC with extra capabilities without sacrificing the proven features already standard with other VCP-W circuit breakers. Features such as:

- Vacuum interrupters with copper-chrome contacts
- V-Flex non-sliding current transfer system
- Visible contact erosion indicators
- Visible contact wipe indicators

- Front, functionally grouped controls and indicators
- Glass-polyester (5/15 kV), or epoxy insulation (27/38 kV)
- Front, vertically mounted stored energy mechanism
- Drawout on extension rails
- Integrally mounted wheels
- Quality Assurance Certificate



*The Type VCP-WC Breakers are not Interchangeable with Standard VCP-W Breakers. They are Equipped with Different Code Plates and Taller Front Panels.*

5

**Table 5.4-2. Extra Capability Type VCP-WC Ratings (Symmetrical Current Basis), Rated K = 1**

Identification Circuit Breaker Type	Rated Values														Mechanical Endurance No-Load Operations			
	Voltage		Insulation Level		Current							Maximum Permissible Tripping Delay	Rate of Rise of Recovery Voltage (RRRV) <sup>③</sup>	Capacitor Switching Ratings				
	Maximum Voltage (V)	Voltage Range Factor	Power-Frequency Withstand Voltage (1 min.)	Lightning Impulse Withstand Voltage (1.2 x 50 µs)	Continuous Current at 60 Hz	Short-Circuit Current					General Purpose			Definite Purpose				
						Sym. Interrupting at Voltage (Isc)	% DC Component (I <sub>dc</sub> )	Asym. Interrupting (I <sub>p</sub> )	Closing and Latching Capability	Short-Time Current for 3 Seconds <sup>①</sup>		Interrupting Time <sup>②</sup>	Isolated Shunt Capacitor Bank Current	Back-to-Back Capacitor Switching				
kV rms	K	kV rms	kV Peak	A rms	kA rms Total	%	kA rms	kA Peak	kA rms	ms	Seconds	kV/µs	A rms	Capacitor Bank Current	Inrush Current	Inrush Frequency		
50 VCP-W 25C	5.95	1	24	75	1200 2000 3000 <sup>④</sup>	25	50 75 75	31 36 36	97	25	50	2.0	0.9 0.9 0.8	400 & 630 1000 <sup>⑤</sup> 250	400 & 630 1000 <sup>⑥</sup> —	20 & 20 18 —	6.5 & 5.5 2.7 —	10,000 10,000 5,000
50 VCP-W 40C	5.95	1	24	75	1200 2000 3000 <sup>④</sup>	40	75	58	139	40	50	2.0	0.9 0.9 0.8	630 <sup>⑤</sup> 1000 <sup>⑤</sup> 250	630 <sup>⑥</sup> 1000 <sup>⑥</sup> —	15 18 —	3.5 2.7 —	10,000 10,000 5,000
50 VCP-W 50C	5.95	1	24	75	1200 2000 3000 <sup>④</sup>	50	57 57 52	64 64 62	139	50	50	2.0	0.9 0.9 0.8	630 <sup>⑤</sup> 1000 <sup>⑤</sup> 250	630 <sup>⑥</sup> 1000 <sup>⑥</sup> —	15 18 —	3.5 2.7 —	10,000 10,000 5,000
50 VCP-W 63C	5.95	1	24	75	1200 2000 3000 <sup>④</sup>	63	62	83	175	63	50	2.0	1.1	250	200, 1600 <sup>⑦</sup> 200, 1600 <sup>⑦</sup> 200, 1600 <sup>⑦</sup>	7.7 7.7 7.7	465 465 465	10,000 10,000 10,000
75 VCP-W 50C	10.3	1	42	95	1200 2000 3000 <sup>④</sup>	50	57 57 52	64 64 62	139	50	50	2.0	0.9 0.9 0.8	630 <sup>⑤</sup> 1000 <sup>⑤</sup> 250	630 <sup>⑥</sup> 1000 <sup>⑥</sup> —	15 18 —	3.5 2.7 —	10,000 10,000 5,000
150 VCP-W 25C	17.5	1	42	95	1200 2000 3000 <sup>④</sup>	25	50 75 75	31 36 36	97 <sup>⑧</sup>	25	50	2.0	0.9 0.9 0.8	400 & 600 <sup>⑨</sup> 1000 <sup>⑤⑨</sup> 250 <sup>⑨</sup>	400 & 600 <sup>⑨</sup> 1000 <sup>⑥⑨</sup> —	20 & 20 18 —	6.5 & 5.5 2.7 —	10,000 10,000 5,000
150 VCP-W 40C	17.5	1	42	95	1200 2000 3000 <sup>④</sup>	40	75	58	139	40	50	2.0	0.9 0.9 0.8	630 <sup>⑤⑨</sup> 1000 <sup>⑤⑨</sup> 250 <sup>⑨</sup>	630 <sup>⑥⑨</sup> 1000 <sup>⑥⑨</sup> —	15 18 —	3.5 2.7 —	10,000 10,000 5,000
150 VCP-W 50C	17.5	1	42	95	1200 2000 3000 <sup>④</sup>	50	57 57 52	64 64 62	139	50	50	2.0	0.9 0.9 0.8	630 <sup>⑤⑨</sup> 1000 <sup>⑤⑨</sup> 250 <sup>⑨</sup>	630 <sup>⑥⑨</sup> 1000 <sup>⑥⑨</sup> —	15 18 —	3.5 2.7 —	10,000 10,000 5,000
150 VCP-W 63C	15	1	42	95	1200 2000 3000 <sup>④</sup>	63	62	83	175	63	50	2.0	1.1	250	200, 1600 <sup>⑦</sup> 200, 1600 <sup>⑦</sup> 200, 1600 <sup>⑦</sup>	7.7 7.7 7.7	465 465 465	10,000 10,000 10,000

Note: Refer to Page 5.4-7 for footnotes.

**Table 5.4-2. VCP-WC Ratings (Symmetrical Current Basis), Rated K = 1 (Continued)**

Identification Circuit Breaker Type	Rated Values																	Mechanical Endurance  No-Load Operations	
	Voltage		Insulation Level		Current					Maximum Permissible Tripping Delay	Rate of Rise of Recovery Voltage (RRRV) <sup>③</sup>	Capacitor Switching Ratings							
	Maximum Voltage (V)	Voltage Range Factor	Power Frequency Withstand Voltage (1 min.)	Lightning Impulse Withstand Voltage (1.2 x 50 µs)	Continuous Current at 60 Hz	Short-Circuit Current						General Purpose		Definite Purpose					
						Sym. Interrupting at Voltage (Isc)	% DC Component (I <sub>dc</sub> )	Asym. Interrupting (I <sub>q</sub> )	Closing and Latching Capability	Short-Time Current for 3 Seconds <sup>①</sup>	Interrupting Time <sup>②</sup>	Cable Charging Current	Isolated Shunt Capacitor Bank Current	Back-to-Back Capacitor Switching					
kV rms	K	kV rms	kV Peak	A rms	kA rms Total	%	kA rms	kA Peak	kA rms	ms	Seconds	kV/µs	A rms	A rms	A rms	kA Peak	kHz		
270 VCP-W 25C	27	1	60	125	1200 1600	25	75	36	85	25 <sup>⑩</sup>	50	2.0	1.1	—	400	400	20	4.2	5,000
270 VCP-W 32C	27	1	60	125	1200 1600	31.5	55	40	100	31.5 <sup>⑪</sup>	50	2.0	1.1	—	400	400	20	4.2	5,000
270 VCP-W 40C	27	1	60	125	1200 1600	40	50	49	112	40 <sup>⑫</sup>	50	2.0	1.1	—	400	400	20	4.2	5,000
380 VCP-W 16C	38	1	80	170	1200 2000	16	75	23.3	50	16	50	2.0	0.7 1.3	50 50	250 250 & 1000	250 250 & 1000	20 20 & 20	4.4 5 & 5	10,000
380 VCP-W 25C	38	1	80	170	1200 2000	25	65	34.0	75	25	50	2.0	0.7 1.3	50 50	250 250 & 1000	250 250 & 1000	20 20 & 20	4.4 5 & 5	10,000
380 VCP-W 32C	38	1	80	170	1200 2000 2500 3000FC <sup>⑬</sup>	33.1	57	42.5	91	31.5	50	2.0	0.7 1.3 0.7 1.3	50 50 50 50	250 250 & 1000 — 250 & 1000	250 250 & 1000 — 250 & 1000	20 20 & 20 — 20 & 20	4.4 5 & 5 — 5 & 5	10,000
380 VCP-W 40C	38	1	80	170	1200 2000 2500 3000FC <sup>⑭</sup>	40	63	53.5	107	40	50	2.0	0.7	50 50 50 50	⑮ — — —	⑮ — — —	⑮ — — —	⑮ — — —	10,000


① Except as noted.  
 ② 3 cycles.  
 ③ Contact Eaton for higher RRRV or for more information.  
 ④ 4000A FC rating available.  
 ⑤ Breaker tested to 2700A single bank switching for momentary load (thermal derating must consider harmonic content of current waveform).  
 ⑥ Breaker tested to 1270A back to back switching for momentary load (thermal derating must consider harmonic content of current waveform).  
 ⑦ C37.04.a-2003 Class C2 at 15 kV.  
 ⑧ Close and Latch Current for 1200A Type 150 VCP-W 25C is proven at 15 kV. For sealed interrupters at high altitudes, switching voltage is not derated.  
 ⑨ Capacitor Switching Ratings are proven at 15 kV. For sealed interrupters at high altitudes, switching voltage is not derated.  
 ⑩ 2.5 seconds.  
 ⑪ 1.6 second.  
 ⑫ 1 second.  
 ⑬ 2000A FC to 3000A.  
 ⑭ 2500A FC to 3000A.  
 ⑮ Contact Eaton for capacitor switching ratings.

**Note:** 38 kV, 2500A and 3000A WC breakers are not rated for rapid reclosing.

### Type VCP-WG Generator Circuit Breakers



VCP-WG Breaker (Front View)



VCP-WG Breaker (Rear View)

#### Why generator circuit breakers?

- Specially rated generator breakers typically should be used on generator applications 10,000 kW and above
- A generator circuit breaker, properly rated and tested to the appropriate industry standard, can protect the generator from damage, or even complete failure, that could occur when feeding a faulted transformer, and also can protect the transformer, in the event that a fault should occur in the generator

Generator circuits have unique characteristics that require specially designed and tested circuit breakers. The IEEE® developed the special industry standard C37.013 and amendment C37.013a-2007 to address these characteristics. Eaton Corporation has dedicated years of research, design, enhancement and testing to create Eaton's family of generator breakers.

The VCP-WG (drawout) and VCP-WRG (fixed) circuit breakers meet, and even exceed, the rigorous service duty requirements for generator circuit applications as defined by IEEE.

Eaton's VCP-WG and VCP-WRG generator breakers are available in two frame sizes. The 29.00-inch frame (29.00 inches wide with front cover on) has ratings up to 15 kV, 63 kA and 3000A (4000A with forced-air cooling). The 31.00-inch frame (31.00 inches wide with front cover on) has ratings up to 15 kV, 75 kA and 4000A (5000A with forced-air cooling). The 31.00-inch frame is also available in a fixed version with ratings up to 15 kV, 75 kA and 6000A (7000A with forced-air cooling).

Count on Eaton's innovative technology to handle high continuous AC current and voltage, then safely switch through extreme out-of-phase voltages and high-stress asymmetrical currents using "clean and green" vacuum interruption without fail for over 10,000 normal operations.

Eaton's VCP-WG generator circuit breakers meet the strict service duty requirements set forth by IEEE for generator circuit applications, including:

- Generator circuit configuration
- High continuous current levels
- Unique fault current conditions
  - Transformer-fed faults
  - Generator-fed faults
- Unique voltage conditions
  - Very fast RRRV
  - Out-of-phase switching

#### Generator Circuit Configuration

The transformer and generator can be in close proximity to the circuit breaker. See **Figure 5.4-1**. Applications with high continuous current levels require connections with large conductors of very low impedance. This construction causes unique fault current and voltage conditions as shown in **Figure 5.4-2**.




Figure 5.4-1. Generator Circuit Application

#### High Continuous Current Levels

Generator circuit breakers must be able to handle high continuous current levels without overheating. VCP-WG drawout circuit breakers are designed to reliably operate up to 4000A with natural air convection cooling, and up to 5000A with suitable enclosure fan cooling during overload conditions. VCP-WRG fixed circuit breakers are designed to reliably operate up to 6000A with natural air convection cooling and up to 7000A with suitable enclosure fan cooling during overload conditions.

#### Unique Fault Current Conditions

System-source (aka, transformer-fed) faults (see **Figure 5.4-1**, fault location "a") can be extremely high. The full energy of the power system feeds the fault, and the low impedance of the fault current path does very little to limit the fault current. Eaton's type VCP-WG Generator Circuit Breakers are ideal for interrupting such high fault currents because they have demonstrated high interruption ratings up to 75 kA, with high DC fault content up to 75%, as proven by high power laboratory tests.

Generator-source (aka, generator-fed) faults, see **Figure 5.4-1**, fault location "b") can cause a severe condition called "Delayed Current Zero," see **Figure 5.4-2**). The high ratio of inductive reactance to resistance (X/R ratio) of the system can cause the DC component of the fault current to exceed 100%. The asymmetrical fault current peak becomes high enough and its decay becomes slow enough that the natural current zero is delayed for several cycles. The circuit breaker experiences longer arcing time and more electrical, thermal and mechanical stress during the interruption. The IEEE standard requires verification that the circuit breaker can interrupt under these severe conditions. Eaton's VCP-WG generator circuit breakers have demonstrated their ability to interrupt three-phase fault current levels up to 135% DC content under delayed current zero conditions.

**Unique Voltage Conditions**

Generator circuits typically produce very fast rates of rise of recovery voltage (RRRV) due to the high natural frequency and low impedance and very low stray capacitance. VCP-WG generator circuit breakers are designed to interrupt fault current levels with very fast RRRV in accordance with IEEE standard C37.013 and C37.013a. VCP-WG generator circuit breakers have a distinct ability to perform under out-of-phase conditions when the generator and power system voltages are not in sync. The voltages across the open contacts can be as high as twice the rated line-to-ground voltage of the system. The IEEE standard requires demonstration by test that the generator circuit breaker can switch under specified out-of-phase conditions.


**Versatility in Application**

Eaton’s generator vacuum circuit breakers are available in drawout (VCP-WG) or fixed (VCP-WRG) configurations to provide for superior performance and versatility. Many industrial and commercial power systems now include small generators as a local source of power. New applications are arising as a result of the de-regulation of the utility industry, and the construction of smaller packaged power plants. Eaton’s generator breakers interrupt large short-circuit currents in a small three-pole package.


Typical applications include:

- Electric utilities: fossil, hydro and wind power
- Packaged power plants
- Industrial companies using combined cycle/combustion turbine plants
- Government and military
- Commercial institutions
- Petrochemical and process industries
- Forestry, pulp and paper
- Mining, exploration and marine

The VCP-WG is the world’s generator circuit breaker for reliable and robust power generation protection.



**Figure 5.4-2. Generator-Fed Faults Can Experience Delayed Current Zero, Where the High Inductance to Resistance Ratio of the System Can Cause the DC Component of the Fault Current to Exceed 100%**



**Figure 5.4-3. Type VCP-WG (Drawout) and Type VCP-WRG (Fixed) Circuit Breakers**

## Technical Data—Type VCP-WG and VCP-WRG Generator Circuit Breakers

### 5 kV Class Generator Circuit Breaker Ratings

**Table 5.4-3. Generator Circuit Breaker Types: VCP-WG (Drawout—DO) / VCP-WRG (Fixed—FIX)**

Description	Units	Short-Circuit Current (Isc)									
		50 kA				63 kA				75 kA	
<b>Maximum Voltage (V): 5 kV</b>											
Frame in Inches (mm) (see Figure 5.4-3 on Page 5.4-9)	—	29.00 (736.6)	29.00 (736.6)	31.00 (787.4)	31.00 (787.4)	29.00 (736.6)	29.00 (736.6)	31.00 (787.4)	31.00 (787.4)	31.00 (787.4)	31.00 (787.4)
Ratings Assigned	—	DO	FIX	DO	FIX	DO	FIX	DO	FIX	DO	FIX
Continuous Current	A rms	1200	1200	—	—	1200	1200	—	—	1200	1200
		2000	2000	—	—	2000	2000	—	—	2000	2000
		3000	3000	—	—	3000	3000	—	—	3000	3000
		4000 ①	4000 ①	4000 ①	4000 ①	4000 ①	4000 ①	4000 ①	4000 ①	4000 ①	4000 ①
		—	—	5000 ①	5000 ①	—	—	5000 ①	5000 ①	5000 ①	5000 ①
		—	—	—	6000	—	—	—	6000	—	6000
		—	—	—	6300 ①	—	—	—	6300 ①	—	6300 ①
		—	—	—	7000 ①	—	—	—	7000 ①	—	7000 ①
<b>Dielectric Strength</b>											
Power frequency withstand voltage	kV rms	19	19	19	19	19	19	19	19	19	19
Lightning impulse withstand voltage	kV peak	60	60	60	60	60	60	60	60	60	60
<b>Interrupting Time</b>	ms	50	50	83	83	50	50	83	83	83	83
<b>Closing Time</b>	ms	47	47	47	47	47	47	47	47	47	47
<b>Short-Circuit Current</b>	kA rms	50	50	50	50	63	63	63	63	75	75
Asymmetrical current interrupting capability	% DC	75	75	75	75	75	75	75	75	63	63
Ref: Minimum opening time	ms	30	30	54	54	30	30	54	54	54	54
Short-time current carrying capability	kA rms	50	50	50	50	63	63	63	63	75	75
Duration of short-time current	sec	3	3	2.3	2.3	3	3	1.4	1.4	1	1
<b>Closing and Latching Capability</b>	kA peak	137	137	137	137	173	173	173	173	206	206
<b>First Generator-Source Symmetrical Current Interrupting Capability</b>	kA rms	25	25	25	25	31.5	31.5	31.5	31.5	40	40
<b>First Generator-Source Asymmetrical Current Interrupting Capability</b>	% DC	130	130	130	130	130	130	130	130	130	130
<b>Second Generator-Source Symmetrical Current Interrupting Capability</b>	kA rms	—	—	31.5	31.5	40	40	40	40	50	50
<b>Second Generator-Source Asymmetrical Current Interrupting Capability</b>	% DC	—	—	110	110	110	110	110	110	110	110
<b>Prospective TRV—Rate of Rise of Recovery Voltage (RRRV)</b>	kV / $\mu$ s	3.0	3.0	3.0	3.0	3.0	3.0	3.0	3.0	3.0 ②	3.0 ②
Transient recovery voltage—Peak ( $E_2 = 1.84 \times V$ )	kV peak	9.2	9.2	9.2	9.2	9.2	9.2	9.2	9.2	9.2 ②	9.2 ②
Transient recovery voltage—Time to Peak ( $T_2 = 0.62 \times V$ )	$\mu$ s	3.1	3.1	3.1	3.1	3.1	3.1	3.1	3.1	3.1 ②	3.1 ②
<b>Load Current Switching Endurance Capability</b>	Operations	10,000	10,000	10,000	10,000	10,000	10,000	10,000	10,000	10,000	10,000
<b>No-Load Mechanical Endurance Capability</b>	Operations	10,000	10,000	10,000	10,000	10,000	10,000	10,000	10,000	10,000	10,000
<b>Out-of-Phase Current Switching Capability</b>	kA	25	25	25	25	31.5	31.5	31.5	31.5	37.5	37.5
90° out-of-phase power frequency recovery voltage ( $= 1.5 \times \text{sqrt}(2/3) \times V$ )	kV rms	6.1	6.1	6.1	6.1	6.1	6.1	6.1	6.1	6.1	6.1
90° out-of-phase inherent TRV—Rate of Rise of Recovery Voltage (RRRV)	kV / $\mu$ s	3.3	3.3	3.3	3.3	3.3	3.3	3.3	3.3	3.3	3.3
Transient recovery voltage—Peak ( $E_2 = 2.6 \times V$ )	kV peak	13	13	13	13	13	13	13	13	13	13
Transient recovery voltage—Time to Peak ( $T_2 = 0.89 \times V$ )	$\mu$ s	4.5	4.5	4.5	4.5	4.5	4.5	4.5	4.5	4.5	4.5

① Ratings achieved using forced-air cooling by blowers in the enclosure.

 ② TRV capacitors are required if RRRV is >0.5 kV/ $\mu$ s; or T<sub>2</sub> is <65  $\mu$ s.

**Note:** Rated frequency: 60 Hz.

**Note:** Standard operating duty: CO - 30 m - CO.

**Note:** Relevant Standard: IEEE standards C37.013-1997 and C37.013a-2007.

**Note:** Test certificates available.

**15 kV Class Generator Circuit Breaker Ratings**

**Table 5.4-4. Generator Circuit Breaker Types: VCP-WG (Drawout—DO) / VCP-WRG (Fixed—FIX) (Continued)**

Description	Units	Short-Circuit Current (Isc)									
		50 kA				63 kA				75 kA	
<b>Maximum Voltage (V): 15 kV</b>											
<b>Frame in Inches (mm)</b> (see Figure 5.4-3 on Page 5.4-9)	—	29.00 (736.6)	29.00 (736.6)	31.00 (787.4)	31.00 (787.4)	29.00 (736.6)	29.00 (736.6)	31.00 (787.4)	31.00 (787.4)	31.00 (787.4)	31.00 (787.4)
<b>Ratings Assigned</b>	—	DO	FIX	DO	FIX	DO	FIX	DO	FIX	DO	FIX
<b>Continuous Current</b>	A rms	1200 2000 3000	1200 2000 3000	— — —	— — —	1200 2000 3000	1200 2000 3000	— — —	— — —	1200 2000 3000	1200 2000 3000
		4000 ① — —	4000 ① — —	4000 5000 ① —	4000 5000 6000	4000 ① — —	4000 ① — —	4000 5000 ① —	4000 5000 6000	4000 5000 ① —	4000 5000 6000
		— —	— —	— —	6300 ① 7000 ①	— —	— —	— —	6300 ① 7000 ①	— —	6300 ① 7000 ①
<b>Dielectric Strength</b>											
Power frequency withstand voltage	kV rms	36	36	36	36	36	36	36	36	36	36
Lightning impulse withstand voltage	kV peak	95	95	95	95	95	95	95	95	95	95
<b>Interrupting Time</b>	ms	50	50	83	83	50	50	83	83	83	83
<b>Closing Time</b>	ms	47	47	47	47	47	47	47	47	47	47
<b>Short-Circuit Current</b>	kA rms	50	50	50	50	63	63	63	63	75	75
Asymmetrical current interrupting capability	% DC	75	75	75	75	75	75	75	75	63	63
Ref: Minimum opening time	ms	30	30	54	54	30	30	54	54	54	54
Short-time current carrying capability	kA rms	50	50	50	50	63	63	63	63	75	75
Duration of short-time current	s	3	3	2.3	2.3	3	3	1.4	1.4	1	1
<b>Closing and Latching Capability</b>	kA peak	137	137	137	137	173	173	173	173	206	206
<b>First Generator-Source Symmetrical Current Interrupting Capability</b>	kA rms	25	25	25	25	31.5	31.5	31.5	31.5	40	40
<b>First Generator-Source Asymmetrical Current Interrupting Capability</b>	% DC	130	130	130	130	130	130	130	130	130	130
<b>Second Generator-Source Symmetrical Current Interrupting Capability</b>	kA rms	—	—	31.5	31.5	40	40	40	40	50	50
<b>Second Generator-Source Asymmetrical Current Interrupting Capability</b>	% DC	—	—	110	110	110	110	110	110	110	110
<b>Prospective TRV—Rate of Rise of Recovery Voltage (RRRV)</b>	kV / μs	3.4	3.4	3.4	3.4	3.4	3.4	3.4	3.4	3.4 ②	3.4 ②
Transient recovery voltage—Peak (E2 = 1.84 x V)	kV peak	27.6	27.6	27.6	27.6	27.6	27.6	27.6	27.6	30.9 ②	30.9 ②
Transient recovery voltage—Time to Peak (T2 = 0.62 x V)	μs	9.3	9.3	9.3	9.3	9.3	9.3	9.3	9.3	9.3 ②	9.3 ②
<b>Load Current Switching Endurance Capability</b>	Operations	10,000	10,000	10,000	10,000	10,000	10,000	10,000	10,000	10,000	10,000
<b>No-Load Mechanical Endurance Capability</b>	Operations	10,000	10,000	10,000	10,000	10,000	10,000	10,000	10,000	10,000	10,000
<b>Out-of-Phase Current Switching Capability</b>	kA	25	25	25	25	31.5	31.5	31.5	31.5	37.5	37.5
90° out-of-phase power frequency recovery voltage (= 1.5 x sqrt(2/3) x V)	kV rms	18.4	18.4	18.4	18.4	18.4	18.4	18.4	18.4	18.4	18.4
90° out-of-phase inherent TRV—Rate of Rise of Recovery Voltage (RRRV)	kV / μs	3.3	3.3	3.3	3.3	3.3	3.3	3.3	3.3	3.3	3.3
Transient recovery voltage—Peak (E2 = 2.6 x V)	kV peak	39	39	39	39	39	39	39	39	39	39
Transient recovery voltage—Time to Peak (T2 = 0.89 x V)	μs	13.4	13.4	13.4	13.4	13.4	13.4	13.4	13.4	13.4	13.4

① Ratings achieved using forced-air cooling by blowers in the enclosure.

② TRV capacitors are required if RRRV is >0.5 kV/μs; or T2 is <65 μs.

**Note:** Rated frequency: 60 Hz.

**Note:** Standard operating duty: CO - 30 m - CO.

**Note:** Relevant Standard: IEEE standards C37.013-1997 and C37.013a-2007.

**Note:** Test certificates available.

## Technical Data—Circuit Breakers

### Type VCP-W Circuit Breaker Operating Times


The closing time (initiation of close signal to contact make) and opening time (initiation of the trip signal to contact break) are shown in **Table 5.4-5**.

**Figure 5.4-4** below shows the sequence of events in the course of circuit interruption, along with applicable VCP-W circuit breaker timings.

**Table 5.4-5. Closing Time and Opening Time**


Rated Control Voltage	Breaker Rating	Closing Time Milliseconds	Opening Time Milliseconds	
			Standard 5-Cycle Breaker	Optional 3-Cycle Breaker
48V, 125V, 250 Vdc	All	45–60	30–45	30–38
120V, 240 Vac	All	45–60	—	—
120V or 240 Vac capacitor trip	All	—	26–41	26–38
Optional—undervoltage trip release 48V, 125V, 250 Vdc	All	—	30–45	30–45

5



**Figure 5.4-4. Sequence of Events and Circuit Breaker Operating Times**

- ① Times shown are based on 60 Hz.
- ② % DC component capability (and asymmetry factor S) depend on the minimum contact parting time. The % DC component capability is  $\geq 50\%$  (S factor  $\geq 1.2$ ) for all VCP-W circuit breakers.



**Figure 5.4-5. Typical Transfer Times ③—Fast Sequential Transfer**

- ③ Times shown are based on 60 Hz.

**Application Quick Check**

See **Table 5.4-7** for application of circuit breakers in a radial system supplied from a single-source transformer. Short-circuit duty was determined using E/X amperes and 1.0 multiplying factor for X/R ratios in the range of 15 to 40.

**Usual Service Conditions**

Usual service conditions for operation of metal-clad switchgear are as follows:

- Altitude does not exceed 3300 feet (1000m)
- Ambient temperature within the limits of -30°C and +40°C (-22°F and +104°F)
- The effect of solar radiation is not significant

**Applications Above 3300 Feet (1006m)**

The rated one-minute power frequency withstand voltage, the impulse withstand voltage, the continuous current rating and the maximum voltage rating must be multiplied by the appropriate correction factor in **Table 5.4-9** to obtain modified ratings that must equal or exceed the application requirements.

**Note:** Intermediate values may be obtained by interpolation.

**Applications Above or Below 40°C Ambient**

Refer to ANSI C37.20.2, Section 8.4 for load current-carrying capabilities under various conditions of ambient temperature and load.

**Applications at Frequencies Less Than 60 Hz**

**Rated Short-Circuit Current**

Based on series of actual tests performed on Type VCP-W circuit breakers and analysis of these test data and physics of vacuum interrupters, it has been found that the current interruption limit for Type VCP-W circuit breakers is proportional to the square root of the frequency. **Table 5.4-6** provides derating factors, which must be applied to breaker interrupting current at various frequencies.

**Table 5.4-6. Derating Factors**

Interrupting Current Derating Factors			
50 Hz	25 Hz	16 Hz	12 Hz
None	0.65	0.52	0.45

**Rated Short-Time and Close and Latch Currents**

No derating is required for short time and close and latch current at lower frequency.

**Rated Continuous Current**

Because the effective resistance of circuit conductors is less at lower frequency, continuous current through the circuit can be increased somewhat. **Table 5.4-8** provides nominal current rating for VCP-W breakers when operated at frequencies below 60 Hz.

**Table 5.4-7. Radial System Application Information**

Source Transformer MVA Rating	Operating Voltage									
	kV									
	Motor Load		2.4	4.16	6.6	12	13.8	27		
	100%	0%								
Up to 5	Up to 7.5	50 VCP-W 250 ① (36 kA)	50 VCP-W 250 ① (33.2 kA)	150 VCP-W 500 (23 kA)	150 VCP-W 500 (22.5 kA)	150 VCP-W 500 (19.6 kA)	270 VCP-W 750 (16 kA)			
7.5 10 ②	10 10	50 VCP-W 350 (49 kA)								
10	12 ②									
12	15		50 VCP-W 350 (46.9 kA)	75 VCP-W 500 (41.3 kA)						
15	20									
20 ②	25 30	Breaker type and symmetrical interrupting capability at the operating voltage					150 VCP-W 750 (35 kA)	150 VCP-W 750 (30.4 kA)		
	50 ②						150 VCP-W 1000 (46.3 kA)	150 VCP-W 1000 (40.2 kA)	270 VCP-W 1000 (22 kA)	
25	50									
30							270 VCP-W 1250 (25 kA)			

① Also includes 50VCPW-ND250.

② Transformer impedance 6.5% or more. All other transformer impedances are 5.5% or more.

**Table 5.4-8. Current Ratings**

Rated Continuous Current at 60 Hz	Nominal Current at Frequency Below 60 Hz			
	50 Hz	25 Hz	16 Hz	12 Hz
1200A	1243	1410	1519	1589
2000A	2075	2374	2573	2703
3000A	3119	3597	3923	4139

**Power Frequency and Impulse Withstand Voltage Ratings**

No derating is required for lower frequency.

**CTs, VTs, Relays and Instruments**

Application at frequency other than rated frequency must be verified for each device on an individual basis.

**Table 5.4-9. Altitude Derating Factors**

Altitude Above Sea Level in Feet (m)	Altitude Correction Factor to be Applied to:	
	Voltage	Rated Continuous Current
3300 (1006) (and Below)	1.0	1.0
4000 (1219)	0.98	0.995
5000 (1524)	0.95	0.991
6000 (1829)	0.92	0.987
6600 (2012)	0.91	0.985
7000 (2137)	0.89	0.98
8000 (2438)	0.86	0.97
9000 (2743)	0.83	0.965
10,000 (3048)	0.80	0.96
12,000 (3658)	0.75	0.95
13,200 (4023)	0.72	0.94
14,000 (4267)	0.70	0.935
16,000 (4877)	0.65	0.925
16,400 (5000)	0.64	0.92
18,000 (5486)	0.61	0.91
20,000 (6096)	0.56	0.90

## Technical Data—Switchgear

### Unusual Service Conditions

Applications of metal-clad switchgear at other than usual altitude or temperature, or where solar radiation is significant, require special consideration. Other unusual service conditions that may affect design and application include:

- Exposure to salt air, hot or humid climate, excessive dust, dripping water, falling dirt, or other similar conditions
- Unusual transportation or storage conditions
- Switchgear assemblies when used as the service disconnecting means
- Installations accessible to the general public
- Exposure to seismic shock
- Exposure to nuclear radiation

### Load Current Switching

Table 5.4-10 showing number of operations is a guide to normal maintenance for circuit breakers operated under usual service conditions for most repetitive duty applications including isolated capacitor bank switching and shunt reactor switching, but not for arc furnace switching. The numbers in the table are equal to or in excess of those required by ANSI C37.06.

Maintenance shall consist of adjusting, cleaning, lubricating, tightening, etc., as recommended by the circuit breaker instruction book.

Continuous current switching assumes opening and closing rated continuous current at rated maximum voltage with power factor between 80% leading and 80% lagging.

Inrush current switching ensures a closing current equal to 600% of rated continuous current at rated maximum voltage with power factor of 30% lagging or less, and an opening current equal

to rated continuous current at rated maximum voltage with power factor between 80% leading and 80% lagging.

In accordance with ANSI C37.06, if a short-circuit operation occurs before the completion of the listed switching operations, maintenance is recommended and possible functional part replacement may be necessary, depending on previous accumulated duty, fault magnitude and expected future operations.

**Table 5.4-10. Breaker Operations Information**

Circuit Breaker Ratings			Maximum Number of Operations <sup>①</sup>			
Rated Maximum Voltage kV rms	Rated Continuous Current Amperes	Rated Short-Circuit Current kA rms, sym.	Between Servicing	No-Load Mechanical	Rated Continuous Current Switching	Inrush Current Switching
4.76, 8.25, 15	1200, 2000	33 kA and below	2000	10,000	10,000	750
4.76, 8.25, 15	3000	All	1000	5000	5000	400
4.76, 15	All	37 kA and above	1000	5000	5000	400
27	All	All	500	2500	2500	100
38	All	All	250	1500	1500	100

<sup>①</sup> Each operation is comprised of one closing plus one opening.

**Table 5.4-11. Heat Loss in Watts at Full Rating, at 60 Hz**

Type of Switchgear Assembly	Breaker Rating	1200A	2000A	2500A	3000A	4000A Fan Cooled
VCP-W	5, 15, and 27 kV	600W	1400W	—	2100W	3700W
VCP-W	38 kV	850W	1700W	2300W	3800W	—
<b>Other Components</b>						
Each CT, standard accuracy	50W					
Each CT, high accuracy	100W					
Each VT	60W					
CPT single-phase, 25 kVA	450W					
CPT single-phase, 45 kVA	892W					
Space heater—each	250W					

## Standard Metal-Clad Switchgear Assembly Ratings

VacClad-W metal-clad switchgear is available for application at voltages up to 38 kV, 50 or 60 Hz. Refer to the table below for complete list of available ratings.

**Table 5.4-12. Standard VCP-W (Non-Arc-Resistant) Metal-Clad Switchgear Ratings Per IEEE C37.20.2-1999 ①②**

Rated Maximum Voltage	(Ref.) Rated Voltage Range Factor K	(Ref.) Rated Short-Circuit Current I	Insulation Level		Rated Main Bus Continuous Current ③④	Rated Short-Time Short-Circuit Current Withstand (2-Second)	Rated Momentary Short-Circuit Current Withstand (10-Cycle) (167 ms)	
			Power Frequency Withstand Voltage, 60 Hz, 1 Minute	Lightning Impulse Withstand Voltage [LIWV] (BIL)			K*I ⑤	2.7 *K*I ⑥
kV rms		kA rms	kV rms	kV Peak	Amperes	kA rms Sym.	kA Crest	kA rms Asym.
4.76	1	25	19	60	1200, 2000, 3000, 4000	25	68	40
	1.24	29			1200, 2000, 3000, 4000	36	97	58
	1	40			1200, 2000, 3000, 4000	40	108	64
	1.19	41			1200, 2000, 3000, 4000	49	132	78
	1	50			1200, 2000, 3000, 4000	50	135	80
	1	63			1200, 2000, 3000, 4000	63	170	101
8.25	1.25	33	36	95	1200, 2000, 3000, 4000	41	111	66
	1	50			1200, 2000, 3000, 4000	50	135	80
15	1.3	18	36	95	1200, 2000, 3000, 4000	23	62	37
	1	25			1200, 2000, 3000, 4000	25	68	40
	1.3	28			1200, 2000, 3000, 4000	36	97	58
	1	40			1200, 2000, 3000, 4000	40	108	64
	1.3	37			1200, 2000, 3000, 4000	48	130	77
	1	50			1200, 2000, 3000, 4000	50	135	80
27	1	16	60	125	1200, 2000, 2500, 2700	16	43	26
	1	22			1200, 2000, 2500, 2700	22	60	35
	1	25			1200, 2000, 2500, 2700	25	68	40
	1	31.5			1200, 2000, 2500, 2700	31.5	85	51
	1	40			1200, 2000, 2500, 2700	40	108	64
38	1	16	80	150 ⑧	1200, 2000, 2500	16	43	26
	1	25			1200, 2000, 2500	25	68	40
	1	31.5			1200, 2000, 2500	31.5	85	51
	1.65	23			1200, 2000, 2500	35	95	56
	1	40			1200, 2000, 2500	40	108	64
38	1	16	80	170 ⑨	1200, 2000, 2500, 3000	16	43	26
	1	25			1200, 2000, 2500, 3000	25	68	40
	1	31.5			1200, 2000, 2500, 3000	31.5	85	51
	1.65	23			1200, 2000, 2500, 3000	35	95	56
	1	40			1200, 2000, 2500, 3000	40	108	64

① The switchgear assembly is designed for use with type VCP-W, VCP-WC and VCP-WG circuit breakers. However, please note that certain VCP-WC circuit breakers may have higher capabilities than required by ANSI standards. In such cases, switchgear assembly ratings as given in this table will apply.

② Switchgear assemblies can be supplied with UL/CSA label. Contact Eaton for availability.

③ Circuit breaker requires forced air cooling to carry 4000A at 4.76, 8.25 and 15 kV, and 3000A at 38 kV.

④ 27 kV 2500A and 2700A main bus ratings are available in two-high design configurations only.

⑤ Please note that use of certain current transformers (for example, bar type CTs) and protective devices may limit the duration to a value less than 2 seconds.

⑥ These values exceed 2.6\*K\*I required by IEEE C37.20.2-1999 and ANSI C37.06-2000.

⑦ These values exceed 1.55\*K\*I required by IEEE C37.20.2-1999.

⑧ This is a standard IEEE C37.20.2 rating for 38 kV Class of switchgear.

⑨ 170 kV LIWV (BIL) rating available as an option, except when a control power transformer is included.

## Technical Data—Assembly Ratings

### Arc-Resistant Switchgear Assembly Ratings

VacClad-W metal-clad arc-resistant switchgear is available for application at voltages up to 38 kV, 50 or 60 Hz. Refer to the table below for complete list of available ratings.

**Table 5.4-13. VacClad-W Arc-Resistant Metal-Clad Switchgear** <sup>①②</sup>

Rated Maximum Voltage <sup>③</sup>	(Ref.) Rated Voltage Range Factor K	(Ref.) Rated Short-Circuit Current I	Ratings per IEEE C37.20.2-1999						Enclosure Internal Arc Withstand				
			Insulation Level		Rated Main Bus Continuous Current <sup>④</sup>	Rated Short-Time Short-Circuit Current Withstand (2-Second)	Rated Momentary Short-Circuit Current Withstand (10-Cycle) (167 ms)		Accessibility Type		Rated Arc Short-Circuit Withstand Current		Rated Arc Duration
			Power Frequency Withstand Voltage, 60 Hz, 1 Minute	Lightning Impulse Withstand Voltage [LIWV] (BIL)			kA rms Sym.	kA Crest	kA rms Asym.	IEEE C37.20.7	EEMAC G14-1	Isc	
kV rms		kA rms	kV rms	kV Peak	Amperes	kA rms Sym.	kA Crest	kA rms Asym.			kA rms Sym.	kA Peak	Sec.
4.76	1	25	19	60	1200, 2000, 3000, 4000	25	68	40	2B	—	25	65	0.5
	1.24	29				36	97	58	2B	—	36	93.6	0.5
	1	40				40	108	64	2B	—	40	104	0.5
	1.19	41				49	132	78	2B	—	49	127.4	0.5
	1	50				50	135	80	2B	—	50	130	0.5
	1	63				63	170	101	2B	—	63	170	0.5
8.25	1.25	33	36	95	1200, 2000, 3000, 4000	41	111	66	2B	—	41	106.6	0.5
	1	50				50	135	80	2B	—	50	130	0.5
15	1.3	18	36	95	1200, 2000, 3000, 4000	23	62	37	2B	—	23	59.8	0.5
	1	25				25	68	40	2B	—	25	65	0.5
	1.3	28				36	97	58	2B	—	36	93.6	0.5
	1	40				40	108	64	2B	—	40	104	0.5
	1.3	37				48	130	77	2B	—	48	124.8	0.5
	1	50				50	135	80	2B	—	50	130	0.5
27 <sup>③⑥</sup>	1	16	60	125	1200, 2000, 2500, 3000	16	43	26	2	B	16	41.6	0.5
	1	22				22	60	35	2	B	22	57.2	0.5
	1	25				25	68	40	2	B	25	65	0.5
	1	31.5				31.5	85	51	2	B	31.5	81.9	0.5
	1	40				40	108	64	2	B	40	104	0.5
38 <sup>③</sup>	1	16	80	150	1200, 2000, 2500, 3000	16	43	26	2	B	16	41.6	0.5
	1	25				25	68	40	2	B	25	65	0.5
	1	31.5				31.5	85	51	2	B	31.5	81.9	0.5
	1.65	23				35	95	56	2	B	35	91	0.5
	1	40				40	108	64	2	B	40	104	0.5

① The switchgear assembly is designed for use with type VCP-W, VCP-WC and VCP-WG circuit breakers. However, please note that certain VCP-WC circuit breakers may have higher capabilities than required by ANSI standards. In such cases, switchgear assembly ratings as given in this table will apply.

② Switchgear assemblies can be supplied with UL/CSA label. Contact Eaton for availability.

③ **5–15 kV switchgear is supplied with a plenum. 27–38 kV switchgear is supplied with arc wall.** For plenum requirements at 27 and 38 kV, contact Eaton.

④ Maximum continuous current rating for circuit breaker that can be supplied at 38 kV is 2500A.

⑤ Please note that use of certain current transformers (for example, bar type CTs) and protective devices may limit the duration to a value less than 2 seconds.

⑥ These values exceed 2.6\*K\*I required by IEEE C37.20.2-1999 and ANSI C37.06-2000.

⑦ These values exceed 1.55\*K\*I required by IEEE C37.20.2-1999.

⑧ 27 kV arc-resistant switchgear can be supplied in one-high configuration only.

## Surge Protection

Eaton's VacClad-W metal-clad switchgear is applied over a broad range of circuits, and is one of the many types of equipment in the total system. The distribution system can be subject to voltage transients caused by lighting or switching surges.

Recognizing that distribution system can be subject to voltage transients caused by lighting or switching, the industry has developed standards to provide guidelines for surge protection of electrical equipment. Those guidelines should be used in design and protection of electrical distribution systems independent of the circuit breaker interrupting medium. The industry standards are:

### ANSI C62

*Guides and Standards for Surge Protection*

### IEEE 242—Buff Book

*IEEE Recommended Practice for Protection and Coordination of Industrial and Commercial Power Systems*

### IEEE 141—Red Book

*Recommended Practice for Electric Power Distribution for Industrial Plants*

### IEEE C37.20.2

*Standards for Metal-Clad Switchgear*

Eaton's medium voltage metal-clad and metal-enclosed switchgear that uses vacuum circuit breakers is applied over a broad range of circuits. It is one of the many types of equipment in the total distribution system. Whenever a switching device is opened or closed, certain interactions of the power system elements with the switching device can cause high frequency voltage transients in the system. Due to the wide range of applications and variety of ratings used for different elements in the power systems, a given circuit may or may not require surge protection. Therefore, Eaton does not include surge protection as standard with its metal-clad or metal-enclosed medium voltage switchgear. The user exercises the options as to the type and extent of the surge protection necessary depending on the individual circuit characteristics and cost considerations.

The following are Eaton's recommendations for surge protection of medium voltage equipment. **Please note these recommendations are valid when using Eaton's vacuum breakers only.**

### Surge Protection Recommendations:

**Note:** The abbreviation ZORC® used in the text below refers to Surge Protection Device manufactured by Strike Technology (Pty) Ltd. An equivalent device offered by other manufacturers, such as Type EHZ by ABB, and Protec Z by Northern Technologies SA can also be used.

1. For circuits exposed to lightning, surge arresters should be applied in line with Industry standard practices.
2. Transformers
  - a. Close-Coupled to medium voltage primary breaker: Provide transients surge protection, such as Surge Arrester in parallel with RC Snubber, or ZORC®. The surge protection device selected should be located and connected at the transformer primary terminals or it can be located inside the switchgear and connected on the transformer side of the primary breaker.
  - b. Cable-Connected to medium voltage primary breaker: Provide transient surge protection, such as Surge Arrester in parallel with RC Snubber, or ZORC for transformers connected by cables with lengths up to 75 feet. The surge protection device should be located and connected at the transformer terminals. No surge protection is needed for transformers with lightning impulse withstand ratings equal to that of the switchgear and connected to the switchgear by cables at least 75 feet or longer. For transformers with lower BIL, provide surge arrester in parallel with RC Snubber or ZORC.
3. Arc-Furnace Transformers—Provide Surge Arrester in parallel with RC Snubber, or ZORC at the transformer terminals.
4. Motors—Provide Surge Arrester in parallel with RC Snubber, or ZORC at the motor terminals. For those motors using VFDs, surge protection should be applied and precede the VFD devices as well.
5. Generators—Provide station class Surge Arrester in parallel with RC Snubber, or ZORC at the generator terminals.
6. Capacitor Switching—No surge protection is required. Make sure that the capacitor's lightning impulse withstand rating is equal to that of the switchgear.
7. Shunt Reactor Switching—Provide Surge Arrester in parallel with RC Snubber, or ZORC at the reactor terminals.
8. Motor Starting Reactors or Reduced Voltage Auto-Transformers—Provide Surge Arrester in parallel with RC Snubber, or ZORC at the reactor or RVAT terminals.
9. Switching Underground Cables—Surge protection not needed.

RC Snubber and/or ZORC damp internal transformer resonance:

The natural frequency of transformer windings can under some circumstances be excited to resonate. Transformer windings in resonance can produce elevated internal voltages that produce insulation damage or failure. An RC Snubber or a ZORC applied at the transformer terminals as indicated above can damp internal winding resonance and prevent the production of damaging elevated internal voltages. This is typically required where rectifiers, UPS or similar electronic equipment is on the transformer secondary.

## Types of Surge Protection Devices




Figure 5.4-6. Surge Protection Devices

Generally surge protective devices should be located as closely as possible to the circuit component(s) that require protection from the transients, and connected directly to the terminals of the component with conductors that are as short and flat as possible to minimize the inductance. It is also important that surge protection devices should be properly grounded for effectively shunting high frequency transients to ground.

## Surge Arresters

The modern metal-oxide surge arresters are recommended because this latest advance in arrester design ensures better performance and high reliability of surge protection schemes. Manufacturer's technical data must be consulted for correct application of a given type of surge arrester. Notice that published arrester MCOV (Maximum Continuous Operating Voltage) ratings are based on 40° or 45°C ambient temperature. In general, the following guidelines are recommended for arrester selections, when installed inside Eaton's medium voltage switchgear:

- A. Solidly Grounded Systems: Arrester MCOV rating should be equal to  $1.05 \times V_{LL} / (1.732 \times T)$ , where  $V_{LL}$  is nominal line-to-line service voltage, 1.05 factor allows for +5% voltage variation above the nominal voltage according to ANSI C84.1, and T is derating factor to allow for operation at 55°C switchgear ambient, which should be obtained from the arrester manufacturer for the type of arrester under consideration. Typical values of T are: 0.946 to 1.0.

- B. Low Resistant Grounded Systems (systems grounded through resistor rated for 10 seconds): Arrester 10-second MCOV capability at 60°C, which is obtained from manufacturer's data, should be equal to  $1.05 \times V_{LL}$ , where  $V_{LL}$  is nominal line-to-line service voltage, and 1.05 factor allows for +5% voltage variation above the nominal voltage.
- C. Ungrounded or Systems Grounded through impedance other than 10-second resistor: Arrester MCOV rating should be equal to  $1.05 \times V_{LL} / T$ , where  $V_{LL}$  and T are as defined above.

Refer to **Table 5.4-14** for recommended ratings for metal-oxide surge arresters that are sized in accordance with the above guidelines, when located in Eaton's switchgear.

## Surge Capacitors

Metal-oxide surge arresters limit the magnitude of prospective surge overvoltage, but are ineffective in controlling its rate of rise. Specially designed surge capacitors with low internal inductance are used to limit the rate of rise of this surge overvoltage to protect turn-to-turn insulation. Recommended values for surge capacitors are: 0.5  $\mu\text{f}$  on 5 and 7.5 kV, 0.25  $\mu\text{f}$  on 15 kV, and 0.13  $\mu\text{f}$  on systems operating at 24 kV and higher.

## RC Snubber

A RC Snubber device consists of a non-inductive resistor R sized to match surge impedance of the load cables, typically 20 to 30 ohms, and connected in series with a Surge Capacitor C. The Surge Capacitor is typically sized to be 0.15 to 0.25 microfarad. Under normal operating conditions, impedance of the capacitor is very high, effectively "isolating" the resistor R from the

system at normal power frequencies, and minimizing heat dissipation during normal operation. Under high frequency transient conditions, the capacitor offers very low impedance, thus effectively "inserting" the resistor R in the power system as cable terminating resistor, thus minimizing reflection of the steep wave-fronts of the voltage transients and prevents voltage doubling of the traveling wave. The RC Snubber provides protection against high frequency transients by absorbing and damping the transients. Please note RC Snubber is most effective in mitigating fast-rising transient voltages, and in attenuating reflections and resonances before they have a chance to build up, but does not limit the peak magnitude of the transient. Therefore, the RC Snubber alone may not provide adequate protection. To limit peak magnitude of the transient, application of surge arrester should also be considered.

## ZORC

A ZORC device consists of parallel combination of Resistor (R) and Zinc Oxide Voltage Suppressor (ZnO), connected in series with a Surge Capacitor. The resistor R is sized to match surge impedance of the load cables, typically 20 to 30 ohms. The ZnO is a gapless metal-oxide non-linear arrester, set to trigger at 1 to 2 PU voltage, where  $1 \text{ PU} = 1.412 \times (V_{LL} / 1.732)$ . The Surge Capacitor is typically sized to be 0.15 to 0.25 microfarad. As with RC Snubber, under normal operating conditions, impedance of the capacitor is very high, effectively "isolating" the resistor R and ZnO from the system at normal power frequencies, and minimizing heat dissipation during normal operation. Under high frequency transient conditions, the capacitor offers very low impedance, thus effectively "inserting" the resistor R and ZnO in the power system as cable terminating network, thus minimizing reflection of the steep wave-fronts of the voltage transients and prevents voltage doubling of the traveling wave. The ZnO element limits the peak voltage magnitudes. The combined effects of R, ZnO, and Capacitor of the ZORC device provides optimum protection against high frequency transients by absorbing, damping, and by limiting the peak amplitude of the voltage wave-fronts. Please note that the ZORC is not a lightning protection device. If lightning can occur or be induced in the electrical system, a properly rated and applied surge arrester must precede the ZORC.

**Surge Protection Summary**

**Minimum protection:** Surge Arrester for protection from high overvoltage peaks, or Surge Capacitor for protection from fast-rising transient. Please note that the surge arresters or surge capacitor alone may not provide adequate surge protection from escalating voltages caused by circuit resonance. Note that when applying surge capacitors on both sides of a circuit breaker, surge capacitor on one side of the breaker must be RC Snubber or ZORC, to mitigate possible virtual current chopping.

**Good protection:** Surge Arrester in parallel with Surge Capacitor for protection from high overvoltage peaks and fast rising transient. This option may not provide adequate surge protection from escalating voltages caused by circuit resonance. When applying surge capacitors on both sides of a circuit breaker, surge capacitor on one side of the breaker must be RC Snubber or ZORC, to mitigate possible virtual current chopping.

**Better protection:** RC Snubber in parallel with Surge Arrester for protection from high frequency transients and voltage peaks.

**Best protection:** ZORC, plus proper surge arrester preceding ZORC where needed for protection against lightning. ZORC provides protection from high frequency voltage transients and limits peak magnitude of the transient to 1 to 2 PU (see ZORC description on **Page 5.4-18** for more detail). Surge arrester provides protection from higher voltage peaks resulting from lightning surges.

**Table 5.4-14. Surge Arrester Selections—Recommended Ratings**

Service Voltage Line-to-Line kV	Distribution Class Arresters						Station Class Arresters					
	Solidly Grounded System		Low Resistance Grounded System		High Resistance or Ungrounded System		Solidly Grounded System		Low Resistance Grounded System		High Resistance or Ungrounded System	
	Arrester Ratings kV						Arrester Ratings kV					
	Nominal	MCOV	Nominal	MCOV	Nominal	MCOV	Nominal	MCOV	Nominal	MCOV	Nominal	MCOV
2.30	3	2.55	3	2.55	3	2.55	3	2.55	3	2.55	3	2.55
2.40	3	2.55	3	2.55	6	5.10	3	2.55	3	2.55	6	5.10
3.30	3	2.55	3	2.55	6	5.10	3	2.55	3	2.55	6	5.10
4.00	3	2.55	6	5.10	6	5.10	3	2.55	6	5.10	6	5.10
4.16	6	5.10	6	5.10	6	5.10	6	5.10	6	5.10	6	5.10
4.76	6	5.10	6	5.10	9	7.65	6	5.10	6	5.10	9	7.65
4.80	6	5.10	6	5.10	9	7.65	6	5.10	6	5.10	9	7.65
6.60	6	5.10	6	5.10	9	7.65	6	5.10	6	5.10	9	7.65
6.90	6	5.10	6	5.10	9	7.65	6	5.10	9	7.65	9	7.65
7.20	6	5.10	6	5.10	10	8.40	6	5.10	9	7.65	10	8.40
8.32	9	7.65	9	7.65	12	10.20	9	7.65	9	7.65	12	10.20
8.40	9	7.65	9	7.65	12	10.20	9	7.65	9	7.65	12	10.20
11.00	9	7.65	9	7.65	15	12.70	9	7.65	10	8.40	15	12.70
11.50	9	7.65	10	8.40	18	15.30	9	7.65	12	10.20	18	15.30
12.00	10	8.40	10	8.40	18	15.30	10	8.40	12	10.20	18	15.30
12.47	10	8.40	12	10.20	18	15.30	10	8.40	12	10.20	18	15.30
13.20	12	10.20	12	10.20	18	15.30	12	10.20	12	10.20	18	15.30
13.80	12	10.20	12	10.20	18	15.30	12	10.20	15	12.70	18	15.30
14.40	12	10.20	12	10.20	21	17.00	12	10.20	15	12.70	21	17.00
18.00	15	12.70	15	12.70	27	22.00	15	12.70	18	15.30	27	22.00
20.78	18	15.30	18	15.30	30	24.40	18	15.30	21	17.00	30	24.40
22.00	18	15.30	18	15.30	30	24.40	18	15.30	21	17.00	30	24.40
22.86	18	15.30	21	17.00	—	—	18	15.30	24	19.50	36	29.00
23.00	18	15.30	21	17.00	—	—	18	15.30	24	19.50	36	29.00
24.94	21	17.00	24	19.50	—	—	21	17.00	24	19.50	36	29.00
25.80	21	17.00	24	19.50	—	—	21	17.00	24	19.50	36	29.00
26.40	21	17.00	24	19.50	—	—	21	17.00	27	22.00	39	31.50
33.00	27	22.00	30	24.40	—	—	27	22.00	36	29.00	45	36.50
34.50	30	24.40	30	24.40	—	—	30	24.40	36	29.00	48	39.00
38.00	30	24.40	—	—	—	—	30	24.40	36	29.00	—	—

### Instrument Transformers

Instrument transformers are used to protect personnel and secondary devices from high voltage, and permit use of reasonable insulation levels for relays, meters and instruments. The secondaries of standard instrument transformers are rated at 5A and/or 120V, 60 Hz.

### Voltage Transformers

Selection of the ratio for voltage transformers is seldom a question since the primary rating should be equal to or higher than the system line-to-line voltage. The number of potential transformers per set and their connection is determined by the type of system and the relaying and metering required.

When two VTs are used, they are typically connected L-L, and provide phase-to-phase voltages, (Vab, Vbc, Vca) for metering and relaying.

When three VTs are used, they are connected line-to-ground, and provide phase-to-phase (Vab, Vbc, Vca), as well as phase-to-ground (Va, Vb, Vc) voltages for metering and relaying.

If metering or relaying application requires phase-to-ground voltages, use three VTs, each connected L-G. If not, use of two VTs connected L-L is sufficient.

For ground detection, three VTs connected in Line-to-ground/broken-delta are used.

A single VT, when used, can be connected line-to-line (it will provide line-to-line output, for example Vab or Vbc or Vca), or line-to-ground (it will provide line-to-ground output, for example Va or Vb or Vc). Generally, a single VT is used to derive voltage signal for synchronizing or Over Voltage/Under Voltage function.

### Current Transformers

The current transformer ratio is generally selected so that the maximum load current will read about 70% full scale on a standard 5A coil ammeter. Therefore, the current transformer primary rating should be 140–150% of the maximum load current.

Maximum system fault current can sometimes influence the current transformer ratio selection because the connected secondary devices have published one-second ratings.

The zero-sequence current transformer is used for sensitive ground fault relaying or self-balancing primary current type machine differential protection. The zero-sequence current transformer is available with a nominal ratio of 50/5 or 100/5 and available opening size for power cables of

7.25 inches (184.2 mm). Special zero-sequence transformers with larger windows are also available.

The minimum number of current transformers for circuit relaying and instruments is three current transformers, one for each phase or two-phase connected current transformers and one zero-sequence current transformer. Separate sets of current transformers are required for differential relays.

The minimum pickup of a ground relay in the residual of three-phase connected current transformers is primarily determined by the current transformer ratio. The relay pickup can be reduced by adding one residual connected auxiliary current transformer. This connection is very desirable on main incoming and tie circuits of low resistance grounded circuits.

When utilizing the MP-3000 Motor Protective Relay, it is recommended that the ratio of CT primary rating to the motor full load amperes (CTprim/Motor FLA) is selected to fall between 0.5 to 1.5.

Standard accuracy current transformers are normally more than adequate for most standard applications of microprocessor-based protective relays and meters. See **Table 5.4-17** for CT accuracy information.

**Table 5.4-15. Standard Voltage Transformer Ratio Information**

Rating-Volts	2400	4200	4800	7200	8400	10800	12000	14400	15600	18000	21000	24000	27000	36000
Ratio	20-1	35-1	40-1	60-1	70-1	90-1	100-1	120-1	130-1	150-1	175-1	200-1	225-1	300-1

**Table 5.4-16. Standard Voltage Transformer, 60 Hz Accuracy Information**

Switchgear		Voltage Transformer—ANSI Accuracy											
kV Class	kV BIL	Maximum Number Per Set and Connection	Standard Ratios	Burdens at 120 Volts				Burdens at 69.3 Volts				Thermal Rating 55°C Connection	Volt-Ampere
				W, X, Y	Z	M	ZZ	W, X	Y	M	Z		
5	60	2LL or 3LG	20, ① 35, 40	0.3	1.2	—	—	0.3	—	—	—	LL LG LG ②	700 400 700
7.5 and 15	95	2LL or 3LG	35, 40, 60, 70, 100, 120	0.3	0.3	0.3	0.6	0.3	0.3	0.3	1.2	LL LG LG ②	1000 550 1000
27	125	2LL or 3LG	90, 100, 120, 130, 150, 175, 200, 225	0.3	0.3	0.3	1.2	0.3	0.3	0.3	1.2	LL LG LG ②	1000 550 1000
38	170	2LL or 3LG	175, 300	0.3	0.3	0.3	0.3	0.3	0.3	0.3	0.3	LL LG LG ②	1000 550 1000

① For solidly grounded 4160V system only or any type 2400V system.

② For solidly grounded system only.

**Note:** LL = Line-to-line connection. LG = Line-to-ground connection.

**Table 5.4-17. Current Transformers, 55°C Ambient**

CT Ratio (MR = Multi-Ratio)	Metering Accuracy Classification			Relaying Accuracy Classification		
	At 60 Hz Standard Burden B 0.1	At 60 Hz Standard Burden B 0.5	At 60 Hz Standard Burden B 1.8	Minimum Accuracy Required per IEEE C37.20.2	Standard Accuracy Supplied in VCP-W Switchgear	Optional High Accuracy Available in VCP-W Switchgear
50:5 75:5 100:5	1.2 1.2 1.2	— 2.4 2.4	— — —	C10 C10 C10	C10 C20 C20	— — —
150:5 200:5 250:5	0.6 0.6 0.6	2.4 2.4 2.4	— — —	C20 C20 ③	C20 C20 C20	C50 C50 C50
300:5 400:5 500:5	0.6 0.3 0.3	2.4 1.2 0.3	2.4 2.4 2.4	C20 C50 ③	C20 C50 C50	C100 C100 C100
600:5 800:5 1000:5	0.3 0.3 0.3	0.3 0.3 0.3	2.4 1.2 0.3	C50 C50 ③	C100 C100 C100	C200 C200 C200
1200:5 1500:5 2000:5	0.3 0.3 0.3	0.3 0.3 0.3	0.3 0.3 0.3	C100 C100 C100	C200 C200 C200	C400 C400 C400
2500:5 3000:5 4000:5	0.3 0.3 0.3	0.3 0.3 0.3	0.3 0.3 0.3	③ C100 C100	C200 C200 C200	C400 C400 C400
600:5 MR 1200:5 MR 2000:5 MR 3000:5 MR	0.3 0.3 0.3 0.3	0.3 0.3 0.3 0.3	2.4 0.3 0.3 0.3	③ ③ ③ ③	C100 C200 C200 C200	C200 C400 C400 C400
50:5 zero sequence 100:5 zero sequence	— —	— —	— —	— —	C10 C20	— —

③ Not listed in C37.20.2.

**Note:** Maximum number of CTs—Two sets of standard accuracy or one set of high accuracy CTs can be installed in the breaker compartment on each side of the circuit breaker.

## Control Equipment

### Circuit Breaker Control

Eaton's VCP-W circuit breaker has a motor charged spring type stored energy closing mechanism. Closing the breaker charges accelerating springs. Protective relays or the control switch will energize a shunt trip coil to release the accelerating springs and open the breaker. This requires a reliable source of control power for the breaker to function as a protective device. Typical AC and DC control schematics for type VCP-W circuit breakers are shown on **Pages 5.4-24 and 5.4-25**.

For AC control, a capacitor trip device is used with each circuit breaker shunt trip to ensure that energy will be available for tripping during fault conditions. A control power transformer is required on the source side of each incoming line breaker. Closing bus tie or bus sectionalizing breakers will require automatic transfer of control power. This control power transformer may also supply other AC auxiliary power requirements for the switchgear.

For DC control, it would require a DC control battery, battery charger and an AC auxiliary power source for the battery charger. The battery provides a very reliable DC control source, since it is isolated from the AC power system by the battery charger. However, the battery will require periodic routine maintenance and battery capacity is reduced by low ambient temperature. Any economic comparison of AC and DC control for switchgear should consider that the AC capacitor trip is a static device with negligible maintenance and long life, while the DC battery will require maintenance and replacement at some time in the future.

### Relays

Microprocessor-based or solid-state relays would generally require DC power or reliable uninterruptible AC supply for their logic circuits.

### Auxiliary Switches

Optional circuit breaker and cell auxiliary switches are available where needed for interlocking or control of auxiliary devices. Typical applications and operation are described in **Figure 5.4-7** and **Table 5.4-18**.

Breaker auxiliary switches and MOC switches are used for breaker open/close status and interlocking.

Auxiliary contacts available for controls or external use from auxiliary switch located on the circuit breaker are typically limited in number by the breaker control requirements as follows:

- Breakers with AC control voltage: 1NO and 3NC
- Breakers with DC control voltage: 2NO and 3NC

When additional auxiliary contacts are needed, following options are available:

- 5/15/27 kV Breakers: Each breaker compartment can be provided with up to three Mechanism Operated Cell (MOC) switches, each with 5NO and 4NC contacts. The MOC switches are rotary switches, mounted in the cell, and operated by a plunger on the breaker. Two types of MOC switches can be provided—MOC that operates with breaker in connected position only, or MOC that operates with breaker in connected, as well as test position

- 38 kV Breakers: Each 38 kV breaker can be provided with an additional breaker mounted auxiliary switch, with 5 NO and 5 NC contacts

Another optional switch available is called TOC—Truck Operated Switch. This switch is mounted in the cell and operates when the circuit breaker is levered into or out of the operating position. This switch changes its state when breaker is moved from test to connected position and vice versa. The TOC provides 4NO and 5NC contacts.

Auxiliary switch contacts are primarily used to provide interlocking in control circuits, switch indicating lights, auxiliary relays or other small loads. Suitability for switching remote auxiliary devices, such as motor heaters or solenoids, may be checked with the interrupting capacity listed in **Table 5.4-18**. Where higher interrupting capacities are required, an interposing contactor should be specified.




Figure 5.4-7. Breaker Auxiliary Switch Operating Times

Table 5.4-18. Auxiliary Switch Contacts Interrupting Capacities

Type Auxiliary Switch	Continuous Current Amperes	Control Circuit Voltage				
		120 Vac	240 Vac	48 Vdc	125 Vdc	250 Vdc
<b>Non-inductive Circuit Interrupting Capacity in Amperes</b>						
Breaker Auxiliary Switch	20	15	10	16	10	5
TOC Switch	20	15	10	16	10	5
MOC Switch	20	15	10	16	10	5
<b>Inductive Circuit Interrupting Capacity in Amperes</b>						
Breaker Auxiliary Switch	20	15	10	16	10	5
TOC Switch	20	15	10	16	10	5
MOC Switch	20	15	10	16	10	5

**Technical Data—Control Equipment**

**Table 5.4-19. VCP-W Breaker Stored Energy Mechanism Control Power Requirements**

Rated Control Voltage	Spring Charging Motor			Close or Trip Amperes	UV Trip mA Maximum	Voltage Range		Indicating Light Amperes
	Inrush Amperes	Run Amperes	Average Run Time, Sec.			Close	Trip	
48 Vdc	36.0	9	6	16	200	38–56	28–56	0.02
125 Vdc	16.0	4	6	7	80	100–140	70–140	0.02
250 Vdc	9.2	2	6	4	40	200–280	140–280	0.02
120 Vac	16.0	4	6	6	—	104–127	104–127	0.02
240 Vac	9.2	2	6	3	—	208–254	208–254	0.02

**Table 5.4-20. Control Power Transformers—Single-Phase, 60 Hz ①**


Taps			Secondary Volts	kVA	kV Class
+7-1/2%	Rated	-7-1/2%			
2580	2400	2220	240/120	5, 10, 15	5
4470	4160	3850	240/120	5, 10, 15	5
5160	4800	4400	240/120	5, 10, 15	5
7740	7200	6680	240/120	5, 10, 15	15
9030	8400	7770	240/120	5, 10, 15	15
13405	12470	11535	240/120	5, 10, 15	15
14190	13200	12210	240/120	5, 10, 15	15
14835	13800	12765	240/120	5, 10, 15	15
24725	23000	21275	240/120	5, 10, 15	27
37088	34500	31913	240/120	15, 25	38 ②

① Line-to-line connection only available. Refer to Eaton for other voltages and kVA ratings.

② 150 kV BIL.

**Technical Data—Control Schematics**


5



**Figure 5.4-8. Typical 5/15/27 kV VCP-W “DC” and “AC” Control Schematics**

**Legend:** CS = Breaker Control Switch—Close  
 C = Breaker Control Switch—Close  
 CS T = Breaker Control Switch—Trip  
 Y = Anti Pump Relay  
 SR = Spring Release Coil (Coil)  
 M = Spring Charge Motor  
 ST = Shunt Trip  
 PR = Protective Relay  
 A = Secondary Disconnect

**Operation:** LS1 = Open until springs are fully charged.  
 LS1 = Closed until springs are fully charged.  
 LS2 = Open until springs are fully charged.  
 LS2 = Closed until springs are fully charged.  
 LC = Open until mechanism is reset.  
 PS1 = Open in all except between “Test” and “Connected” positions.  
 PS2 = Closed in all except between “Test” and “Connected” positions.




**Figure 5.4-9. Typical 38 kV VCP-W "DC" and "AC" Control Schematics**

**Legend:** CS = Breaker Control Switch—Close  
 C = Breaker Control Switch—Close  
 CS T = Breaker Control Switch—Trip  
 Y = Anti Pump Relay  
 SR = Spring Release Coil (Coil)  
 M = Spring Charge Motor  
 ST = Shunt Trip  
 PR = Protective Relay  
 Δ = Secondary Disconnect


**Operation:** LS1 = Open until springs are fully charged.  
 LS1 = Closed until springs are fully charged.  
 LS2 = Open until springs are fully charged.  
 LS2 = Closed until springs are fully charged.  
 LC = Open until mechanism is reset.  
 PS1 = Open in all except between "Test" and "Connected" positions.  
 PS2 = Closed in all except between "Test" and "Connected" positions.

**Technical Data—Relays—Device Numbers, Type and Function**


5




**Figure 5.4-10. Protective Relays—Feeder Circuit**



**Figure 5.4-12. Protective Relays—Transformer Feeder**




**Figure 5.4-11. Protective Relays—Induction Motors Below 1500 hp Minimum Adequate Protection**



**Figure 5.4-13. Protective Relays—Induction Motors Above 1500 hp and Synchronous Motors**

**EDR-4000 Relay—Typical One-Line Diagrams**




**5**

**Figure 5.4-14. EDR-4000 Eaton Distribution Relay—Typical Main or Feeder Breaker Application Diagram**

- ① Can be set for Forward, Reverse or Both directions.
- ② Can be Set for Underfreq, Overfreq, Rate of Change or Vector Change.

**EDR-5000 Relay—Typical One-Line Diagrams**



**Figure 5.4-15. EDR-5000 Eaton Distribution Relay—Typical Main or Feeder Breaker Application Diagram**

- ① Can be set for Forward, Reverse or Both directions.
- ② Can be Set for Underfreq, Overfreq, Rate of Change or Vector Change.


Refer to **Tab 4** for details on Eaton’s relays. Refer to **Tab 3** for details on Eaton’s available metering.

5

**Typical Main-Tie-Main Arrangements (Standard Metal-Clad)**


**Note:** Arrangements shown in **Figures 5.4-16–5.4-18** can be provided in 26.00-inch (660.4 mm) wide, 95.00-inch (2413.0 mm) high, 96.25-inch (2444.8 mm) deep structures with 50VCPWND, 1200A circuit breakers.

**Note:** R = Multi-function relay, M = Multi-function meter.



**5**

**Figure 5.4-16. Typical Main-Tie-Main Arrangement with Bus and Line VTs and Line CPTs  
5 or 15 kV VCP-W Switchgear, 1200 or 2000A Mains and Tie, 36.00-Inch (914.4 mm) Wide Structures**




**Figure 5.4-17. Typical Main-Tie-Main Arrangement with Bus and Line VTs, but without Line CPTs—Preferred Arrangement  
5 or 15 kV VCP-W Switchgear, 1200 or 2000A Mains and Tie, 36.00-Inch (914.4 mm) Wide Structures**

**Typical Standard Metal-Clad Switchgear Application Layouts, 5–15 kV**


**Typical Main-Tie-Main Arrangements (Continued)**

Note: R = Multi-function relay, M = Multi-function meter

5




**Figure 5.4-18. Typical Main-Tie-Main Arrangement with Bus and Line VTs, but without Line CPTs—Alternate Arrangement  
5 or 15 kV VCP-W Switchgear, 1200 or 2000A Mains and Tie, 36.00-Inch (914.4 mm) Wide Structures**



**Figure 5.4-19. Typical Main-Tie-Main Arrangement with Bus and Line VTs, and Line CPTs  
5 or 15 kV VCP-W Switchgear, 3000A Mains and Tie, 36.00-Inch (914.4 mm) Wide Structures**

**Typical Main-Tie-Main Arrangements (Continued)**

Note: R = Multi-function relay, M = Multi-function meter



**Figure 5.4-20. Typical Main-Tie-Main Arrangement with Bus and Line VTs  
5 or 15 kV VCP-W Switchgear, 3000A Mains and Tie, 36.00-Inch (914.4 mm) Wide Structures**

① This arrangement can be supplied with cooling fans to allow 4000A continuous.

**Medium Voltage High Resistance  
Grounding System**


Refer to **Tab 36, Section 36.1**, for complete product description, single-line diagram, layout and dimensions of medium voltage high resistance grounding system.

---


*This page intentionally left blank.*

**Layout Dimensions—5 and 15 kV—Dimensions in Inches (mm)**


**Typical Units**



**Figure 5.5-1. 36.00-Inch (914.4 mm) Wide Typical Breaker/Breaker Vertical Section**




**Figure 5.5-2. 36.00-Inch (914.4 mm) Wide Typical Auxiliary/Breaker Vertical Section**



**Figure 5.5-3. 36.00-Inch (914.4 mm) Wide Typical Auxiliary/Auxiliary Vertical Section**

**Tie Breaker Bus Transition Requirements**



**Figure 5.5-4. Tie Breaker Bus Transition Requirements**

① Breakers cannot be located in bus transition compartment.

**Available Configurations**

1200 Ampere Breaker	1200 Ampere Breaker	1200 Ampere Breaker
1200 Ampere Breaker	2000 Ampere Breaker	Drawout Auxiliary
Drawout Auxiliary	2000 Ampere Breaker	Drawout Auxiliary
1200 Ampere Breaker	Drawout Auxiliary	2000 Ampere Breaker
Vented Auxiliary Compartment (Non-Drawout)	Drawout Auxiliary	2000 Ampere Breaker
3000 Ampere Breaker	Drawout Auxiliary	1200 Ampere Breaker
3000 Ampere Breaker ②③		
Vent Area		
Drawout Auxiliary		

**Figure 5.5-5. Available Configurations**

② For 4000A force cooled application, refer to Eaton.

③ This configuration is available for indoor and outdoor walk-in designs only.

*Dimensions for estimating purposes only.*

Layout Dimensions—5 and 15 kV, 36.00-Inch (914.4 mm) Wide Structures (Standard Metal-Clad)

## Typical Weights in Lbs (kg)

Table 5.5-1. Assemblies (Less Breakers. See Table 5.5-2 for Breakers.) ①

Type of Vertical Section	Main Bus Rating Amperes	Indoor	Aisleless	Sheltered-Aisle Including Aisle	
				Single Row	Double Row
B/B	1200	2400 (1090)	3200 (1453)	4200 (1907)	7200 (3269)
	2000	2500 (1135)	3300 (1500)	4300 (1952)	7400 (3360)
	3000	2600 (1180)	3400 (1545)	4400 (1998)	7600 (3450)
	4000	2700 (1226)	3500 (1590)	4500 (2045)	7700 (3500)
B/A or A/B	1200	2300 (1044)	2900 (1317)	4100 (1861)	7000 (3178)
	2000	2400 (1090)	3000 (1362)	4200 (1907)	7200 (3269)
	3000	2500 (1135)	3100 (1407)	4300 (1952)	7400 (3360)
	4000	2600 (1180)	3200 (1453)	4400 (1998)	7500 (3409)
A/A	1200	2000 (908)	2600 (1180)	3800 (1725)	6400 (2906)
	2000	2100 (953)	2700 (1226)	3900 (1771)	6600 (2996)
	3000	2200 (999)	2800 (1271)	4000 (1816)	6800 (3087)
	4000	2300 (1046)	2900 (1317)	4100 (1861)	6900 (3136)

① See Table 5.5-2 for breakers.

Table 5.5-2. Breaker Weights in Lbs (kg)

Type of Breaker	Current Rating, Amperes		
	1200	2000	3000
	Approximate Weight, Lbs (kg), Static ②		
50 VCP-W 250, 40C, 25, 40	350 (159)	410 (186)	525 (238)
50 VCP-W 350, 50C, 50	460 (209)	490 (222)	525 (238)
50 VCP-W 500, 63C, 63	575 (261)	575 (261)	575 (261)
75 VCP-W 500, 50C, 50	375 (170)	410 (186)	525 (238)
150 VCP-W 500, 25C, 25	350 (159)	410 (186)	525 (238)
150 VCP-W 750, 40C, 40	350 (159)	410 (186)	525 (238)
150 VCP-W 1000, 50C, 50	460 (209)	490 (222)	525 (238)
150 VCP-W 1500, 63C, 63	575 (261)	575 (261)	575 (261)

② Impact weight = 1.5 times static weight.

## Dimensions in Inches (mm)




Figure 5.5-6. Outdoor Sheltered Aisle Single Row




Figure 5.5-7. Outdoor Sheltered Aisle Double Row




Figure 5.5-8. Indoor





Figure 5.5-9. Outdoor Aisleless

Dimensions and weights for estimating purposes only.





**Layout Dimensions—5 and 15 kV, 36.00-Inch (914.4 mm) Wide Structures (Standard Metal-Clad)**


- ① Location for station ground connection.
- ② Attach switchgear to foundation using one of the two holes. Use 5/8" Grade 5 or better bolt. Torque to 150 ft.-lbs. (Total of 4 mounting bolts per vertical section, one at each corner.)
- ③ Power cable entrance space. Refer to shop order base plan drawing for conduit locations. Conduit projection not to exceed 8.00 inches (203.2 mm).
- ④ Secondary control wiring conduit entrance space. Conduit stub ups not to project more than 7.00 inches (177.8 mm).
- ⑤ Finished foundation surface shall be level within 0.06-inch (1.5 mm) in 36 inches (914.4 mm) left-to-right, front-to-back, and diagonally, as measured by a laser level.



Attach to the Floor at One of the Two Hole Locations Shown Using 5/8" Grade 5 Bolt or Better Torque to 150 Ft.-Lbs.



**Figure 5.5-14. 5/15 kV Switchgear Outdoor Aisleless Base Plan (Typical Details)—Dimensions in Inches (mm)**



**Figure 5.5-15. 5/15 kV Switchgear Outdoor Sheltered Aisle Base Plan (Typical Details)—Dimensions in Inches (mm)**

## Layout Dimensions—5 and 15 kV, 36.00-Inch (914.4 mm) Wide Structures (Standard Metal-Clad)

**Note:**  
First install both rows of switchgear then install aisle parts per drawing. (Later)

① Location for station ground connection typical each end unit.

② ⑤ Attach switchgear to foundation using one of the two holes. Use 5/8" Grade 5 or better bolt. Torque to 150 ft. lbs. (Total of 4 mounting bolts per vertical section, one at each corner.)


③ Power cable entrance space. Refer to shop order base plan drawing for conduit locations. Conduit projection not to exceed 8.00 inches (203.2 mm).

④ Secondary control wiring conduit entrance space. Conduit stub ups not to project more than 7.00 inches (177.8 mm).


⑥ Finished foundation surface shall be level within 0.06-inch (1.5 mm) in 36.00 inches (914.4 mm) left-to-right, front-to-back, and diagonally, as measured by a laser level.

Attach to the Switchgear Channels Using Supplied Hardware

Attach to the Floor at One of the Two Hole Locations Shown Using 5/8" Grade 5 Bolt or Better Torque to 150 Ft. Lbs.



⑤ Mounting Angle Details



② Mounting Clip Details

5






Figure 5.5-16. 5/15 kV Switchgear Outdoor Common Aisle Base Plan (Typical Details)—Dimensions in Inches (mm)

**Layout Dimensions—5 kV—Dimensions in Inches (mm)**


**Typical Units—Indoor**



**Figure 5.5-17. 26.00-Inch (660.4 mm) Wide Typical Breaker/Breaker Vertical Section**




**Figure 5.5-18. 26.00-Inch (660.4 mm) Wide Typical Auxiliary/Breaker Vertical Section**



**Figure 5.5-19. 26.00-Inch (660.4 mm) Wide Typical Auxiliary/Auxiliary Vertical Section**


**Tie Breaker Bus Transition Requirements**



**Figure 5.5-20. Tie Breaker Bus Transition Requirements**

① Breakers cannot be located in bus transition compartment.

**Available Configurations**



**Figure 5.5-21. Available Configurations**

**Typical Weights**

**Table 5.5-3. Switchgear Assembly (Less Breaker)**

Type of Vertical Section	Main Bus Rating, Amperes	Weight Lbs (kg)
B/B	1200	2000 (908)
	2000	2200 (999)
B/A or A/B	1200	1700 (772)
	2000	1900 (863)
A/A	1200	1600 (726)
	2000	1800 (817)


**Table 5.5-4. Circuit Breaker ②**

Type of Circuit Breaker	Current Rating, Amperes	Weight Lbs (kg) (Static)
50 VCPW-ND-250	1200	345 (157)

② Breaker impact weight = 1.5 x static weight.


*Dimensions for estimating purposes only.*

**Dimensions in Inches (mm) (Continued)**




**Figure 5.5-22. Top View of Typical Indoor Breaker and Auxiliary Structures**

① Primary conduit locations for top or bottom entry.




**Figure 5.5-23. Base Plan of a Typical Indoor Breaker or Auxiliary Structure**

- ② Primary conduit locations for top or bottom entry.
- ③ Recommended minimum clearance to rear of VacClad-W: 30.00 inches (762.0 mm).
- ④ Floor steel, if used, must not exceed 3.25 inches (82.6 mm) under VacClad-W.
- ⑤ Anchor locations: indoor—0.50-inch (12.7 mm) bolts or weld, outdoor—0.50-inch (12.7 mm) bolts.
- ⑥ Station ground connection provision.
- ⑦ Secondary conduit space: All—maximum of 1.00-inch (25.4 mm) projection.
- ⑧ Minimum clearance to LH side of VacClad-W: 26.00 inches (660.4 mm).
- ⑨ Finished foundation surface shall be level within 0.06-inch (1.5 mm) in 36.00 inches (914.4 mm) left-to-right, front-to-back, and diagonally, as measured by a laser level.
- ⑩ Minimum clearance to front of VacClad-W: 70.00 inches (1778.0 mm).
- ⑪ Floor steel if used, must not exceed this dimension under VacClad-W.



**Figure 5.5-24. Primary Conduit Locations for Top or Bottom Entry**


⑫ Changes to 8.25 (209.6 mm) if optional hinged rear doors are required.



**Figure 5.5-25. Maximum Hinged Panel Equipment**


**Note:** The figure above shows that the arrangement of components differs between upper and lower panels. The figure may also be used to select custom arrangements of hinged panel components. Also, the use of multi-purpose solid-state relays such as Eaton's Digitrip 3000 (same size as 7) will significantly reduce consumption of panel space.

*Dimensions for estimating purposes only.*




**Figure 5.5-26. 5 kV, 1200A, 250 MVA VCP-W ND Low Profile 26.00-Inch (660.4 mm) Wide Indoor Unit, Blank/Breaker**

① Depth can be reduced to 72.00 inches (1828.8 mm) if power cables enter from top.




**Figure 5.5-27. 5 kV, 1200A, 250 MVA VCP-W ND Low Profile 26.00-Inch (660.4 mm) Wide Indoor Unit, Breaker/Blank**

② Depth can be reduced to 72.00 inches (1828.8 mm) if power cables enter from below.




**Figure 5.5-28. 5 kV, 1200A, 250 MVA VCP-W ND Low Profile 26.00-Inch (660.4 mm) Wide Indoor Unit, Auxiliary/Breaker**

③ Depth can be reduced to 72.00 inch (1831.7 mm) if power cables enter from top.



**Figure 5.5-29. Tie Breaker Bus Transition Requirements**



**Figure 5.5-30. Available Configurations (Front View)**

④ Relays or control devices cannot be mounted on the circuit breaker or auxiliary compartment door.

**Typical Weights**

**Table 5.5-5. Switchgear Assembly (Less Breaker)**


Vertical Section Type	Main Bus Rating, Amperes	Weight Lbs (kg)
B/A or A/B	1200 2000	1500 (682) 1700 (772)
A/A	1200 2000	1400 (636) 1600 (726)

**Table 5.5-6. Circuit Breaker ⑤**


Circuit Breaker Type	Current Rating, Amperes	Weight (Static) Lbs (kg)
50 VCPW-ND-250	1200	345 (157)

⑤ Breaker impact weight = 1.5 x static weight.


Layout Dimensions—Special Design—5/15 kV, Low Profile 36.00-Inch (9.14.4 mm) Wide (Standard Metal-Clad)



**Figure 5.5-31. 36.00-Inch (660.4 mm) Wide VCP-W Low Profile Indoor Unit**  
① Other depths possible depending on cable entry direction and VT/CPT connections. Contact Eaton.



**Figure 5.5-32. Tie Breaker Bus Transition Requirements**



**Figure 5.5-33. Available Configurations (Front View)**


**Typical Weights**

**Table 5.5-7. Assemblies (Less Breakers, See Table 5.5-2 for Breakers)**


Vertical Section Type	Main Bus Rating, Amperes	Indoor Structure Lbs (kg)
B/B	1200	2200 (999)
	2000	2300 (1044)
	3000	2400 (1090)
B/A or A/B	1200	2100 (953)
	2000	2200 (999)
	3000	2300 (1044)
A/A	1200	1800 (818)
	2000	1900 (864)
	3000	2000 (908)

**Layout Dimensions—27 kV One-High Design—Dimensions in Inches (mm)**


**Typical Units**



**Figure 5.5-34. Indoor 36.00-Inch (914.4 mm) Wide Typical Auxiliary/Breaker Vertical Section**




**Figure 5.5-36. Indoor Auxiliaries 36.00-Inch (914.4 mm) Wide Typical Auxiliary/Auxiliary Vertical Section**



**Figure 5.5-35. Outdoor Aisleless Typical Auxiliary/Breaker Vertical Section**

**Available Configurations**



**Figure 5.5-37. Available Configurations**

**Typical Weights in Lbs (kg)**

**Table 5.5-8. Assemblies (Less Breakers)**

Type of Vertical Section	Main Bus Rating Amperes	Indoor	Outdoor Aisleless
A/B	1200	2500 (1135)	3400 (1545)
	2000	2600 (1180)	3500 (1591)
A/A	1200	2200 (999)	2800 (1271)
	2000	2300 (1045)	2900 (1317)

**Table 5.5-9. Breaker Weights in Lbs (kg) ①**

Type of Breaker	Current Rating, Amperes	
	1200	2000
270 VCP-W 750	415 (188)	475 (216)
270 VCP-W 1000	415 (188)	475 (216)
270 VCP-W 1250, 25C	415 (188)	475 (216)
270 VCP-W 40, 40C	415 (188)	475 (216)


① Breaker impact = 1.5 x breaker weight.

*Dimensions for estimating purposes only.*




**Layout Dimensions—27 kV Two-High Design—  
Dimensions in Inches (mm)**

**Typical Units—Indoor ①**




**Figure 5.5-42. Indoor 36.00-Inch (914.4 mm) Wide Typical Breaker-over-Breaker Vertical Section**

① For 1-high arrangement (1 breaker per cell), depth may be reduced to 108.64 inches (2759.5 mm).



**Figure 5.5-43. 36.00-Inch (914.4 mm) Wide Typical Auxiliary-over-Breaker Vertical Section**


**Available Configurations ②**



**Figure 5.5-44. Available Configurations**

- ② Available Main Bus Ratings for 27 kV two-high design are 1200A, 2000A, 2500A or 2700A.
- ③ Bus connected, maximum 4A fuses. CPT is installed remote from the switchgear.
- ④ Fuses are bus or line connected. CPT is installed in front bottom, on drawout frame. Maximum CPT size is single-phase 37.5 kVA or three-phase 45 kVA.
- ⑤ Bus or Line connected, maximum 4A fuses. CPT is installed remote from the switchgear.

**Tie Breaker Bus Transition Requirements**



**Figure 5.5-45. Tie Breaker Bus Transition Requirements**

⑥ Breakers cannot be located in bus transition compartment.

**Typical Weights**

**Table 5.5-10. Assemblies (Less Breakers) ⑦**


Type of Vertical Section	Main Bus Rating, Amperes	Weight Lbs (kg)
Aux/Bkr	1200	2500 (1135)
	2000	2600 (1180)
	2500	2600 (1180)
	2700	2700 (1227)
Aux/Aux	1200	2200 (1000)
	2000	2300 (1046)
	2500	2300 (1046)
	2700	2400 (1091)
Bkr/Bkr	1200	2700 (1227)
	2000	2800 (1273)
	2500	2800 (1273)
	2700	2900 (1318)

⑦ Refer to Table 5.5-9 for breaker weights.

Typical Floor Plan—27 kV Two-High, Indoor

**Typical Floor Plan—27 kV Two-High, Indoor**

5



- ① Anchor locations for 0.50-inch (12.7 mm) bolts SAE Grade 5 or better, (6) places in each vertical section.
- ② Secondary control wiring conduit openings, conduit projection must not exceed 1.00 inch (25.4 mm).
- ③ Minimum front clearance when using Eaton's portable lifter.
- ④ Minimum left-hinged panel clearance.
- ⑤ Recommended minimum rear clearance.
- ⑥ Finished foundation surface shall be level within 0.06-inch (1.5 mm) in 36.00 inches (914.4 mm) left-to-right, front-to-back, and diagonally, as measured by a laser level.
- ⑦ 4.25 inches (108.0 mm) maximum dimension under the front of the switchgear must not be exceeded to avoid interference with secondary conduits.
- ⑧ Primary (H.V.) conduit projection must not exceed 2.00 inches (50.8 mm). See shop order base plan for conduit locations.
- ⑨ Customer's ground provisions, provided as shown by symbol on shop order sectional side views.
- ⑩ 5.00 inches (127.0 mm) minimum foundation supports for attaching switchgear.





Figure 5.5-46. Typical Floor Plan—27 kV Two-High, Indoor

*Dimensions for estimating purposes only.*


**Layout Dimensions—38 kV, 170 kV BIL Design—  
Dimensions in Inches (mm)**

**Typical Units**




**Figure 5.5-47. Indoor—Typical Breaker, Vertical Section, Bottom Cable Exit**

① Bus side CT bushings are not provided if there are no bus side CTs.



**Figure 5.5-48. Indoor—Typical Auxiliary/Auxiliary**



**Figure 5.5-49. Indoor—Typical Bus Tie Breaker, Vertical Section**

② Bus side CT bushings are not provided if there are no bus side CTs.

**Typical Weights in Lbs (kg)**

**Table 5.5-11. Assemblies (Less Breakers)**

Type of Vertical Section	Main Bus Rating Amperes	Indoor
Breaker	1200	3300 (1500)
	2000	3400 (1545)
	2500	3555 (1616)
	3000	3555 (1616)
Auxiliary	1200	3200 (1453)
	2000	3300 (1500)
	2500	3455 (1570)
	3000	3455 (1570)


**Table 5.5-12. Breaker Weights in Lbs (kg)**

Type of Breaker	Current Rating, Amperes	
	1200	2000
380 VCP-W-16, 16C	1080 (490)	1140 (518)
380 VCP-W-25, 25C	1080 (490)	1140 (518)
380 VCP-W-32, 32C	1080 (490)	1140 (518)
380 VCP-W-21	1080 (490)	1140 (518)
380 VCP-W-40, 40C	1080 (490)	1140 (518)
	1080 (490)	1140 (518)

**5**


*Dimensions for estimating purposes only.*

**Dimensions in Inches (mm) (Continued)**




**Figure 5.5-50. Top View of Typical Indoor Breaker and Auxiliary Structures**

① Primary conduit locations for top or bottom entry.




**Figure 5.5-52. Base Plan of a Typical Indoor Breaker and Auxiliary Structure**

- ② Primary conduit locations for top or bottom entry.
- ③ Recommended minimum clearance to rear of VacClad-W: 42.00 inches (1066.8 mm).
- ④ Floor steel, if used, must not exceed 3.25 inches (82.6 mm) under VacClad-W.
- ⑤ Anchor locations: indoor—0.50-inch (12.7 mm) bolts or weld, outdoor—0.50-inch (12.7 mm) bolts.
- ⑥ Station ground connection provision.
- ⑦ Secondary conduit space: All—maximum of 1.00-inch (25.4 mm) projection.
- ⑧ Minimum clearance to LH side of VacClad-W: 38.00 inches (965.2 mm).
- ⑨ Finished foundation surface shall be level within 0.06-inch (1.5 mm) in 36.00 inches (914.4 mm) left-to-right, front-to-back, and diagonally, as measured by a laser level.
- ⑩ Minimum clearance to front of VacClad-W: 84.00 inches (2133.6 mm).



**Figure 5.5-53. Primary Conduit Locations for Top or Bottom Entry**

- ⑪ Changes to 10.25 inches (260.4 mm) if optional hinged rear doors are required.
- ⑫ Changes to 13.25 inches (336.6 mm) if optional hinged rear doors are required.



**Figure 5.5-51. Maximum Hinged Panel Equipment**

**Note:** The figure above shows that the arrangement of components. The figure may also be used to select custom arrangements of hinged panel components. Also, the use of multi-purpose solid-state relays such as Eaton's Digitrip 3000 (same size as device 7) will significantly reduce consumption of panel space.

**Layout Dimensions—38 kV, 150 kV BIL Design—  
Dimensions in Inches (mm)**

**Typical Units**




Figure 5.5-54. Indoor—Typical Breaker, Main or Feeder




Figure 5.5-55. Typical Auxiliary-over-Auxiliary




Figure 5.5-56. Typical Bus Tie Breaker

**Typical Weights in Lbs (kg) ①**

Table 5.5-13. Assemblies (Less Breakers)


Type of Vertical Section	Main Bus Rating Amperes	Indoor
Breaker	1200	3100 (1409)
	2000	3200 (1455)
	2500	3355 (1525)
Auxiliary	1200	3000 (1364)
	2000	3100 (1409)
	2500	3355 (1525)

① Refer to Table 5.5-12 for breaker weights.

*Dimensions for estimating purposes only.*


**Layout Dimensions—38 kV, 150 kV BIL Design—Dimensions in Inches (mm)**

5



- ① Suggested locations for 0.500-13 bolts or welding.
- ② Secondary conduit location bottom entrance. Conduit projection must not exceed 1.00 inch (25.4 mm).
- ③ Recommended minimum clearance on all sides—follow local regulations.
- ④ Minimum left-hinged panel clearance.
- ⑤ Recommended minimum real clearance—follow local regulations.
- ⑥ Finished foundation surface shall be level within 0.06-inch (1.5 mm) in 36.00 inches (914.4 mm) left-to-right, front-to-back, and diagonally, as measured by a laser level.
- ⑦A Floor steel if used, must not exceed this dimension under switchgear.
- ⑦B Finished foundation (within 0.08-inch (2.0 mm) clearance) must extend under switchgear minimum 1.50 inches (38.1 mm) to maximum 3.00 inches (76.2 mm).
- ⑧ Primary (H.V.) conduit projection must not exceed 2.00 inches (50.8 mm). See shop order base plan for conduit locations.
- ⑨ Customer's ground provisions provided as shown by symbol on shop order sectional side views.
- ⑩ 4.00 inches (101.6 mm) minimum channel supplied by customer.

**Alternate Secondary Conduit Location Top Entrance**



Typical Application Layouts




Figure 5.5-58. Typical Arc-Resistant Switchgear Application Layouts—5 and 15 kV

Notes:

1. Maximum number of CTs: Two sets of standard or one set of high accuracy CTs can be installed on each side of the circuit breaker.
2. Bottom entry is standard for all power cables. In breaker over breaker arrangement, maximum number of cables is limited to **two per phase for each breaker.**
3. All lineups shown can be provided in mirrored configuration.
4. Refer to **Figure 5.5-61 to 5.5-66** for dimensions.

## Typical Arc-Resistant Switchgear Application Layouts—5 and 15 kV

## Typical Application Layouts





Figure 5.5-59. Typical Arc-Resistant Switchgear Application Layouts—5 and 15 kV

## Notes:

1. Maximum number of CTs: Two sets of standard or one set of high accuracy CTs can be installed on each side of the circuit breaker.
2. Bottom entry is standard for all power cables. In breaker over breaker arrangement, maximum number of cables is limited to **two per phase for each breaker**.
3. All lineups shown can be provided in mirrored configuration.
4. Refer to **Figure 5.5-61 to 5.5-66** for dimensions.

**Typical Application Layouts (Continued)**



**Figure 5.5-60. Typical Arc-Resistant Switchgear Application Layouts—5 and 15 kV**


**Notes:**

1. Maximum number of CTs: Two sets of standard or one set of high accuracy CTs can be installed on each side of the circuit breaker.
2. Bottom entry is standard for all power cables. In breaker over breaker arrangement, maximum number of cables is limited to **two per phase for each breaker.**
3. All lineups shown can be provided in mirrored configuration.
4. Refer to **Figure 5.5-61 to 5.5-66** for dimensions.

**Available Arc-Resistant Switchgear Configurations (Front Views)—5 and 15 kV**

**Available Configurations**

5




**Notes:**

- 1 = Please note that the only control space available for relays and LV devices for this configuration is the relay box located on the breaker compartment door.
- 2 = Maximum current through a 2000A breaker in this location must be limited to 1750A.
- 3 = This configuration requires use of a 4000A main bus.
- 4 = Maximum current through each 2000A breaker in this configuration must be limited to 1750A each.

**Figure 5.5-61. Available Arc-Resistant Switchgear Configurations (Front Views)—5 and 15 kV**

**Available Configurations**




**Figure 5.5-61. Available Arc-Resistant Switchgear Configurations (Front Views)—5 and 15 kV (Continued)**


Typical Arc-Resistant Switchgear (Side Views)—5 and 15 kV

Typical Sectional Side Views


5




1200A Breaker, Cables from Below



2000A Breaker, Cables from Below




3000A Breaker, Cables from Below



3000A Breaker, Bus Duct from Rear

Figure 5.5-62. Typical Arc-Resistant Switchgear (Side Views)—5 and 15 kV

**Typical Sectional Side Views (Continued)**




**Figure 5.5-63. Typical Arc-Resistant Switchgear (Side Views)—5 and 15 kV**

Typical Arc-Resistant Switchgear (Side Views)—5 and 15 kV

Typical Sectional Side Views (Continued)

5



**1200A Bkr over 1200A Bkr, Cables from Top**

- Arc Fault Venting
- Surge Arrester, Cable Boots, and BYZ shown are optional.




Figure 5.5-64. Typical Arc-Resistant Switchgear (Side Views)—5 and 15 kV

**5/15 kV Arc-Resistant Switchgear—Typical Weights**


**Table 5.5-14. Assemblies (Less Breakers) ①②③④**

Type of Vertical Section	Main Bus Rating	Indoor Structure 36.00-Inch (914.4 mm) W 97.50-Inch (2476.5 mm) D	Indoor Structure 36.00-Inch (914.4 mm) W 109.50-Inch (2781.3 mm) D	Indoor Structure 36.00-Inch (914.4 mm) W 121.50-Inch (3086.1 mm) D
	Amperes	Lbs (kg)	Lbs (kg)	Lbs (kg)
Breaker/breaker	1200	2800 (1271)	3025 (1374)	3175 (1441)
	2000	2900 (1317)	3175 (1441)	3375 (1532)
	3000	3000 (1362)	3275 (1487)	3475 (1578)
	4000	3100 (1407)	3375 (1532)	3575 (1623)
Blank/breaker or breaker/blank	1200	2700 (1226)	2900 (1317)	3125 (1419)
	2000	2800 (1271)	3125 (1419)	3175 (1441)
	3000	2900 (1317)	3150 (1430)	3325 (1510)
	4000	3000 (1362)	3275 (1487)	3475 (1578)
Auxiliary/breaker or breaker/auxiliary	1200	2650 (1203)	2850 (1294)	2975 (1351)
	2000	2750 (1248)	2975 (1351)	3225 (1464)
	3000	2850 (1294)	3100 (1407)	3275 (1487)
	4000	2950 (1339)	3225 (1464)	3450 (1566)
Auxiliary/auxiliary	1200	2600 (1180)	2800 (1271)	2925 (1328)
	2000	2700 (1226)	2925 (1328)	3175 (1441)
	3000	2800 (1271)	3050 (1385)	3225 (1464)
	4000	2900 (1317)	3175 (1441)	3375 (1532)
Blank/auxiliary or auxiliary/blank	1200	2500 (1135)	2700 (1226)	2825 (1283)
	2000	2600 (1180)	2825 (1283)	2975 (1351)
	3000	2700 (1226)	2950 (1339)	3125 (1419)
	4000	2800 (1271)	3075 (1396)	3275 (1487)
Blank/blank	1200	2500 (1135)	2700 (1226)	2825 (1283)
	2000	2600 (1180)	2825 (1283)	2975 (1351)
	3000	2700 (1226)	2950 (1339)	3125 (1419)
	4000	2800 (1271)	3075 (1396)	3275 (1487)

- ① Refer to **Table 5.5-2** for breaker weights.
- ② Add weights of end-wall to left and right end structures as follows:  
350 Lbs (159.1 kg) for 97.50-inch (2476.5) D structures.  
390 Lbs (177.3 kg) for 109.50-inch (2781.3) D structures.  
430 Lbs (195.4 kg) for 121.50-inch (3086.1) D structures.
- ③ Add plenum weight as follows:  
300 Lbs (136.4 kg) to left and right end structures.  
200 Lbs (91.0 kg) to each intermediate structures.
- ④ Add arc duct assembly weight as follows:  
200.00 Lbs (91.0 kg) for standard 51.00-inch (1295.4 mm) arc exhaust duct assembly.  
30.00 Lbs (14.0 kg) per foot for additional arc duct.

**Typical Arc-Resistant Switchgear (Side Views)—5 and 15 kV**

**Typical Top Plan**




5

**Figure 5.5-65. Typical Arc-Resistant Switchgear, Top Entry Cables—Typical Conduit Entrance Locations—5 and 15 kV**

**Note:** For switchgear with enclosure arc ratings of up to 41 kA rms symmetrical, minimum two vertical sections and one arc duct exit are required.  
For switchgear with enclosure arc ratings of 50 kA rms symmetrical or higher, minimum three vertical sections and two arc duct exits are required.

**Typical Arc-Resistant Switchgear Floor Plan—5 and 15 kV**

**Typical Floor Plan**



**Figure 5.5-66. Typical Arc-Resistant Switchgear Floor Plan—5 and 15 kV**

## Typical Arc-Resistant Switchgear Application Layouts—27 kV

### Typical Application Layouts





Figure 5.5-67. Typical Arc-Resistant Switchgear Application Layouts—27 kV

#### Notes:

1. Maximum number of CTs: Two sets of standard or one set of high accuracy CTs can be installed on each side of the circuit breaker.
2. Bottom entry is standard for all power cables, maximum four per phase.
3. Refer to **Figure 5.5-68 to 5.5-70** for dimensions.
4. 27 kV arc-resistant switchgear can be supplied in one-high design configuration only.

**Available Configurations (Continued)**



**5**

**Figure 5.5-68. Available Arc-Resistant Switchgear Configurations (Front Views)—27 kV**

① Please note that an additional 48.00-inch (1219.2 mm) clearance is required above the arc wall for arc exhaust.

**Typical Weights in Lbs (kg) ②**

**Table 5.5-15. Assemblies (Less Breakers)**

Type of Vertical Section	Main Bus Rating Amperes	Indoor Structure
Control/breaker	1200	2700 (1226)
	2000	2800 (1271)
Control/auxiliary	1200	2400 (1090)
	2000	2500 (1135)

② Refer to **Table 5.5-9** for breaker weights.

Typical Arc-Resistant Switchgear Sectional (Side Views)—27 kV

Typical Sectional Side Views—Dimensions in Inches (mm)

5





Figure 5.5-69. Typical Arc-Resistant Switchgear Sectional (Side Views)—27 kV

**Typical Arc-Resistant Switchgear Floor Plan—27 kV**

**Typical Floor Plan—Dimensions in Inches (mm)**



**Figure 5.5-70. Typical Arc-Resistant Switchgear Floor Plan—27 kV**

Typical Arc-Resistant Switchgear Application Layouts—38 kV

Typical Application Layouts

5





Figure 5.5-71. Typical Arc-Resistant Switchgear Application Layouts—38 kV

**Available Configurations**



**5**

**Figure 5.5-72. Available Arc-Resistant Switchgear Application Layouts (Front Views)—38 kV**

① Please note that an additional 48.00-inch (1219.2 mm) clearance is required above the arc wall for arc exhaust.

**Typical Weights in Lbs (kg) ②**

**Table 5.5-16. Assemblies (Less Breakers)**


Type of Vertical Section	Main Bus Rating Amperes	Indoor Structure
Breaker cell	1200	3500 (1589)
	2000	3700 (1680)
	2500	4000 (1816)
	3000	4000 (1816)
Auxiliary cell	1200	3000 (1362)
	2000	3200 (1453)
	2500	3500 (1589)
	3000	3500 (1589)

② Refer to **Table 5.5-12** for breaker weights.

**Typical Arc-Resistant Switchgear Sectional (Side Views)—38 kV**

**Typical Sectional—Dimensions in Inches (mm)**


5



**Figure 5.5-73. Typical Arc-Resistant Switchgear Sectional (Side Views)—38 kV**

**Typical Arc-Resistant Switchgear Floor Plan—38 kV**

**Typical Floor Plan—Dimensions in Inches (mm)**



**Figure 5.5-74. Typical Arc-Resistant Switchgear Floor Plan—38 kV**

## Typical Arc-Resistant Switchgear—Arc Exhaust Wall and Plenum

### Arc Exhaust Wall—for 27 and 38 kV Switchgear




Figure 5.5-75. Arc Exhaust Wall Above the Switchgear

### Arc Exhaust Chamber (Plenum) with Arc Duct Exit—for 5 and 15 kV Switchgear




Figure 5.5-76. Arc Exhaust Chamber (Plenum) with Arc Duct Exit Above the Switchgear

Arc Exhaust wall **Figure 5.5-75** is supplied as standard for all 27/38 kV arc-resistant switchgear. The arc exhaust wall must be field installed above the switchgear. Note minimum 48.00-inch (1219.2 mm) ceiling clearance is required above the arc exhaust wall for proper venting of the arc exhaust. All 5/15 kV arc-resistant switchgear is provided with arc exhaust chamber (plenum). It is also installed in the field. When using arc exhaust chamber, minimum ceiling clearance required above the arc exhaust chamber (plenum) is equal to that needed for field installation of the chamber. Eaton recommends minimum 18.00-inch (457.2 mm). Refer to **Figures 5.5-77** and **5.5-78** for typical arc exhaust chamber (plenum) and arc duct exit arrangements for arc-resistant switchgear installed inside an electrical room and inside an outdoor house.


**Note:** APPLICABLE TO ALL ARC-RESISTANT SWITCHGEAR:

For switchgear with enclosure arc ratings of up to 41 kA rms symmetrical, minimum two vertical sections and one arc duct exit is required.

For switchgear with enclosure arc rating of 50 kA rms symmetrical or higher, minimum three vertical sections and two arc duct exits are required.

**Typical Arc-Resistant Switchgear—Exhaust Layout**


**Typical Layout—Dimensions in Inches (mm)**



**Figure 5.5-77. Typical Layout of 5/15 kV Arc-Resistant Switchgear Inside Electrical Room and Outside Minimum Exhaust Area**

**Typical Arc-Resistant Switchgear—Exhaust Layout**

**Typical Layout (Continued)**




**Arc Exhaust Caution!**

When equipment is energized and operating, all personnel stay clear of fenced area below the arc exhaust release point.

De-energize the equipment prior to entering the fenced area prior to opening any switchgear rear doors.

**Simplified Top View**  
(not to scale)

Seismic Applications = 6.00 (152.4)  
Non-Seismic Applications can be Less than 6.00 (152.4) or as Required by the House Design




**Simplified Side View**  
(not to scale)

For the layout shown, doors on the house wall (not shown) provide access to rear of the switchgear. For rear access to switchgear from within the house, minimum 36.00 (914.4) clearance is required behind the switchgear.

5

**Figure 5.5-78. Typical Layout of 5/15 kV Arc-Resistant Switchgear Inside an Outdoor House (Electrocenter)**

# SEL-787 Transformer Protection Relay




SEL Synchrophasors

## SEL Advances the State of the Art in Transformer Protection

- **Synchrophasors** detect system oscillations and potential instability.
- **MIRRORED BITS® communications** is ideal for teleprotection and remote control applications.
- **Flexible communications** make control integration fast and easy.
- **Small form factor** speeds new installations and retrofits of electromechanical relays.
- **Commissioning Assistant** is the first transformer relaying software that recommends correction settings after identifying errors.

### Optimize the Life of Your Transformers by Monitoring Key Health Indicators




*Cumulative Through-Fault Current Recording  
Measurement and Logic Input*

### Flexible Communications


*Single or Dual  
Copper or Fiber  
Ethernet Port*

*Three or Four\*  
Serial Ports*



\*Optional

### Use Commissioning Assistant to Easily Generate Differential Compensation Settings




### Industry-Leading Quality, Reliability, and Customer Service



**Making Electric Power Safer, More Reliable, and More Economical®**

## Functional Overview



## Feature Overview

Power supply options include:


24–48 Vdc  
110–250 Vdc  
110–230 Vac

Modbus TCP, Telnet, and FTP, with optional IEC 61850 and DNP3 LAN/WAN.

Single or dual copper or fiber Ethernet port.

Positions for optional expansion cards.

Two-winding CT inputs.



## Ordering Options

- CPU Board
  - Single or dual copper or fiber Ethernet port
  - EIA-232 or EIA-485 rear port
  - IRIG-B input
- Optional Expansion Cards
  - 3 digital inputs/4 digital outputs/4–20 mA analog output
  - 4 digital inputs/4 digital outputs (electromechanical)
  - 4 digital inputs/4 digital outputs (fast, high-current interrupting)
  - 4 analog inputs/4 analog outputs
  - EIA-232 or EIA-485 serial communication
  - EIA-485 DeviceNet communication
  - 8 digital inputs
  - 10 RTD inputs
  - Neutral ac current input
  - Neutral ac current input/three-phase ac voltage (300 Vac) input
- Conformal Coating



Pullman, Washington USA  
Tel: +1.509.332.1890 • Fax: +1.509.332.7990 • www.selinc.com • info@selinc.com


© 2007, 2008 by Schweitzer Engineering Laboratories, Inc. PF00167 • 20080616



# SEL-751 Feeder Protection Relay



Choose the SEL-751 for feeder overcurrent protection with optional directional overcurrent, arc-flash detection, and Arc Sense™ technology.




SEL IEC 61850 SEL Synchrophasors®


## Detect High-Impedance Faults With Arc Sense Technology



## High-Speed Arc-Flash Detection Improves Safety



## Substation-Hardened Ethernet




## Industry-Leading Quality, Reliability, and Service



Making Electric Power Safer, More Reliable, and More Economical®

# Functional Overview



# Ordering Options

- Single or dual, copper or fiber-optic Ethernet port(s)
- Modbus® TCP, DNP3 serial and DNP3 LAN/WAN, FTP, and Telnet protocols
- IEC 61850
- DeviceNet™
- EIA-232 or EIA-485 communications
- Additional EIA-232 or EIA-485 port
- Analog I/O (4 AI/4 AO, 8 AI)
- Digital I/O (4 DI/4 DO, 4 DI/3 DO (2 Form C and 1 Form B), 8 DI, 8 DO, 3 DI/4 DO/1 AO)
- Vsync and Vbat input card with four arc-flash detection inputs
- 10 RTDs
- Conformal coating for chemically harsh and high-moisture environments
- Multishot reclosing
- Arc Sense technology (AST) for high-impedance fault (HIF) detection
- Directional overcurrent

# Feature Overview

*Available high-impedance fault detection with Arc Sense™ technology (AST)*

*Available with islanding detection (81RF element)*

*Large 2 x 16 character liquid crystal display.*

*Use default messages, or program up to 32 custom display labels.*

*Use default pushbuttons, or program your own pushbutton actions and labels.*

*Front-panel LEDs can be programmed to indicate custom alarms.*

*Optional multishot reclosing.*

*User-configurable labels.*

*Power supply options include: 110–250 Vdc, 110–230 Vac, 24–48 Vdc.*

*Optional copper or fiber-optic Ethernet port(s), Modbus® TCP, DNP3, or IEC 61850.*

*Fiber-optic serial port.*


*Positions for optional I/O or arc-flash detection/Vsync/Vbat card.*

*Phase current and phase voltage inputs on one card.*

# Reduce Arc-Flash Hazards

## Combined light-sensing technology with fast overcurrent protection provides high-speed arc-flash detection without false tripping.

In addition to arc-flash detection, the SEL-751 provides several other methods to limit personnel exposure to arc-flash hazards. Reduce the danger of explosive arc-flash incidents by reducing the available fault current energy or removing personnel from the danger zone. Coordinate protection for faster clearing times, and stay outside the danger zone completely with wireless or remote communications.



Arc-Flash Overcurrent

Fault Current

Arc Flash

Line


Arc-Flash Light Sensors (up to four)

Easily mounted point sensors detect light from the arc flash in confined areas.

Bare-fiber sensors detect light from the arc flash over the entire length of the fiber loop. This type of sensor is used for large areas, such as busbars.

## Coordinate Protection

Use SEL MIRRORED BITS® communications to coordinate upstream protection if a fault occurs. Coordination and fast-bus trip schemes allow short delays (two or three cycles) for backup protection, reducing arc-flash energy.



## Stay Outside the Danger Zone

Use Ethernet or serial communications to remotely obtain metering, event, and maintenance information from the relay. Optional delayed breaker tripping or closing via pushbuttons allows personnel to move to a safe distance.


# Flexible Communications

## Communications Media

- Ethernet 10/100BASE-T
- Ethernet 100BASE-FX
- Single or dual Ethernet ports
- EIA-232 serial
- EIA-485 serial
- Fiber-optic, serial multimode ST®

## Communications Protocols

- MIRRORED BITS communications
- IEC 61850
- Modbus RTU/TCP
- DNP3 serial, LAN/WAN
- DeviceNet
- Telnet
- FTP
- Synchrophasors (IEEE C37.118)
- SNTP (Simple Network Time Protocol)



Central control room.



Field remote terminal.



Engineering access.

# SEL-751 Feeder Protection Relay

## Easy to Set and Use


Use **acSELERATOR QuickSet® SEL-5030 Software to set, monitor, and control the SEL-751.**

- Save engineering time while keeping flexibility. Communicate with the SEL-751 through any ASCII terminal, or use the acSELERATOR QuickSet graphical user interface.
- Develop settings offline with a menu-driven interface and completely documented help screens. Speed installation by copying existing settings files and modifying application-specific items.
- Simplify the setting procedure with rules-based architecture to automatically check interrelated settings. Out-of-range or conflicting settings are highlighted for correction.



Use **acSELERATOR Software to retrieve and display event reports recorded by the SEL-751.**


- Display event report oscillograms. View each report as a plot of magnitude versus time. Select analog and digital points to build a custom display. Analyze arc-flash events using light intensity and phase current waveforms recorded during the arc fault.
- Display phase and symmetrical component phasors. Display the phasor view of electrical data to better understand asymmetrical three-phase faults. Build a custom plot using per-phase and symmetrical component sequence currents and voltages.
- Retrieve event reports using serial or Ethernet communications links.



## High-Impedance Fault Detection

High-impedance faults and downed conductors on poorly conductive surfaces cause fault current levels too low to be detected by conventional overcurrent protection elements. The SEL-751 with Arc Sense technology (AST) detects many high-impedance faults while maintaining secure protection.

- The SEL-751 with AST is easy to understand, set, and test. SEL offers straightforward protection algorithms with two sensitivity levels and a test mode.
- Never lose an AST event report with an event collection system that automatically transfers event reports to long-term storage. Selectable event report length of 2 to 20 minutes provides the level of detail needed to evaluate downed conductors and high-impedance events.
- Advancements in technology and innovation now make it possible to securely detect many high-impedance faults. However, it is important to educate the public of the dangers associated with downed power lines.



*High-impedance fault detection algorithm.*



Pullman, Washington USA  
Tel: +1.509.332.1890 • Fax: +1.509.332.7990 • www.selinc.com • info@selinc.com

© 2007-2011 by Schweitzer Engineering Laboratories, Inc. PF00254 • 20110330



# SEL-587Z



## High-Impedance Differential Relay

# Bus or Transformer High-Impedance Differential Relay



*Apply the SEL-587Z Relay for single-zone bus protection, reactor protection, or sensitive restricted earth fault protection on grounded, wye-connected power transformer windings.*

## Features and Benefits

### Protection

Use high-impedance differential elements for fast tripping for in-zone faults, while providing security during heavy through faults and CT saturation. Reduce panel design cost and space requirements by using a single relay that includes three-phase protection, resistors, and metal oxide varistors (MOVs).

### Control

Use front-panel pushbuttons to save the expense of separately mounted control switches. Serial port communication provides for remote control of circuit breakers or other user-defined functions.

### Reporting, Monitoring, and Metering


Simplify fault analysis with event reports and Sequential Events Recorder (SER). Validate CT connections using the metered voltage differential quantities.

### Communications

Integrate the relay with SCADA, local HMI, or modems using Modbus®, SEL ASCII, and SEL Fast Messaging protocols through the rear-panel isolated communications port. Use the front-panel communications port for relay settings and event report retrieval.

***Making Electric Power Safer, More Reliable, and More Economical®***

# Functional Overview



## Differential Protection

The SEL-587Z Relay has three independent high-impedance elements, each with two setting levels, with all differential elements set in volts. As shown below, the faulted-circuit CT can saturate during through faults. High-impedance differential protection offers immunity against relay misoperation resulting from CT saturation, provided that the stabilizing resistor is of sufficiently high value. To comply with this requirement, the SEL-587Z Relay uses 2000-ohm resistors, large enough to provide security against CT saturation for through faults.


During bus faults, the voltage across the resistor can rise to unacceptably high values if not limited. MOVs in parallel with each high-impedance element clamp the secondary peak voltage to less than 2 kV.

For best performance, select current transformers with fully distributed windings and identical ratios.


For other SEL-587Z applications that involve mismatched current transformers, contact SEL.

Use the second level of the high-impedance element as a CT open-circuit alarm by configuring the setting with a low value.


Install the SEL-587Z Relay on transformers with grounded-wye windings for sensitive restricted earth fault protection. The combination of restricted earth fault protection and overcurrent elements will protect smaller transformers where differential protection is not economical.



Voltage without MOV.



MOV-clamped voltage.



## Overcurrent Protection

Overcurrent elements include a maximum-phase measurement, phase-specific elements, and negative-sequence and residual overcurrent elements. Use the independent overcurrent elements for protecting other equipment.


Apply the SEL-587Z overcurrent elements for transformer protection. These elements provide instantaneous overcurrent protection for bushing faults and time-overcurrent protection for coordination with other system protection.

## Sequential Events Recorder

Use the time- and date-tagged sequential events messages recorded by the SEL-587Z Relay to analyze the time relationships between assertion and deassertion of logical elements within the relay.

## Event Reports

Analyze faults from the event reports, which include 15 cycles of all the analog values measured in the relay as well as most of the digital information. Use ACSELEATOR Analytic Assistant® SEL-5601 Software for a graphical representation of the data.



The first trace is a high-impedance voltage—87A with maximum value about 1600 V. The second trace is a low-impedance current—IA, which represents the total current through the resistor and MOV.

### Metering Functions

Voltage 87A, 87B, 87C	Voltages from each differential element
Current IA, IB, IC, IG, 3I2	Separate phase, negative-sequence, and residual currents
Demand current IA, IB, IC, IG, 3I2	Separate phase, negative-sequence, and residual currents


## SELogic® Control Equations

SELogic control equations put relay logic in the hands of the protection engineer. Assign relay inputs to suit the application. Logically combine selected relay elements for various control functions, and assign outputs to logic functions. Eliminate traditional panel control switches with eight local control switches and RTU-to-relay wiring with eight remote control switches. Replace traditional indicating panel lights with eight programmable displays.

## Applications

### High-Impedance Bus Protection

Use the high-impedance elements 87A1, 87B1, and 87C1 for instantaneous high-impedance bus protection. Set the second level of the high-impedance elements—87A2, 87B2, and 87C2—to lower values to detect CT open-circuit conditions.



87Z – High-Impedance Differential Element

50 – Overcurrent Element

R – 2000 Ω Stabilizing Resistor

86 – Lockout Relay (not included)

MOV – Metal Oxide Varistor

### Breaker Failure/Bus Fault Cleared Detection

Apply the 50/51 overcurrent elements in series with the high-impedance elements to detect breaker failure conditions. Following a bus fault, the lockout relay (86) contacts short out the high-impedance elements, and the entire fault current then flows through the 50/51 elements. Delay operation of the 50 element for a suitable period to give all circuit breakers time to open. An element still picked up after the time delay indicates that one or more circuit breakers have failed to open. Use the 50 elements to send a direct transfer trip command to all adjacent substations to clear the fault, or use these elements to supervise SCADA attempts to re-energize the bus.

# SEL-587Z High-Impedance Differential Relay

## General Specifications

### High-Impedance (87A, 87B, 87C)

150 V continuous, linear to 3000 V symmetrical

Burden 2000  $\Omega$  stabilizing resistor

Range 20–800 V

#### MOV clamping voltage

One or two MOV option 2000 V (8 x 20  $\mu$ s)

Four MOV option 1500 V (8 x 20  $\mu$ s)

#### MOV maximum transient energy rating

One MOV—2500 J, two MOV—5000 J, four MOV—8400 J

#### MOV maximum continuous ac voltage rating

One or two MOV option 750 V

Four MOV option 600 V

### AC Current Inputs (IA, IB, IC)

#### 5 A nominal

15 A continuous, 500 A for 1 second, linear to 100 A symmetrical, 625 A for 1 cycle (sinusoidal waveform)

Burden <0.16 VA @ 5 A; <1.15 VA @ 15 A

Range 0.5–80 A

#### 1 A nominal

3 A continuous, 100 A for 1 second, linear to 20 A symmetrical, 250 A for 1 cycle (sinusoidal waveform)

Burden <0.06 VA @ 1 A; <0.18 VA @ 3 A

Range 0.1–16 A

### Frequency and Phase Rotation

60/50 Hz system frequency and ABC/ACB rotation

### Output Contacts (4 plus 1 alarm)

6 A continuous carry, 30 A make per IEEE C37.90: 1989, 100 A for 1 second, 270 Vac/360 Vdc MOV for differential surge protection, pickup/dropout time: <5 ms

Breaking capacity (L/R = 40 ms, 10,000 operations): 0.75 A @ 24 V; 0.5 A @ 48 V; 0.3 A @ 125 V; 0.2 A @ 250 V

Cyclic capacity (L/R = 40 ms, 2.5 cycles per second): 0.75 A @ 24 V; 0.5 A @ 48 V; 0.3 A @ 125 V; 0.2 A @ 250 V

### Optoisolated Input Ratings (2 total)

Any of the following nominal voltages: 24, 48, 125, 250 Vdc

### Power Supply Ratings

24 V (polarity sensitive) 16–36 Vdc

48/125 V 36–200 Vdc or 85–140 Vac

125/250 V 85–350 Vdc or 85–264 Vac

5.5 W maximum

### Serial Communications

One front-panel EIA-232 serial port, one isolated rear-panel EIA-232 or EIA-485 serial port (specify when ordering), data rate: 300, 1200, 2400, 4800, 9600, 19200, and 38400 bps

### Time-Code Input

Demodulated IRIG-B accepted at rear-panel serial port

### Operating Temperature

–40° to +85°C (–40° to +185°F)

### Mounting Options

Horizontal rack-mount and horizontal panel-mount versions available

### Production Dielectric Strength Tests

High-impedance and ac current inputs: 2500 Vac for 10 seconds

Power supply, optoisolated inputs, and output contacts: 3100 Vdc for 10 seconds



Cutaway view showing stabilizing resistors and MOVs.



Pullman, Washington USA  
Tel: +1.509.332.1890 • Fax: +1.509.332.7990 • www.selinc.com • info@selinc.com

© 2001–2010 by Schweitzer Engineering Laboratories, Inc. PF00012 • 20101004





**ELECTROSWITCH**  
SWITCHES & RELAYS

[Home](#) | [Glossary](#)

(781) 335-5200  
[info@electroswitch.com](mailto:info@electroswitch.com)

[Overview](#) | [Products: Utility](#) | [Industrial](#) | [Military](#) | [Catalogs](#) | [Order Status](#) | [Sales Reps](#) | [News](#) | [Employment](#) | [Search](#) |

## SERIES 24 INSTRUMENT AND CONTROL SWITCHES

### Features

- Double-Sided, Double-Wiping, Knife-Type Rotary Contacts
- Silver Contact Surfaces for Long, Reliable Life
- Terminal Screws – Easy Installation
- Four Hole Mount



### Control Switch Special Features

- Spring Return to Normal (Vertical) Position

[Ordering Information](#)  
[Switch Diagram](#)

### Instrument Switch Special Features

- Make-Before-Break (Shorting Contacts)
- Common Input Tap Switch Arrangement — Sequentially Connected to Several Lines Using the Same Switching Deck
- Positive Positioning, Maintained Action Detent Mechanism

### Electrical Specifications

#### Interrupt Ratings

- 15A/120VAC
- 4A/600VAC
- 7.5A/240VAC
- Overload Current (50 operations): 30A/125VAC Resistive
- Voltage Breakdown: 1200V rms minimum
- Insulation Resistance: 100 Megohms minimum
- Contacts Resistance: 10 milliohms maximum

### Mechanical Specifications

Sections	1 to 30
Poles	1 to 60
Positions	8; Adjustable Stops for 2–8 Position Rotation
Contacts	Break-Before-Make (Non-Shorting); Make-Before-Break (Shorting)
Action	45° Positive Detent Indexing
Mounting	4-Hole
Panel Thickness	3/16" Max. Standard
Rotor Contacts	Silver Plated Phosphor-bronze, Double Grip
Stationary Contacts	Silver Plated Copper, w/Integral Screw Type Terminals
Construction	Contacts Enclosed in Molded-phenolic Disks

### Approvals

- UL File No. E18174
- CSA File #LR20743


### Variations

For Key Lock Handle, Key Operated Handle, Solenoid Lock Handle, Push-to-Turn, Spring Return or Waterproof Mount Switches please see page 18.



- UL and cUL Approved (File #E247592)
- As per ANSI/IEEE C57.13, IEC, OR relevant standard

TABLES (Specify Catalog # and Group with the RFQ)



**INSULATION LEVEL**  
 15.5 kV, BIL 110 kV full wave

**FREQUENCY**  
 60 Hz (50 Hz upon request)

**ACCURACY CLASS**  
 0.3WXYMZ, 1.2ZZ @ 100% rated V, 120V based ANSI burden  
 0.3WXYMZ, 1.2ZZ @ 58% rated V, 69.3V based ANSI burden

**THERMAL RATING**  
 1500 VA @ 30 deg. C ambient  
 1000 VA @ 55 deg. C ambient

**OUTER ENCAPSULATION**  
 Resin Encapsulated

**PRIMARY TERMINALS**  
 1/4"-20 Brass screw with one flat washer and lock washer

**SECONDARY TERMINALS**  
 M5X0.8 Female Insert, with brass slotted pan head screw, two plain washers and one lock washer

**APPROX. WEIGHT**  
 90 lbs.

**PLATED STEEL MOUNTING BASE**

**CUSTOM OPTIONS (CONTACT US)**

- Different Ratios, Accuracies
- Non-standard thermal rating
- Different encapsulation
- Different secondary termination
- Special mounting needs etc.


<b>TWO BUSHING</b>						
CATALOG # WITH FUSES	CATALOG # WITHOUT FUSES	CATALOG # WITH FUSES AND GROUNDING CLIPS	GROUP	PRIMARY VOLTAGE	RATIO	SECONDARY VOLTAGE
V21.1-2-242FF	*V21.1-2-242NF	V21.1-242FFG2	1	2400	20:1	120
V21.1-2-422FF	*V21.1-2-422NF	V21.1-422FFG2	1	4200	35:1	120
V21.1-2-482FF	*V21.1-2-482NF	V21.1-482FFG2	1	4800	40:1	120
V21.1-2-662FF	*V21.1-2-662NF	V21.1-662FFG2	1	6600	60:1	110-50Hz
V21.1-2-722FF	*V21.1-2-722NF	V21.1-722FFG2	1	7200	60:1	120
V21.1-2-842FF	*V21.1-2-842NF	V21.1-842FFG2	1	8400	70:1	120
V21.1-2-113FF	*V21.1-2-113NF	V21.1-113FFG2	2	11000	100:1	110-50Hz
V21.1-2-123FF	*V21.1-2-123NF	V21.1-123FFG2	2	12000	100:1	120
V21.1-2-12471FF	*V21.1-2-12471NF	V21.1-12471FFG2	2	12470	104:1	120
V21.1-2-1322FF	*V21.1-2-1322NF	V21.1-1322FFG2	2	13200	110:1	120
V21.1-2-1382FF	*V21.1-2-1382NF	V21.1-1382FFG2	2	13800	115:1	120
V21.1-2-1442FF	*V21.1-2-1442NF	V21.1-1442FFG2	2	14400	120:1	120

<b>SINGLE BUSHING</b>						
CATALOG # WITH FUSE	CATALOG # WITHOUT FUSES	CATALOG # WITH FUSES AND GROUNDING CLIPS	GROUP	PRIMARY VOLTAGE	RATIO	SECONDARY VOLTAGE
V21.1-242F	*V21.1-242NF	V21.1-242FG1	4A	2400	20:1	120
V21.1-422F	*V21.1-422NF	V21.1-422FG1	4A	4200	35:1	120
V21.1-482F	*V21.1-482NF	V21.1-482FG1	4A	4800	40:1	120
V21.1-722F	*V21.1-722NF	V21.1-722FG1	4A	7200	60:1	120
V21.1-7621F	*V21.1-7621NF	V21.1-7621FG1	4A	7620	63.5:1	120
V21.1-7971F	*V21.1-7971NF	V21.1-7971FG1	4A	7970	66.4:1	120
V21.1-842F	*V21.1-842NF	V21.1-842FG1	4A	8400	70:1	120
V21.1-113F	*V21.1-113NF	V21.1-113FG1	4B	11000	100:1	110-50Hz
V21.1-123F	*V21.1-123NF	V21.1-123FG1	4B	12000	100:1	120
V21.1-12471F	*V21.1-12471NF	V21.1-12471FG1	4B	12470	104:1	120
V21.1-1322F	*V21.1-1322NF	V21.1-1322FG1	4B	13200	110:1	120
V21.1-1382F	*V21.1-1382NF	V21.1-1382FG1	4B	13800	115:1	120
V21.1-1442F	*V21.1-1442NF	V21.1-1442FG1	4B	14400	120:1	120

**\*Contact Amran for the unfused version drawing**

**DIMENSIONS: Dimensions are in mm [inches]**


**TWO BUSHING, TWO FUSE**



- \*Units with optional grounding clips (G2) as shown have the additional label with the corresponding G2 part number listed
- Standard Fuse:
  - 15.5kV, 1.0E fuse for primary voltages below 10kV
  - 15.5kV, 0.5E fuse for primary voltages above 10Kv
- Fuse clips accept 1.63” diameter fuses with Max. length of 12.87”
- Fuses are intended to protect the system and not the PT in the event of a failure

**DIMENSIONS: Dimensions are in mm [inches]**


**SINGLE BUSHING, ONE FUSE**



- \*Units with optional grounding clips (G1) as shown have the additional label with the corresponding G1 part number listed.
- Standard Fuse:
  - 15.5kV, 1.0E fuse for primary voltages below 10kV
  - 15.5kV, 0.5E fuse for primary voltages above 10kV
- Fuse clips accept 1.63” diameter fuses with Max. length of 12.87”
- Fuses are intended to protect the system and not the PT in the event of a failure







**CITY OF CRETE**  
**Doane Substation Transformer**

**Proposal #: M232405A | 26 June 2023**

**Customer Contact Information**

Doane Substation Transformer  
CITY OF CRETE  
C/O TOM OURADA  
1111 LINCOLN MALL  
LINCOLN, NE 68333-0086  
402-474-5160

**VTC Contact Information**

PPU CENTRAL  
540-682-6618  
chad\_kraml@vatransformer.com

220 Glade View Drive, NE Roanoke, 24012  
Phone:540-345-9892 Fax:540-342-7694  
www.vatransformer.com




**SECTION 00430**

**BID BOND (PENAL SUM FORM)**

<p><b>Bidder</b>  <b>Name:</b> Virginia Transformer Corp  <b>Address (principal place of business):</b>                  220 Glade View Dr. NE                  Roanoke, VA 24012-6470</p>	<p><b>Surety</b>  <b>Name:</b> Travelers Casualty and Surety Company of America  <b>Address (principal place of business):</b>                  One Tower Square                  Hartford, CT 06183</p>
<p><b>Owner</b>  <b>Name:</b> City of Crete  <b>Address (principal place of business):</b>                  601 P Street, Suite 200                  Lincoln, NE 65808</p>	<p><b>Bid</b>  <b>Project (name and location):</b>                  Doane Substation Transformer Installed on the Doane University Campus, Crete, Nebraska - 34.5kV/13.8kV-Y77970V, 10/12.5/14 ONAN/ONAF @55 degrees C, 11.2/14/15.8 ONAN/ONAF/ONAF @ 65 degrees C, Z,7-5%. Quote #M232405A   <b>Bid Due Date:</b> June 29, 2023</p>

**Bond**  
**Penal Sum:** 5.00% Five Percent of Amount Bid  
**Date of Bond:** June 29, 2023

Surety and Bidder, intending to be legally bound hereby, subject to the terms set forth in this Bid Bond, do each cause this Bid Bond to be duly executed by an authorized officer, agent, or representative.

<p><b>Bidder</b>                  Virginia Transformer Corp  <i>(Full formal name of Bidder)</i></p>	<p><b>Surety</b>                  Travelers Casualty and Surety Company of America  <i>(Full formal name of Surety) (Corporate Seal)</i></p>
<p><b>By:</b>   <i>(Signature)</i></p>	<p><b>By:</b>   <i>(Signature) (Attach Power of Attorney)</i></p>
<p><b>Name:</b> Jim Qian  <i>(Printed or typed)</i></p>	<p><b>Name:</b> Elizabeth A. Dyer  <i>(Printed or typed)</i></p>
<p><b>Title:</b> Director of Treasury</p>	<p><b>Title:</b> Attorney-in-Fact</p>
<p><b>Attest:</b>   <i>(Signature)</i></p>	<p><b>Attest:</b>   <i>(Signature)</i></p>
<p><b>Name:</b> Clairissa Nicholson  <i>(Printed or typed)</i></p>	<p><b>Name:</b> Amanda E. Smith  <i>(Printed or typed)</i></p>
<p><b>Title:</b> Contract Specialist</p>	<p><b>Title:</b> Witness</p>
<p><i>Notes: (1) Note: Addresses are to be used for giving any required notice. (2) Provide execution by any additional parties, such as joint venturers, if necessary.</i></p>	



1. Bidder and Surety, jointly and severally, bind themselves, their heirs, executors, administrators, successors, and assigns to pay to Owner upon default of Bidder the penal sum set forth on the face of this Bond. Payment of the penal sum is the extent of Bidder's and Surety's liability. Recovery of such penal sum under the terms of this Bond will be Owner's sole and exclusive remedy upon default of Bidder.

2. Default of Bidder occurs upon the failure of Bidder to deliver within the time required by the Bidding Documents (or any extension thereof agreed to in writing by Owner) the executed Agreement required by the Bidding Documents and any performance and payment bonds required by the Bidding Documents.
3. This obligation will be null and void if:
  - 3.1. Owner accepts Bidder's Bid and Bidder delivers within the time required by the Bidding Documents (or any extension thereof agreed to in writing by Owner) the executed Agreement required by the Bidding Documents and any performance and payment bonds required by the Bidding Documents, or
  - 3.2. All Bids are rejected by Owner, or
  - 3.3. Owner fails to issue a Notice of Award to Bidder within the time specified in the Bidding Documents (or any extension thereof agreed to in writing by Bidder and, if applicable, consented to by Surety when required by Paragraph 5 hereof).
4. Payment under this Bond will be due and payable upon default of Bidder and within 30 calendar days after receipt by Bidder and Surety of written notice of default from Owner, which notice will be given with reasonable promptness, identifying this Bond and the Project and including a statement of the amount due.
5. Surety waives notice of any and all defenses based on or arising out of any time extension to issue Notice of Award agreed to in writing by Owner and Bidder, provided that the total time for issuing Notice of Award including extensions does not in the aggregate exceed 120 days from the Bid due date without Surety's written consent.
6. No suit or action will be commenced under this Bond prior to 30 calendar days after the notice of default required in Paragraph 4 above is received by Bidder and Surety, and in no case later than one year after the Bid due date.
7. Any suit or action under this Bond will be commenced only in a court of competent jurisdiction located in the state in which the Project is located.
8. Notices required hereunder must be in writing and sent to Bidder and Surety at their respective addresses shown on the face of this Bond. Such notices may be sent by personal delivery, commercial courier, or by United States Postal Service registered or certified mail, return receipt requested, postage pre-paid, and will be deemed to be effective upon receipt by the party concerned.
9. Surety shall cause to be attached to this Bond a current and effective Power of Attorney evidencing the authority of the officer, agent, or representative who executed this Bond on behalf of Surety to execute, seal, and deliver such Bond and bind the Surety thereby.
10. This Bond is intended to conform to all applicable statutory requirements. Any applicable requirement of any applicable statute that has been omitted from this Bond will be deemed to be included herein as if set forth at length. If any provision of this Bond conflicts with any applicable statute, then the provision of said statute governs and the remainder of this Bond that is not in conflict therewith continues in full force and effect.
11. The term "Bid" as used herein includes a Bid, offer, or proposal as applicable.

**END OF SECTION**



**Travelers Casualty and Surety Company of America**  
**Travelers Casualty and Surety Company**  
**St. Paul Fire and Marine Insurance Company**  
**Farmington Casualty Company**

**POWER OF ATTORNEY**

**KNOW ALL MEN BY THESE PRESENTS:** That Travelers Casualty and Surety Company of America, Travelers Casualty and Surety Company, St. Paul Fire and Marine Insurance Company, and Farmington Casualty Company are corporations duly organized under the laws of the State of Connecticut (herein collectively called the "Companies"), and that the Companies do hereby make, constitute and appoint Elizabeth A. Dyer of Roanoke, VA, their true and lawful Attorney(s)-in-Fact to sign, execute, seal and acknowledge the following bond:

**Surety Bond No.:** Bid Bond

**Principal:** Virginia Transformer Corp

OR


**Obligee:** City of Crete

**Project Description:** Doane Substation Transformer Installed on the Doane University Campus, Crete, Nebraska # 34.5KV/15.8KV-77370V, 10/12.5/14 ONAN/ONAF @55 degrees C, 11.2/14/15.8 ONAN/ONAF/ONAF @ 55 degrees C, Z.7-5%. Quote #M232405A

IN WITNESS WHEREOF, the Companies have caused this instrument to be signed, and their corporate seals to be hereto affixed, this 21st day of April, 2021.



State of Connecticut

By:   
 Robert L. Raney, Senior Vice President

City of Hartford ss.

On this the 21st day of April, 2021, before me personally appeared Robert L. Raney, who acknowledged himself to be the Senior Vice President of each of the Companies, and that he, as such, being authorized so to do, executed the foregoing instrument for the purposes therein contained by signing on behalf of said Companies by himself as a duly authorized officer.

IN WITNESS WHEREOF, I hereunto set my hand and official seal.

My Commission expires the 30th day of June, 2026



  
 Anna P. Nowik, Notary Public

This Power of Attorney is granted under and by the authority of the following resolutions adopted by the Boards of Directors of each of the Companies, which resolutions are now in full force and effect, reading as follows:

**RESOLVED**, that the Chairman, the President, any Vice Chairman, any Executive Vice President, any Senior Vice President, any Vice President, any Second Vice President, the Treasurer, any Assistant Treasurer, the Corporate Secretary or any Assistant Secretary may appoint Attorneys-in-Fact and Agents to act for and on behalf of the Company and may give such appointee such authority as his or her certificate of authority may prescribe to sign with the Company's name and seal with the Company's seal bonds, recognizances, contracts of indemnity, and other writings obligatory in the nature of a bond, recognizance, or conditional undertaking, and any of said officers or the Board of Directors at any time may remove any such appointee and revoke the power given him or her; and it is

**FURTHER RESOLVED**, that the Chairman, the President, any Vice Chairman, any Executive Vice President, any Senior Vice President or any Vice President may delegate all or any part of the foregoing authority to one or more officers or employees of this Company, provided that each such delegation is in writing and a copy thereof is filed in the office of the Secretary; and it is

**FURTHER RESOLVED**, that any bond, recognizance, contract of indemnity, or writing obligatory in the nature of a bond, recognizance, or conditional undertaking shall be valid and binding upon the Company when (a) signed by the President, any Vice Chairman, any Executive Vice President, any Senior Vice President or any Vice President, any Second Vice President, the Treasurer, any Assistant Treasurer, the Corporate Secretary or any Assistant Secretary and duly attested and sealed with the Company's seal by a Secretary or Assistant Secretary; or (b) duly executed (under seal, if required) by one or more Attorneys-in-Fact and Agents pursuant to the power prescribed in his or her certificate or their certificates of authority or by one or more Company officers pursuant to a written delegation of authority; and it is

**FURTHER RESOLVED**, that the signature of each of the following officers: President, any Executive Vice President, any Senior Vice President, any Vice President, any Assistant Vice President, any Secretary, any Assistant Secretary, and the seal of the Company may be affixed by facsimile to any Power of Attorney or to any certificate relating thereto appointing Resident Vice Presidents, Resident Assistant Secretaries or Attorneys-in-Fact for purposes only of executing and attesting bonds and undertakings and other writings obligatory in the nature thereof, and any such Power of Attorney or certificate bearing such facsimile signature or facsimile seal shall be valid and binding upon the Company and any such power so executed and certified by such facsimile signature and facsimile seal shall be valid and binding on the Company in the future with respect to any bond or understanding to which it is attached.

I, Kevin E. Hughes, the undersigned, Assistant Secretary of each of the Companies, do hereby certify that the above and foregoing is a true and correct copy of the Power of Attorney executed by said Companies, which remains in full force and effect.

Dated this 29th day of June, 2023.



  
 Kevin E. Hughes, Assistant Secretary

To verify the authenticity of this Power of Attorney, please call us at 1-800-421-3880.  
 Please refer to the above-named Attorney(s)-in-Fact and the details of the bond to which this Power of Attorney is attached.

# BID FORM FOR PROCUREMENT CONTRACT

The terms used in this Bid with initial capital letters have the meanings stated in the Instructions to Bidders, the General Conditions, and the Supplementary Conditions.

## ARTICLE 1—BUYER AND BIDDER

1.01 This Bid is submitted to:

**City of Crete, Crete, Nebraska**

1.02 The undersigned Bidder proposes and agrees, if this Bid is accepted, to enter into a Procurement Contract with Buyer in the form included in the Procurement Bidding Documents, and to furnish the Goods and Special Services as specified or indicated in the Procurement Bidding Documents, for the prices and within the times indicated in this Bid, and in accordance with the other terms and conditions of the Procurement Bidding Documents.

## ARTICLE 2—BASIS OF BID

2.01 *Lump Sum Bids*

A. Bidder will furnish the Goods and Special Services in accordance with the Procurement Contract Documents for the following Procurement Contract Price(s) for Doane Substation Transformer:

1. Lump Sum Bid Price - Transformer

BID LUMP SUM	\$ 876,669.00
--------------	---------------

## ARTICLE 3—TIME OF COMPLETION

3.01 Bidder agrees that the furnishing of Goods and Special Services will conform to the schedule of Procurement Contract Times set forth in Article 2 of the Procurement Agreement.

3.02 Bidder accepts the provisions of the Procurement Agreement as to liquidated damages.

## ARTICLE 4—ATTACHMENTS TO THIS BID

4.01 The following documents are attached to and made a condition of this Bid:

- A. Required Bid security in the form prescribed in the Instructions to Bidders.
- B. Evidence of authority to do business in the state of the Project; or a written covenant to obtain such authority within the time for acceptance of Bids.
- C. Equipment Data Sheets.
- D. Required Bidder Qualification Statement with supporting data.
- E. Technical information required for comparative evaluation as described in Instruction to Bidders, and more specifically in Specifications.

**ARTICLE 5—BIDDER’S ACKNOWLEDGMENTS**

- 5.01 Bidder accepts all terms and conditions of the Instructions to Bidders. This Bid will remain subject to acceptance for 60 days after the Bid opening, or for such longer period that Bidder may agree to in writing upon request of Buyer.
- 5.02 Bidder has examined and carefully studied the Procurement Bidding Documents, the related data identified in the Procurement Bidding Documents, and the following Addenda, receipt of which is hereby acknowledged:

<b>Addendum No.</b>	<b>Addendum Date</b>
1	May 25th, 2023

**ARTICLE 6—BIDDER’S REPRESENTATIONS AND CERTIFICATIONS**

6.01 *Bidder’s Representations*

- A. In submitting this Bid, Bidder represents that:
  - 1. Bidder has examined and carefully studied the Procurement Contract Documents.
  - 2. If required by the Instructions to Bidders to visit the Point of Destination and the site where the Goods are to be installed or Special Services will be provided, or if, in Bidder’s judgment, any observable local or site conditions may affect the delivery, cost, progress, or furnishing of the Goods and Special Services, then Bidder has visited the Point of Destination and site where the Goods are to be installed or Special Services will be provided (as applicable) and become familiar with and is satisfied as to the observable local and site conditions that may affect delivery, cost, progress, and furnishing of the Goods and Special Services.
  - 3. Bidder is familiar with and is satisfied as to all Laws and Regulations that may affect the cost, progress, and performance of Seller's obligations under the Procurement Contract.
  - 4. Bidder has carefully studied, considered, and correlated the information known to Bidder with respect to the effect of such information on the cost, progress, and performance of Seller's obligations under the Procurement Contract.
  - 5. Bidder has given Engineer written notice of all conflicts, errors, ambiguities, or discrepancies that Bidder has discovered in the Procurement Contract Documents, and the written resolution (if any) thereof by Engineer is acceptable to Bidder.
  - 6. The Procurement Contract Documents are generally sufficient to indicate and convey understanding of all terms and conditions for performance of Seller's obligations under the Procurement Contract.
  - 7. The submission of a Bid will constitute an incontrovertible representation by Bidder that Bidder has complied with every requirement of the Bidding Requirements, that without exception the Bid (including all Bid prices) is premised upon furnishing the Goods and Special Services as required by the Procurement Contract Documents.

6.02 *Bidder's Certifications*

A. Bidder certifies that:

1. This Bid is genuine and not made in the interest of or on behalf of any undisclosed individual or entity and is not submitted in conformity with any collusive agreement or rules of any group, association, organization, or corporation;
2. Bidder has not directly or indirectly induced or solicited any other Bidder to submit a false or sham Bid;
3. Bidder has not solicited or induced any individual or entity to refrain from bidding; and
4. Bidder has not engaged in corrupt, fraudulent, collusive, or coercive practices in competing for the Procurement Contract. For the purposes of this Paragraph 6.02.A.4:
  - a. "corrupt practice" means the offering, giving, receiving, or soliciting of anything of value likely to influence the action of a public official in the bidding process;
  - b. "fraudulent practice" means an intentional misrepresentation of facts made (a) to influence the bidding process to the detriment of Buyer, (b) to establish bid prices at artificial non-competitive levels, or (c) to deprive Buyer of the benefits of free and open competition;
  - c. "collusive practice" means a scheme or arrangement between two or more Bidders, with or without the knowledge of Buyer, a purpose of which is to establish bid prices at artificial, non-competitive levels; and
  - d. "coercive practice" means harming or threatening to harm, directly or indirectly, persons or their property to influence their participation in the bidding process.


This Bid is offered by:

Bidder:

Virginia Transformer Corporation

(typed or printed name of organization)

By:



(individual's signature)

Date:

6/26/2023

(date signed)

Name:

JOSHUA YUN

(typed or printed)


Title:

Vice Pres. of Sales

(typed or printed)

(If Bidder is a corporation, a partnership, or a joint venture, attach evidence of authority to sign.)

Attest:



(individual's signature)


Title:

JIM QIAN, Director of Treasury

(typed or printed)

Address for giving notices:

220 Glade View Drive, NE Roanoke, VA 24012



Designated Representative:

Name: Chad Kraml

(typed or printed)

Title: Sales Engineer

(typed or printed)

Address:

220 Glade View Drive, NE Roanoke, VA 24012

Phone:

540-682-6618

Email:

Chad\_Kraml@vatransformer.com

License No.:

N/A

Classification:

N/A

Limitation:

N/A

**Doane Substation Transformer**

**CITY OF CRETE**

**Proposal #: M232405A**



---


## Table of Contents

<b>Commercial Summary</b> .....	3
<b>Base Price</b> .....	3
<b>Price Policy</b> .....	3
<b>Validity of Quote</b> .....	3
<b>Estimated Freight Cost</b> .....	3
<b>ITEM #1</b> .....	4
<b>Optional Pricing</b> .....	4
<b>Shipping</b> .....	4
<b>Proposed Payment Terms</b> .....	4
<b>Warranty</b> .....	4
<b>Testing - As Per IEEE ANSI 57.12.90</b> .....	5
<b>Drawings</b> .....	5
<b>Technical Summary</b> .....	6
<b>ITEM #1</b> .....	6
<b>Transformer Ratings</b> .....	6
<b>Mechanical Features</b> .....	6
<b>Radiators</b> .....	7
<b>Standard Gauges and Accessories</b> .....	7
<b>Bushings</b> .....	7
<b>Load Tap Changer</b> .....	7
<b>Ambient Conditions</b> .....	8
<b>Dimensions and Weights</b> .....	8
<b>Clarifications/Deviations to Specifications and Technical Notes</b> .....	9
<b>TECHNICAL</b> .....	9
<b>COMMERCIAL</b> .....	9
<b>General Terms and Conditions of Sale</b> .....	10

**Doane Substation Transformer**

**CITY OF CRETE**

**Proposal #: M232405A**



**VIRGINIA - GEORGIA TRANSFORMER  
ONE SOURCE-ONE COMMITMENT**

---

## Virginia Transformer Corporation


---

**This document contains Virginia Transformer Corp proprietary information and may not be copied or disclosed to others without written consent form Virginia Transformer Corp.**

For over 50 years, innovative technology and a commitment to superior customer service and support has established Virginia Transformer Corp(VTC) as an engineering company leading in manufacturing a variety of transformers.


VTC designs and manufactures custom power transformers ranging from 500 KVA to 400 MVA, 500 kV class (core type) and up to 1400 MVA, 500 kV class (shell type), and dry-type units up to 15000 KVA, 35 kV.

VTC has design and manufacturing facilities in Roanoke, VA, Pocatello, ID, Chihuahua, Mexico and Georgia Transformer in Rincon GA. In addition, VTC has design and procurement capabilities in Delhi, India, establishing a world-wide presence as a supplier of transformer solutions. VTC reserves the right to manufacture the product quoted herein at VTC owned or affiliated plants in North America.



**ISO 9001**

**"The Commitment Company"**



# Doane Substation Transformer

CITY OF CRETE

Proposal #: M232405A



VIRGINIA - GEORGIA TRANSFORMER  
ONE SOURCE-ONE COMMITMENT

## Commercial Summary

### Base Price

Item	Description	Qty	Unit Price (USD)	Extended Price (USD)
1	10,000 / 11,200 / 12,500 / 14,000 kVA   34.5 - 13.8 kV	1	\$876,669	\$876,669

### Tax Certificates Requirement

Upon acceptance of our proposal, the purchaser is required to submit a sales tax exemption certificate with the Purchase order, otherwise VTC will charge appropriate state taxes based on the destination.

### Price Policy

In the event of customer delay on a job quoted with a firm price and shipment date, VTC/GTC will apply the BLS Transformer Index to adjust price. The agreed firm price will be escalated with the base period being the quoted shipment date and the Settlement date being the month of shipment. Only increases in the BLS index will be considered for this calculation. Any advance payments will be credited to the final invoice. No adjustment will be applied if the transformer is completed and shipped prior to the quoted shipment date.

### Validity of Quote

08/13/2023

### Estimated Freight Cost


Item	Ship To	Qty	Freight Cost (USD)	Extended Freight Cost (USD)
1	Doane University, Crete, NE	1	\$12,219	\$12,219

VTC will quote freight at the time of shipment.

**Doane Substation Transformer**

**CITY OF CRETE**

**Proposal #: M232405A**



**VIRGINIA - GEORGIA TRANSFORMER  
ONE SOURCE-ONE COMMITMENT**

**ITEM #1**

**Optional Pricing**

Particulars	Price (USD/Per Unit)
Field Service Offloading	\$15,400
Field Service Assembly & Testing	\$26,400

For Witness testing, cost for travel, transportation, lodging and meals are not included in the quoted price unless otherwise noted.

**Shipping**

Unit Shipment By	45-50 Weeks from Order Acknowledgement date.VTC reserves the right to ship unit up to 3 months earlier than the contractual ship date.
Freight	PREPAID & ADD
Estimated Freight Cost (Per Unit)	\$12,219
INCO Terms	FOB - FREE ON BOARD(Doane University, Crete, NE)
Proposed Manufacturing Location	ROANOKE, VA USA
Impact Recorder	Impact Recorder to be provided on Returnable Basis, \$ 7,500 to be invoiced if not returned in 30 days after Delivery.

VTC cannot guarantee multiple units to arrive at the same time unless more than one unit can be loaded on the same truck. VTC cannot guarantee arrival dates and times at the job site. Final Lead time will be confirmed at the time of order acknowledgements

**Proposed Payment Terms**

30% Advance with Purchase Order
30% upon drawing submittal, net 30 days
40% invoiced at the time of Shipment or upon moving to storage, Net 30 days

**Warranty**

60/60 Months Extended Warranty	Includes all accessories, tank, core and coil.
--------------------------------	--

**Doane Substation Transformer**

**CITY OF CRETE**

**Proposal #: M232405A**



To ensure validity of Warranty coverage, Virginia - Georgia Transformer requires Dissolved Gas Analysis (DGA) reports of the supplied unit to be provided every year for the period of Warranty coverage. The annual DGA's should be emailed to: [FieldService@vatransformer.com](mailto:FieldService@vatransformer.com)

**Testing - As Per IEEE ANSI 57.12.90**

Routine Test	Included
Impulse Test on HV & LV	Included
Partial Discharge	Included
Power Factor	Included

All tests are as per ANSI/IEEE standard guideline. For Witness testing, cost for travel, transportation, lodging and meals are not included in the quoted price. If customer requires additional time beyond the scheduled witness test period, an additional charge of \$10,000/day will apply.

**Drawings**

Drawings are typically supplied 14-16 Weeks after Order Acknowledgement. Actual Drawing lead time will be confirmed at the time of order Acknowledgement Only. Customer approvals of drawings are required within one week from date of submittal unless otherwise agreed to in writing by VTC-authorized representative.

# Doane Substation Transformer

CITY OF CRETE

Proposal #: M232405A



## Technical Summary

This proposal is Virginia Transformer's complete understanding of the specification requirements provided, and is the basis for acceptance of any resulting orders.

## ITEM #1

### Transformer Ratings


ITEM :1			QUANTITY #1
kVA	10,000 / 11,200 / 12,500 / 14,000	Application	POWER DIST.
Cooling Class	ONAN/ONAF	Winding Temp Rise (Avg)	55/65 °C
# Phase	3	Dielectric Fluid	TYPE II MINERAL
Frequency (Hertz)	60	Winding Material	COPPER
HV Rating (V)	34,500 DELTA	LV Rating (V)	13,800 Y/7,967
HV BIL (kV)	200	LV BIL (kV)	95
HV Tap Changer	DETC	LV Tap Changer	LTC
HV Taps	2 FCAN,2 FCBN @2.5 %	LV Taps	16 ABOVE,16 BELOW @0.625 %
Nom. Impedance	7.50 % +/- 7.50 % @ 10,000 kVA	Noise (dBA)	Standard NEMA TR-1
HV Bushing Mtng	Segment III, Cover Mounted	LV Bushing Mtng	Segment I, Side Mounted
HV Terminal Chamber	Not Applicable	LV Terminal Chamber	FULL ATC
HV Coil Type	DISC CIRC.	LV Coil Type	DISC CIRC.
Paint Color - ANSI	70	Paint Type	III URETHANE OVER EPOXY
Losses	Guaranteed with IEEE Tolerance		
No Load Losses	8.00 kW at 100% volts	Load Losses	49.00 kW @ 10,000 kVA

### Mechanical Features

**Doane Substation Transformer**

**CITY OF CRETE**

**Proposal #: M232405A**



VIRGINIA - GEORGIA TRANSFORMER  
ONE SOURCE-ONE COMMITMENT

De-energized Manual No Load Tap Changer
Diagrammatic Name Plate
Gasketed Manhole in Cover
Panel Type Radiators
Provision for Jacking, Skidding and Lifting
Sealed Tank with Dry Nitrogen Blanket
Two Stainless Steel Ground Pads welded to Base on Diagonally Opposite Corners
Welded Top Cover

**Radiators**

<b>Environment Protection</b>	Hot Dipped Galvanized & Unpainted	<b>Radiator Type</b>	Demount Type
-------------------------------	-----------------------------------	----------------------	--------------

VTC standard radiators are Hot Dipped Galvanized and Unpainted which do not require painting. These radiators are suitable for all climatic conditions that include chemical, petro-chemical and marine conditions. Unless specified differently below, these standard, galvanized radiators will be provided.

**Standard Gauges and Accessories**

Gauges Details	Make
Liquid Level Gauge W/Contact	QUALITROL CORP.
Liquid Temp Gauge W/Contact	QUALITROL CORP.
Pressure Relief Device W/Contact	QUALITROL CORP.
Pressure Vacuum Gauge W/Bleeder	QUALITROL CORP.
Sudden Pressure Relay (GAS) With Seal in Relay	QUALITROL CORP.

**Bushings**

Bushing	kV BIL	Location	Qty / Phase	Make
HV	200	Segment III	1	HITACHI (ABB)/PCORE
LV	95	Segment I	1	HITACHI (ABB)/PCORE

**Load Tap Changer**

Location	On LV Winding
Make	REINHAUSEN MFG
XMFR	PREVENTIVE AUTO

# Doane Substation Transformer

CITY OF CRETE

Proposal #: M232405A



**NOTE:** The actual voltages at various taps of the LTC shall correspond to the nearest turn in accordance with IEEE Std C57.12.00 2010 clause 9.1. This can lead to different step voltage between steps.

### Ambient Conditions

Ambient Temperature(°C)	Min. -20 / Av. 30 / Max. 40
Seismic Zone	Zone 1 & 2
Altitude(Feet)	< 3,300

Unit shall be designed per the latest ANSI standards for Seismic per IEEE 693 – 2018

### Dimensions and Weights

Overall & Shipping Estimated Dimensions:		
Dimension	Overall Dimensions (Inches)	Shipping Dimensions (Inches)
Width	215	215
Depth	145	145
Height	152	139
Overall & Shipping Estimated Weights:		
Weight of the Unit (Lbs)		Shipping Weight (Lbs)
77,500		76,875
Parts Shipped Separately:		
HV Arresters and Mounting		
HV Bushings		

Assembly of any ship separate parts is not in VTC scope unless, VTC field service assembly option is purchased or included in the base price.

**Doane Substation Transformer**

**CITY OF CRETE**

**Proposal #: M232405A**



---

**Clarifications/Deviations to Specifications and Technical Notes**

**TECHNICAL  
CLARIFICATIONS**

- 1.) Transformer will be designed per ANSI/IEEE standards.
  
- 2.) Values of Test like Induced Voltage, SFRA, Corona and Partial Discharge shall be as applicable in ANSI standard.
  
- 3.) Accessories such as CTs or Lightning Arrestors have not been considered in this offer. If the Customer requires these items, then the Customer shall provide ratings to VTC to be considered with inherent price implication.


**COMMERCIAL  
CLARIFICATIONS**

- 1.) Reference attached commercial clarifications for extended explanation.

**Doane Substation Transformer**

**CITY OF CRETE**

**Proposal #: M232405A**



**VIRGINIA - GEORGIA TRANSFORMER  
ONE SOURCE-ONE COMMITMENT**

**General Terms and Conditions of Sale**

**Virginia Transformer Corp's General Terms and Conditions of Sale**

Virginia Transformer Corp, hereinafter referred to as Seller, hereby offers to supply the items and/or services identified in the quotation, proposal, or acknowledgment expressly conditional upon the Buyer's acceptance of the following terms. Seller, by its commencement of performance, shall not prejudice its rights to enforcement of these conditions. Any confirmatory action by the Buyer hereunder, or any acceptance of such equipment or services, installation, energization, or utilization shall constitute assent to said terms or conditions. Stenographic and clerical errors on this quotation, proposal, or acknowledgment are subject to correction.

1. **ACCEPTANCE OF ORDER:** None of Buyer's Terms and Conditions contained the Purchase Order or other submittal by Buyer shall alter Seller's Terms and Conditions in any respect and shall not apply to this transaction unless specifically agreed to in writing by the Seller.
  
2. **EXPIRATION OF OFFER:** All offers of sale by Seller are valid for thirty (30) days from the date of the offer based on product delivery within 6 months unless otherwise specifically stated in the Seller's offer or as otherwise may be expressly agreed to in writing by the Seller. All such offers of Seller are subject to change without notice after this period unless earlier withdrawn by the Seller.
  
3. **MINIMUM ORDER VALUE:** The minimum acceptable value of any order is \$500.00. Buyer's accumulation of several items into one purchase is authorized to reach the minimum order value.
  
4. **F.O.B. POINT AND SHIPMENTS ACCEPTANCE OF ORDER:** Title to the goods and risk of loss shall pass to Buyer at the FOB point. All supplies and services are sold FOB origin and the point of origin shall be that of Seller's factories or locations identified in its proposal or sales contract form unless as otherwise specifically agreed to in writing on the face of Seller's sales contract. Seller assumes no responsibility for delay, breakage, damage, or loss after delivery to the carrier as evidenced by **in good order** receipts from the carrier. All claims for loss, damage and delay in transit are to be handled by Buyer directly with the carrier. Seller shall select method of transportation and route on behalf of Buyer unless Buyer specifies the method and route and is to pay freight costs in addition to price. Seller reserves the right to make partial shipments at its discretion. Claims for shortages or incorrect items must be made in writing to Seller within seven days after receipt of shipment. Failure to give such notice shall constitute an unqualified acceptance of equipment and waiver by Buyer of all claims for such shortages or incorrect items.

# Doane Substation Transformer

CITY OF CRETE

Proposal #: M232405A



When terms are F.O.B. destination or freight allowed to destination, **destination** means common carrier delivery point nearest the destination the continental United States, excluding Alaska, Hawaii, Puerto Rico, etc.). When terms are F.O.B. job site or pad, Buyer guarantees all access roads are suitable for normal unimpeded access to site with free and clear access to area directly adjacent to the placement point of the unit with no physical obstructions and clear of stored materials.

Shipping schedules and delivery arrangements are made in best effort and good faith. Seller cannot, however, accept liability for penalty or damages resulting from shipping delays caused by Force Majeure including but not limited to strikes, fires, truck availability, labor or material shortages, Acts of God, or any other cause beyond VTC's reasonable control. Ship Separate Parts may not arrive concurrently with the transformer and some assembly may be required. Shipment may be made earlier after due notice to Buyer.

5. **BUYER'S OBLIGATION OF ASSISTANCE:** Except to the extent Seller has otherwise assumed such responsibility for itself under express provisions of the attachment hereto entitled **Proposal**, Buyer shall:

(a) place at Seller's disposal all information necessary for performance of the work including any plans, plant layout, wiring instructions and operational information that may reasonably be expected to affect the performance of the work. This includes to the extent reasonable previous studies or reports and other data relative to the design, installation, and selection of equipment for the work to be performed by Seller.

(b) guarantee access to and to make all reasonable provisions for Seller to enter on its property and other public and private lands as is required for performance of the work including safe storage of equipment, materials, and tools during the process of any such off-site work.

(c) agree to cooperate in all reasonable ways necessary to Seller's performance of the work.

(d) covenant that it has disclosed fully and accurately to Seller all general and local conditions which can affect performance of the work prescribed hereunder or the price thereof. Buyer acknowledges that Seller is entitled to rely on information furnished by Buyer in developing its specifications, equipment selection, price, and other terms of this order.

6. **PAYMENT TERMS:** Terms are 30% with the initial order, 30% upon Drawing Submission, net 30 days, and 40% at shipment, net 30 days, calculated from the date of invoice if credit arrangements have been approved, in advance by Seller, and these terms are included on the Seller's proposal. **Otherwise, payment is required before shipment or delivery in a form and arrangement acceptable to Seller.** In addition to any other rights or remedies available to Seller, failure to pay the amount(s) due within the time specified will result in a late charge of one and one half (1-1/2%) percent per month to Buyer's account until final payment. Payments shall not be contingent on end-user payment to Buyer and Seller reserves the right to refuse to fulfill all obligations (including field service and voiding of warranty) if payment is not received as due. In instances involving orders for more than one unit, the foregoing

## Doane Substation Transformer

CITY OF CRETE

Proposal #: M232405A



amounts will be billed and due for each unit. In instances where items are quoted by line item in the proposal, those will be billed, and payment will be due upon rendering of each item.

Purchaser grants Seller a security in the goods to secure payment of all outstanding balances. Purchaser authorizes Seller to file financing statements, fixture filings, and to execute and file any other documents and take all other steps to perfect its security interest.

Except to the extent otherwise specified by Seller in its quotation or proposal, payments shall become due without setoff. If Seller consents to delay shipments after completion of any product, the goods may be placed in storage by Seller for Buyer's account and risk, and Buyer shall pay all charges for storage, cranes, trucking and other incidental expenses incurred by Seller and the provisions in the **Storage** paragraph below shall further apply.

Any order for products by Buyer shall constitute a representation that Buyer is solvent. In addition, upon Seller's request, Buyer will furnish a written representation concerning its solvency and provide adequate assurances of its ability to satisfy its financial obligations under its contract with Seller, including but not limited to current financial statements, at any time prior to shipment. If Buyer's financial condition at any time does not justify continuance of the work to be performed by Seller hereunder on the agreed terms of payment, Seller may require full or partial payment in advance. In the event of Buyer's bankruptcy or insolvency; or in the event any proceeding is brought against Buyer, voluntarily or involuntarily, under the bankruptcy or any insolvency laws; Seller shall be entitled to cancel any order then outstanding at any time during the period allowed for filing claims against the estate and shall receive reimbursement for its proper cancellation charges. Seller's rights under this article are in addition to all rights available to it at law or in equity.

Any delay in payment as due, will impact all deliverables from Seller including the achievement of deliverables through the guaranteed delivery date. Any extended delay in payment can be the basis for the order to be held and any applicable liquidated damages in favor of Buyer shall be deemed waived.

7. **CHARGEBACKS, SET-OFF, OFFSETS OR WITHHOLDING:** Seller will not accept any back charges, set-off, offsets, or withholding for material or services without the prior written consent of Seller.

8. **DELIVERY:** The prices quoted are for the shipment dates provided on the Seller's proposal. While the Seller shall have no obligation to comply with unilateral directives to change schedules or temporarily cease work, Seller may accommodate Buyer's reasonable written requests for acceleration or deceleration made at least ninety/sixty (90/60) days respectively prior to scheduled delivery. Such changes may or may not be accepted by Seller at its sole discretion. In the event Seller accepts such changes, Seller shall be under no

# Doane Substation Transformer

CITY OF CRETE

Proposal #: M232405A



obligation to comply therewith until a price adjustment acceptable to Seller is negotiated between the parties and evidenced by an amendment to the order. Any agreement to delay delivery shall not exceed 6 months from original acknowledgement ship date; goods not released for shipment within such revised time frame shall be automatically deemed canceled and subject to Seller's Cancellation terms listed below.

9. **Storage:** In the event goods are placed in storage at the request of the Purchaser, it is agreed that title will pass to the Purchaser upon placement into storage. Irrespective of anything herein to the contrary, Purchaser will be invoiced for the balance of the purchase price of the goods when they are placed in storage and payment will be due net 30 days. Risk of loss shall pass to Purchaser who shall be responsible for insuring the goods and Seller shall have no liability for loss or damage when the goods remain in its possession in storage. Purchaser further agrees that for any goods placed in storage, Seller will be provided a minimum of three weeks advanced notice before requested delivery out of storage and delivery will then be made subject to availability of carrier and transportation services. Payment of storage fees will be due prior to shipment from storage.

10. **EXPORT REGULATIONS:** Buyer acknowledges that if the items purchased hereunder are to be exported, they are subject to the U.S. Commerce and/or State Department Export Regulations. Buyer accepts full responsibility for and agrees to comply fully with such regulations, including obtaining export licenses and re-export permission unless otherwise agreed that Seller is to be exporter of record.

11. **CANCELLATION & TERMINATION:** Seller, in addition to all other rights and remedies under this order or at law, shall have the right to cancel and terminate Buyer's order for breach by Buyer including, but not limited to, if Buyer fails to make payment as due or if Buyer is adjudicated bankrupt, files a petition in bankruptcy, makes an assignment for the benefit of creditors or if action under any law for the relief of debtors is taken. In the event of cancellation and termination of this order for breach of the provisions hereof by Buyer, Seller shall have no further liability to Buyer and Seller shall not be liable for any costs of cancellation, special, incidental, or consequential damages (including punitive or exemplary damages) for any cause or of any nature whatsoever and such cancellation and termination. All cancellations or terminations by Seller for Buyer's breach shall be subject to the following cancellation or termination charges:

1. 30% of order amount after order entry by Seller.
2. Additional 15% of order amount after outline drawing completion / submission.
3. If manufacturing has begun, charges will be based upon commitments for materials and percent completion in addition to the 45% for engineering and order entry.

# Doane Substation Transformer

CITY OF CRETE

Proposal #: M232405A



In the event Buyer cancels its order, Buyer shall be responsible to Seller for cancellation charges in the amounts set forth above in Cancellation & Termination paragraph 11 which Buyer shall pay Seller upon such cancellation.

12. **RESCHEDULING FEE:** Any extended delays by the customer/Purchaser which result in the loss of the scheduled production slot will be subject to a re-scheduling fee of 30% of the specific order value.

13. **PATENT INFRINGEMENT:** To the extent that the items ordered are manufactured to designs, drawings, specifications, or instructions furnished by Buyer, Buyer guarantees that the manufacture and sale or use of such items will not infringe upon any U.S., or foreign patents. Buyer further agrees to indemnify and hold harmless the Seller from any expense, loss, cost, damage, or liability of any kind which may be incurred because of any such infringement or alleged infringement of patent rights with respect to such items and to defend, at its own cost and expense, any action or claim in which such infringement is alleged. Buyer shall promptly notify Seller of any such action and shall provide Seller an opportunity, at Seller's option, to participate in any defense of such action or claim at Seller's own expense.

Seller shall hold Buyer harmless from costs actually incurred arising directly from the defense of any suit for infringement of any domestic or foreign patent by a Seller-manufactured item, provided Seller shall be given timely written notice of such suit and the option to replace the same, obtain a license, make other arrangements to avoid litigation or to defend the suit. No indemnification is offered or applicable for alleged infringement arising from the use of Seller's items in combination with other items supplied by Buyer or from compliance with drawings, specifications or instructions furnished by Buyer as described in the paragraph above. Further, no indemnification by Seller applies if this order is accepted under a U.S. government contract containing an Authorization and Consent Clause applicable hereto as prescribed by U.S. federal procurement laws and regulations.

14. **DISCLOSURE OF INFORMATION / PROPERTY OF SELLER:** Any information, suggestions or ideas transmitted by either Buyer or Seller in connection with performance hereunder are not to be regarded as secret or submitted in confidence unless it is stamped or marked **Confidential** prior to delivery by the disclosing party. Neither party shall use or disclose such property to any third party or any one not having a need to know, including employees, without the prior written consent from the disclosing party. Title to all tools, test equipment and facilities not furnished by Buyer or specifically paid for by Buyer as a separate line item under any order, shall remain with Seller. Further, Seller does not agree to submit to Buyer because of the Consideration paid under this order, any information, technical data, or drawings which are proprietary to Seller; nor does Seller agree to grant to Buyer any patent rights, title, or license without Seller's expressed prior written consent.

## Doane Substation Transformer

CITY OF CRETE

Proposal #: M232405A



15. **TAXES:** The purchase price of the Goods and Services does not include transportation taxes and sales, use, excise, value added, import or any similar tax or other governmental charge arising pursuant to or in connection with the sale, purchase, processing, delivery, storage, use, consumption, performance or transportation of the Goods and Services. Buyer is responsible for payment of any transportation taxes, and any present or future sales, use, excise, value added, import or any similar tax or other governmental charge applicable to the Agreement and to the sale and/or furnishing of the Goods and Services if a Sales Tax exemption form is not received by Seller from Buyer.

16. **EQUIPMENT WARRANTIES AND REMEDY:**

(A) For the period set forth below in this paragraph, Seller warrants that each newly manufactured item sold hereunder, and such portion of a repaired/refurbished item as has been repaired or replaced by Seller under this warranty, shall be free from defects in material, workmanship, or title at the time of shipment and shall perform during the warranty period in accordance with the specifications incorporated herein. Should any failure to conform to these warranties (excluding any defects in title) be discovered and brought to Seller's attention during the warranty period and be substantiated by examination at Seller's factory or by authorized field personnel, then (i) Seller shall correct such failure by, at Seller's exclusive option, repair or replacement of the nonconforming item or portion thereof with Buyer promptly making product available to be worked by Seller's personnel or agents without interference with no additional cost to the Seller; or (ii) Buyer making available product F.O.B. Seller's plant with Seller's written return authorization, at Seller's exclusive option, for repair or replacement of the nonconforming item or portion thereof. Buyer agrees that this remedy shall be its sole and exclusive remedy against Seller and that no other remedy shall be available or pursued by Buyer against Seller. In no event shall the Seller be liable for any costs or expenses in excess of those described in this paragraph and expressly excluding any liability or damages for special, incidental, or consequential damages.

The warranty period for newly manufactured items shall extend 12 months from the date of first energization or 18 months from the date of shipment whichever occurs first or unless a different warranty period is agreed to by Seller. The warranty period for repaired/refurbished articles shall extend for the unexpired warranty period of the item repaired or replaced or for 90 days, whichever is longer. This warranty shall be voided and not extend to any item that upon examination by Seller is found to have been subject to:

- (a) mishandling, misuse, negligence, or accident.
- (b) storage, installation, operation, testing, or maintenance that either was not in accordance with Seller's specifications, instructions, manuals, or otherwise improper, or contrary to industry standards.
- (c) tampering as evidenced for example by broken seals, damaged packaging containers, etc.

## Doane Substation Transformer

CITY OF CRETE

Proposal #: M232405A



- (d) testing of equipment above normally accepted field tests.
- (e) repair or alteration by anyone other than Seller without Seller's express advance written approval.
- (f) payment(s) not received per terms of sale.

Failure to promptly notify Seller in writing upon discovery of any non-conforming items during the warranty period shall void the warranty as to such items. Buyer shall describe any such non-conformity in detail, expressing its position as to return of any article under the remedy provided herein. No returns shall be accepted without prior approval by Seller. No back charges shall be accepted without the prior written consent of Seller's authorized representative. Where a failure cannot be corrected by Seller's reasonable efforts, the parties shall mutually agree upon an equitable adjustment in price. The preceding sets forth the exclusive remedies for claims (except as to title) based on defect whether in contract or tort (including negligence or strict liability) and however instituted. THIS WARRANTY IS EXCLUSIVE AND IN LIEU OF ANY OTHER WARRANTIES, EITHER EXPRESSED OR IMPLIED INCLUDING WARRANTIES OF MERCHANTABILITY OR FITNESS FOR A PARTICULAR PURPOSE, AND SELLER DISCLAIMS IMPLIED WARRANTIES OF MERCHANTABILITY AND FITNESS FOR A PARTICULAR PURPOSE.

**(B) SELLER'S INSTALLATION WARRANTY:** Seller warrants that all work hereunder shall be performed in accordance with the standards employed by Seller in performing the same or similar services for itself. Seller disclaims any and all other representations or warranties expressed or implied including without limitation any representation or warranty that a) any unauthorized entry, burglary, theft, embezzlement, or any other crimes will be prevented by the equipment and/or installation thereof or that b) any particular purpose or standard of care intended or desired or any particular results to be achieved by Buyer through the installation and operation of the items to be delivered hereunder. Seller's installation services and installation warranty does not include or imply any assistance for system field troubleshooting and no back charges for such services shall be accepted without the prior written consent of Seller's authorized representative.

**(C) EXTENDED WARRANTY PERIOD OPTION FOR CORE AND COIL:** When purchased, the warranty period may be extended by the period specified in such purchase covering core and coils only against failure occurring with respect to normal operation and within the parameters for which the transformer was designed. For extended Warranty period, to ensure validity of Extended Warranty period coverage, Virginia Transformer requires Dissolved Gas Analysis (DGA) reports of the supplied unit to be provided every year for the period of extended warranty period coverage. The annual DGAs should be emailed to: [FieldService@vatransformer.com](mailto:FieldService@vatransformer.com). Failure to conduct annual DGAs and provide the reports to Seller may void the purchased extended warranty. Except for the extended time period all other provisions, terms, conditions, and limitations set forth above shall apply to the extended warranty period. In case of any disturbance in the system that causes the transformer to trip off-line, following information shall be forwarded to Virginia Transformer Corp within 48

# Doane Substation Transformer

CITY OF CRETE

Proposal #: M232405A



hours: Event summary with relevant data, Protection system data, Overvoltage conditions (If any), Fault data (if any) and offset timing with peak current value, Loading, Environmental and atmospheric conditions. Failure to timely provide this information may void the warranty.

**(D) EXTENDED BUMPER TO BUMPER WARRANTY PERIOD OPTION:** When purchased, the warranty for the extended period specified will cover the entire Transformer including core and coils and all associated transformer accessories against failure occurring with respect to normal operation and within the parameters for which the transformer was designed. Bumper to Bumper Warranty does not cover normal wear and tear including paint and gaskets beyond five years. For extended Warranty period, to ensure validity of Extended Warranty period coverage, Virginia Transformer requires Dissolved Gas Analysis (DGA) reports of the supplied unit to be provided every year for the period of extended warranty coverage, and the additional data as stated in Section 15(A) The annual DGA's should be emailed to: [FieldService@vatransformer.com](mailto:FieldService@vatransformer.com). Failure to conduct annual DGAs and provide the reports to Seller may void the purchased extended warranty. Except for the extended time period all other provisions, terms, conditions, and limitations set forth above shall apply to the extended warranty period.

**(E) IN/OUT COVERAGE OPTION:** When purchased, Seller will cover only the expenses to transport the transformer to a repair facility and back to site for warranty failures occurring within the period defined. Buyer will make transformer ready for shipment in the condition it was originally received per the Outline Drawing with clear and free access by Carrier. Craning, civil work, disconnection, and reconnection of the transformer, etc. is the responsibility of the Buyer.

17. **CONFIGURATION STATUS AND SUBSTITUTION OF MATERIALS:** Seller reserves the right to make substitution of materials without degrading the quality of product. Customer approval will be solicited when changes affect form, fit or function. Seller further reserves the right to discontinue any items without notice and to change or modify specifications at any time without incurring any obligation to incorporate new or modified features in components or products previously sold or shipped.

18. **LIMITATION OF LIABILITY:** Neither party shall be liable to the other for any incidental, indirect, special, punitive, or consequential damages regardless of whether liability would arise under contract or tort (including negligence and strict liability), warranty, indemnity, or otherwise. Neither party's liability on any claim for loss or damage arising out of this contract or from the performance or breach thereof shall exceed the price of the item giving rise to the claims for loss or damage in the event more than one item is included in this contract/order with distinct pricing being allocated to each item in arriving at the total contract/order price.

19. **HAZARDOUS BUSINESS:** Unless otherwise agreed in writing by an authorized representative of the Seller, goods sold hereunder are not intended for use in connection with any nuclear facility or any other hazardous activity such as commercial or military aircraft,

## Doane Substation Transformer

CITY OF CRETE

Proposal #: M232405A



missile installation, space exploration or other critical applications where failure of a single component could cause substantial harm to persons or property. If so used, Seller disclaims all liability for any nuclear damage contamination or other injury and Buyer shall indemnify and hold Seller harmless from such liability whether as a result of breach of contract, warranty, tort (including negligence) or other grounds. Neither Seller nor its suppliers shall have any liability to the Buyer or its insurers whether based on contract, warranty, tort (including negligence or strict liability) or other grounds for on-site damage to any property located at a nuclear facility.

20. **COMPLIANCE WITH LAW:** Buyer shall comply with all applicable Federal, State, municipal and local laws including but not limited to: laws concerning procurement integrity (particularly subsections 27(a), (d) and (f) of the Office of Federal Procurement Policy Act, as amended, 41 U.S.C. §423 and FAR 3.104-3; the Byrd Amendment (31 U.S.C. §1352); laws governing lobbying activities (2 U.S.C. §261 et seq., particularly § 267); laws prohibiting the giving of bribes (18 U.S.C. §201(b) or gratuities (18 U.S.C. §201 (c); the Foreign Corrupt Practices Act of 1977, as amended, (15 U.S.C. §78m, 78dd-1, 78dd-2, and 78ff). Buyer acknowledges that if items purchased are to be exported, Buyer has the complete responsibility and agrees to comply with all export laws and regulations of the U.S. Department of Commerce and of the U.S. State Department, or other governmental body. Seller hereby certifies that all goods sold hereunder which are produced or manufactured in the United States of America are products in compliance with the Fair Labor Standards Act of 1938 which shall be considered as satisfied by this certification.

21. **INSURANCE:** Buyer shall maintain its usual and customary insurance coverage for automobile, workmen's compensation and third-party liability claims during performance of this order and, if requested by Seller, name Seller an insured under its third-party liability coverage.

22. **NON-WAIVER:** The failure of Seller to enforce at any time any of the provisions of this order shall not constitute a waiver of such provisions or a waiver of the right of Seller to enforce any or all provisions. If any term or provisions of this order is held invalid or unenforceable by any court of competent jurisdiction, the remainder of this order shall continue to be valid and binding upon the parties unless performance thereof is rendered legally impractical and no longer fulfills the intention of the parties under this order.

23. **APPLICABLE LAW AND FORUM FOR RESOLUTION OF DISPUTES:** This contract shall be deemed to have been made and performed in, and shall be construed, interpreted and the rights and obligations of the parties determined by the law of the Commonwealth of Virginia excluding choice of law rules. Any dispute, controversy or claim arising out of or related to this contract, or any breach thereof, shall be resolved by binding arbitration administered by the American Arbitration Association under its Commercial Arbitration Rules and judgment on the award rendered by the arbitrator may be entered in any court having jurisdiction thereof. Such arbitration shall take place in Roanoke, Va. In case of non- performance by Buyer

## Doane Substation Transformer

CITY OF CRETE

Proposal #: M232405A



requiring arbitration or other legal action, Seller's costs, and reasonable attorney's fees of arbitration or other legal action shall be the responsibility of the Buyer

24. **PRICE SURCHARGE:** In the event any components such as, core steel, mineral oil, electricity, labor etc. are subject to abnormal price increases, and VTC/GTC is not able to otherwise mitigate these increases, during the period between the proposal date and the settlement date, VTC/GTC may pass along those specific incremental cost increases.

25. **ASSIGNMENT:** Except as otherwise expressly provided herein, no assignment of this order or Buyer's rights under this order shall be made by Buyer without the prior written agreement of the Seller. All amounts due to the Seller, including the assignment fee of \$10,000, must be paid to the Seller before any assignments will be granted. In addition, Buyer must provide financial and other information as requested by the Seller to support the ability of the assignee to pay future amounts that may become due. Seller reserves the right to deny any request for assignment.

26. **FORCE MAJEURE:** In addition to other liability limitation herein contained, seller shall not be responsible to the Buyer for any loss or damage due to failure or delay in performance or delivery of any of the items or services required under this order when such delay or failure is due to causes beyond the Seller's reasonable control. Such causes shall include without limitation fires, floods, epidemics, pandemics, quarantines, unusually severe weather, strikes, embargoes, wars, political strife, riots, delays in transportation, compliance with any regulation or directives of any national, state, or local municipal government or authority and unforeseeable shortages in fuel, power, materials, or labor. Seller shall not be liable for delays in delivery or performance, or for failure to manufacture, deliver or perform, due to an inability on account of a cause beyond the reasonable control of Seller to obtain necessary materials, components, services, or facilities. Seller will notify Buyer of any material delay excused by this clause and will specify the revised delivery date as soon as practicable. In the event of any such delay, there will be no termination and the date of delivery or of performance shall be extended for a period equal to the time lost by reason of the delay.

27. **ORDER TERMS EXCLUSIVE:** These Terms and Conditions together with Seller's Proposal and Order Acknowledgement constitute the entire and sole agreement between the parties concerning the subject matter of this order and the parties acknowledge and agree that none of them has made any representation with respect to the subject matter of this order or any representations including the execution and delivery hereof except as specifically set forth herein. Captions as used herein are for convenience or reference only and shall not be deemed or construed as in any way limiting or extending the meaning of any terms and conditions contained herein.

28. **CUSTOMER CONTRACTS:** Buyer will include in its contracts with its purchaser customers the warranty conditions and limitations Section 15 (Equipment Warranties and Remedy), and the limitations of liability provisions set out in Section 17 (Limitation of Liability). Buyer shall

## Doane Substation Transformer

CITY OF CRETE

Proposal #: M232405A



indemnify and hold harmless Seller from any liability to any customer or third parties as a result of the failure to include such conditions and limitations in its contracts with its purchaser customers.

29. **MODIFICATION:** This order may not be modified except by written instrument executed by the following authorized representatives; Director of Contracts, Director of Finance, Senior VP of Materials / MIS, Corporate Controller, President, and CEO.

30. **SECTION TITLES:** Section titles appearing in the General Terms and Conditions of Sale are for convenience only and shall not be construed as interpretations of text.

31. **APPENDICIES:** Any appendix or other terms and conditions of the Seller as may be attached hereto and/or identified herewith are hereby incorporated and made a part of these Terms and Conditions and all orders or contracts shall be subject to such additional terms and conditions which shall control over any inconsistency with the Terms and Conditions stated herein.

32. **"Intellectual Property Rights"** means all registered and unregistered intellectual property rights throughout the world, including rights in patents, copyrights, trademarks, trade secrets, designs, databases, and domain names and moral rights.

33. **Grant of License by VTC Upon** receipt of full payment for the Transformer and conditioned upon Customer not defaulting on its obligations under this Agreement, VTC hereby grants to Customer a perpetual, royalty-free license to use the Intellectual Property Rights of VTC which are incorporated in the Transformer. Such license is limited solely to the use of the Transformer by Customer for the purposes and at the location described in VTC's Proposal. Customer may only transfer this license to a third party upon first providing VTC with a written acknowledgment by such transferee of VTC's ownership of its Intellectual Property Rights contained in the Transformer.

34. If any purchase order submitted by the owner/purchaser contains or invokes terms or conditions other than this Contract or the Terms and Conditions agreed to between VTC and the owner/purchaser, then Seller/VTC may, without penalty, reject said terms and conditions on the purchase order by striking them out.

Virginia Transformer Corp.  
 Summary of Clarifications to the Terms and Conditions  
 to be negotiated and discussed  
**City of Crete – M232405A**

Item	Article/Section	
1	Procurement Contract  Article 2 – Procurement Contract Times  Section 2.01 Time of the Essence <b>Material Importance</b>  Pg. 1 of 9	<b>2.01 Time of the Essence-Material Importance</b>  A. All time limits for Milestones, including the submittal of Shop Drawings and Samples, the delivery of Goods, and the furnishing of Special Services as stated in the Procurement Contract Documents, are of <del>the essence</del> <b>material importance</b> of the Procurement Contract.
	Customer Response	
2	Procurement Contract  Article 9 – Mutual Waiver  Section 9.01 Mutual Waiver of Consequential Damages  Please add the following to this Section.  Pg. 8 of 9	Neither party's liability on any claim for loss or damage arising out of this contract or from the performance or breach thereof shall exceed the price of the item giving rise to the claims for loss or damage in the event more than one item is included in this contract/order with distinct pricing being allocated to each item in arriving at the total contract/order price.
	Customer Response	
3	Conditions of Contract  Article 4 – Commencement and Schedule  Section 4.04 Delays  Please adjust the following.  Pg. 10 of 35	A. If Buyer, Engineer, or anyone for whom Buyer is responsible, delays, disrupts, or interferes with Seller's performance or progress, then Seller shall be entitled to an equitable adjustment in Procurement Contract Price or Procurement Contract Times. <b>Any extended delays requested by the customer/Purchaser which result in the loss of the scheduled production slot will be subject to a re-scheduling fee of 30% of the specific order value.</b>  C 1. 1. severe and unavoidable natural catastrophes such as fires, floods, epidemics, <b>pandemics, quarantines,</b> and earthquakes;
	Customer Response	

4	<p>Conditions of Contract</p> <p>Article 7 – Seller’s Responsibilities</p> <p>Section C. Special Guarantee</p> <p>Please remove this section as this is covered by the Warranty.</p> <p>Pg. 15 of 35</p>	<p><del>Special Guarantee: Buyer may require Seller to furnish at Seller’s expense a special performance guarantee or other surety with respect to any such proposed “or equal.”</del></p>
	Customer Response	
5	<p>Conditions of Contract</p> <p>Article 7 – Seller’s Responsibilities</p> <p>Section 7.07 Indemnification</p> <p>Please see the amendment to this section. VTC also requests that B. be struck in its entirety. Liability should be limited to the Contract Value of the offending unit per Senior Mgmt.</p> <p>Pg. 18 of 35</p>	<p>To the fullest extent permitted by Laws and Regulations, Seller shall indemnify and hold harmless Buyer, Engineer, Project Owner, and any assignee of Buyer, including Contractor/Assignee, and their officers, directors, members, partners, employees, agents, consultants, contractors, and subcontractors, from and against all claims, <del>costs, losses, and damages (including but not limited to all fees and charges of engineers, architects, attorneys, and other professionals and all court or arbitration or other dispute resolution costs)</del> arising out of or relating to the performance of Seller's obligations under the Procurement Contract, provided that any such claim, <del>cost, loss, or damage</del> is attributable to bodily injury, sickness, disease, or death, or to injury to or destruction of tangible property (other than the Goods themselves), including the loss of use resulting therefrom, but only to the extent caused by any negligent act or omission of Seller, or any individual or entity directly or indirectly employed by Seller or anyone for whose acts Seller may be liable. <b>Seller's liability under this Clause shall be only to the proportionate extent of Seller's fault, negligence, or responsibility and not for any portion of any claim under this Clause that is the fault, negligence or responsibility of other parties including the Indemnified Parties.</b></p>
	Customer Response	
6	<p>Conditions of Contract</p> <p>Article 9 – Warranty</p> <p>Please replace this entire Section with the following as VTC reserves the right to warrant its own product, and rejection takes place during FAT. Any damage during transit is our responsibility, and any nonconformity at</p>	<p>(A) For the period set forth below in this paragraph, Seller warrants that each newly manufactured item sold hereunder, and such portion of a repaired/refurbished item as has been repaired or replaced by Seller under this warranty, shall be free from defects in material, workmanship, or title at the time of shipment and shall perform during the warranty period in accordance with the specifications incorporated herein. Should any failure to conform to these warranties (excluding any defects in title) be discovered and brought to Seller's attention during the warranty period and be substantiated by examination at Seller's factory or by authorized field personnel, then (i) Seller shall correct such failure, at Seller's exclusive option, repair or replacement of the nonconforming item or portion thereof with Buyer promptly making product available to be worked by Seller’s personnel or agents without interference with no additional cost to the Seller; or (ii) Buyer making available product F.O.B. Seller’s plant with Seller’s written return authorization, at Seller’s exclusive option, for repair or replacement of the nonconforming item or portion thereof. Buyer agrees that this remedy shall be its sole and exclusive remedy against Seller and that no other remedy shall be available or pursued by Buyer against Seller. In no event shall the Seller be liable for any costs or expenses in excess of those described in this paragraph and expressly excluding any liability or damages for special, incidental, or consequential damages.</p>

the time of delivery is a warranty issue that will be made whole.

Please also use this same language in Section 016000 – Product Requirements Section 1.5 Product Warranties, and Section 261213 2.5 Warranty.

The warranty period for newly manufactured items shall extend 12 months from the date of first energization or 18 months from the date of shipment whichever occurs first or unless a different warranty period is agreed to by Seller. The warranty period for repaired/refurbished articles shall extend for the unexpired warranty period of the item repaired or replaced or for 90 days, whichever is longer. This warranty shall be voided and not extend to any item that upon examination by Seller is found to have been subject to:

- a) mishandling, misuse, negligence, or accident.
- b) storage, installation, operation, testing, or maintenance that either was not in accordance with Seller's specifications, instructions, manuals, or otherwise improper, or contrary to industry standards.
- c) tampering as evidenced for example by broken seals, damaged packaging containers, etc.
- d) testing of equipment above normally accepted field tests.
- e) repair or alteration by anyone other than Seller without Seller's express advance written approval.
- f) payment(s) not received per terms of sale.

Failure to promptly notify Seller in writing upon discovery of any non-conforming items during the warranty period shall void the warranty as to such items. Buyer shall describe any such non-conformity in detail, expressing its position as to return of any article under the remedy provided herein. No returns shall be accepted without prior approval by Seller. No back charges shall be accepted without the prior written consent of Seller's authorized representative. Where a failure cannot be corrected by Seller's reasonable efforts, the parties shall mutually agree upon an equitable adjustment in price. The preceding sets forth the exclusive remedies for claims (except as to title) based on defect whether in contract or tort (including negligence or strict liability) and however instituted. THIS WARRANTY IS EXCLUSIVE AND IN LIEU OF ANY OTHER WARRANTIES, EITHER EXPRESSED OR IMPLIED INCLUDING WARRANTIES OF MERCHANTABILITY OR FITNESS FOR A PARTICULAR PURPOSE, AND SELLER DISCLAIMS IMPLIED WARRANTIES OF MERCHANTABILITY AND FITNESS FOR A PARTICULAR PURPOSE.

(B) SELLER'S INSTALLATION WARRANTY: Seller warrants that all work hereunder shall be performed in accordance with the standards employed by Seller in performing the same or similar services for itself. Seller disclaims any and all other representations or warranties expressed or implied including without limitation any representation or warranty that a) any unauthorized entry, burglary, theft, embezzlement, or any other crimes will be prevented by the equipment and/or installation thereof or that b) any particular purpose or standard of care intended or desired or any particular results to be achieved by Buyer through the installation and operation of the items to be delivered hereunder. Seller's installation services and installation warranty does not include or imply any assistance for system field troubleshooting and no back charges for such services shall be accepted without the prior written consent of Seller's authorized representative.

(C) EXTENDED WARRANTY PERIOD OPTION FOR CORE AND COIL: When purchased, the warranty period may be extended by the period specified in such purchase covering core and coils only against failure occurring with respect to normal operation and within the parameters for which the transformer was designed. For extended Warranty period, to ensure validity of Extended Warranty period coverage, Virginia Transformer requires Dissolved Gas Analysis (DGA) reports of the supplied unit to be provided every year for the period of extended warranty period coverage. The annual DGAs should be emailed to: [FieldService@vatransformer.com](mailto:FieldService@vatransformer.com). Failure to conduct annual DGAs and provide the reports to Seller may void the purchased extended warranty. Except for the extended time period all other provisions, terms, conditions, and limitations set forth above shall apply to the extended warranty period. In case of any disturbance in the system that causes the transformer to trip off-line, following information shall be forwarded to Virginia Transformer Corp within 48 hours: Event summary with relevant data, Protection system data, Overvoltage conditions (If any), Fault data (if any) and offset timing with peak current value, Loading, Environmental and atmospheric conditions. Failure to timely provide this information may void the warranty.

		<p>(D) EXTENDED BUMPER TO BUMPER WARRANTY PERIOD OPTION: When purchased, the warranty for the extended period specified will cover the entire Transformer including core and coils and all associated transformer accessories against failure occurring with respect to normal operation and within the parameters for which the transformer was designed. Bumper to Bumper Warranty does not cover normal wear and tear including paint and gaskets beyond five years. For extended Warranty period, to ensure validity of Extended Warranty period coverage, Virginia Transformer requires Dissolved Gas Analysis (DGA) reports of the supplied unit to be provided every year for the period of extended warranty coverage, and the additional data as stated in Section 15(A) The annual DGA's should be emailed to: FieldService@vatransformer.com. Failure to conduct annual DGAs and provide the reports to Seller may void the purchased extended warranty. Except for the extended time period all other provisions, terms, conditions, and limitations set forth above shall apply to the extended warranty period.</p> <p>IN/OUT COVERAGE OPTION: When purchased, Seller will cover only the expenses to transport the transformer to a repair facility and back to site for warranty failures occurring within the period defined. Buyer will make transformer ready for shipment in the condition it was originally received per the Outline Drawing with clear and free access by Carrier. Craning, civil work, disconnection, and reconnection of the transformer, etc. is the responsibility of the Buyer.</p>
	Customer Response	
7	<p>Conditions of Contract</p> <p>Article 11 – Changes</p> <p>Section 11.06 Buyer's Contingency Allowance</p> <p>Please add the following</p> <p>Pg. 26 of 35</p>	<p>E. In the event any components such as, electricity, freight, labor, core steel, mineral oil etc. are subject to abnormal price increases, and VTC/GTC is not able to otherwise mitigate these increases, during the period between the proposal date and the shipment date, VTC/GTC may pass along those specific incremental cost increases.</p>
	Customers Response	
8	<p>Conditions of Contract</p> <p>Article 14 – Cancellation, Suspension, and Termination</p> <p>Section 14.01 Cancellation and Section 14.02 Suspension of Performance by Buyer.</p> <p>Pg. 33 of 35</p>	<p>14.01 Cancellation</p> <p>A. Buyer has the right to cancel the Procurement Contract, without cause, at any time prior to delivery of the Goods by written notice. Cancellation pursuant to the terms of this paragraph will not constitute a breach of contract by Buyer. <del>Upon cancellation:</del></p> <p><del>1. Buyer shall pay Seller for the direct costs incurred in producing any Goods that Seller has specially manufactured for the Project, plus a fair and reasonable amount for overhead and profit.</del></p> <p><del>2. For Goods that are not specially manufactured for the Project, Seller shall be entitled to a restocking charge of 10 percent of the unpaid Procurement Contract Price of such Goods. Seller, in addition to all other rights and remedies under this order or at law, shall have the right to cancel and terminate Buyer's order for breach by Buyer including, but not limited to, if Buyer fails to make payment as due or if Buyer is adjudicated bankrupt, files a petition in bankruptcy, makes an assignment for the benefit of creditors or if action under any law for the relief of debtors is taken. In the event of cancellation and termination of this order for breach of the provisions hereof by Buyer, Seller shall have no further liability to Buyer and Seller shall not be liable for any costs of cancellation, special, incidental or consequential damages (including punitive or exemplary damages) for any cause or of any nature whatsoever and such cancellation and termination. All cancellations or terminations by Seller for Buyer's breach shall be subject to the</del></p>

		<p><b>following cancellation or termination charges:</b></p> <ul style="list-style-type: none"> <li>• <b>30 % of order amount after order entry by Seller.</b></li> <li>• <b>Additional 15 % of order amount after outline drawing completion / submission.</b></li> <li>• <b>If manufacturing has begun, charges will be based upon commitments for materials and percent completion in addition to the 45% for engineering and order entry.</b></li> </ul> <p><b>In the event Buyer cancels its order, Buyer shall be responsible to Seller for cancellation charges in the amounts set forth in the Cancellation &amp; Termination paragraph above, which Buyer shall pay Seller upon such cancelation.</b></p> <p>14.02 Suspension of Performance by Buyer  A. Buyer has the right to suspend performance of the Procurement Contract for up to 90 days, without cause, by written notice. <del>Upon suspension under this paragraph, Seller shall be entitled to an increase in the Procurement Contract Times and Procurement Contract Price caused by the suspension, provided that performance would not have been suspended or delayed for causes attributable to Seller.</del> <b>Any extended delays requested by the customer/Purchaser which result in the loss of the scheduled production slot will be subject to a re-scheduling fee of 30% of the specific order value.</b></p>
	Customer Response	
9	<p>Supplementary Conditions of the Procurement Contract</p> <p>Article 9 – Buyer’s Rights</p> <p>Section 9.05 B Please strike in its entirety.</p> <p>Limitation of Seller’s Liability</p> <p>Pg. 6 of 6</p>	<p><del>B. Upon assignment the terms of this Paragraph 9.05 will be binding upon both the assignor and assignee with respect to Seller's liability, The terms of this limitation do not apply to or limit any claim by Buyer against Seller based on any of the following: (a) contribution or indemnification with respect to third party claims, losses, and damages; (b) costs, losses, or damages attributable to personal or bodily injury, sickness, disease, or death, or to injury to or destruction of the tangible property of others, (c) intentional or reckless wrongful conduct, or (d) rights conferred by any bond provided by Seller under this Contract.</del></p>
	Customer Response	
10	<p>Requesting the insertion of the following section.</p> <p>Storage</p>	<p>In the event goods are placed in storage at the request of the Purchaser, it is agreed that title will pass to the Purchaser upon placement into storage. Irrespective of anything herein to the contrary, Purchaser will be invoiced for the balance of the purchase price of the goods when they are placed in storage and payment will be due net 30 days. Risk of loss shall pass to Purchaser who shall be responsible for insuring the goods and Seller shall have no liability for loss or damage when the goods remain in its possession in storage. Purchaser further agrees that for any goods placed in storage, Seller will be provided a minimum of three weeks advanced notice before requested delivery out of storage and delivery will then be made subject to availability of carrier and transportation services. In the event goods are placed in storage at the request of the Purchaser, it is agreed that title will pass to the Purchaser upon placement into storage. Irrespective of anything herein to the contrary, Purchaser will be invoiced for the balance of the purchase price of the goods when they are placed in storage and payment will be due net 30 days. Risk of loss shall pass to Purchaser who shall be responsible for insuring the goods and Seller shall have no liability for loss or damage when the goods remain in its possession in storage. Purchaser further agrees that for any goods placed in storage, Seller will be provided a minimum of three weeks advanced notice before requested delivery out of storage and</p>

		delivery will then be made subject to availability of carrier and transportation services. Storage and crantage fees will be applied and be payable prior to shipment.
	Customer Response	
11	Requesting the insertion of the following section.  Grant of License by VTC	Upon receipt of full payment for the Transformer and conditioned upon Customer not defaulting on its obligations under this Agreement, VTC hereby grants to Customer a perpetual, royalty-free license to use the Intellectual Property Rights of VTC which are incorporated in the Transformer. Such license is limited solely to the use of the Transformer by Customer for the purposes and at the location described in your Proposal. Customer may only transfer this license to a third party upon first providing VTC with a written acknowledgment by such transferee of VTC's ownership of its Intellectual Property Rights contained in the Transformer.
	Customer Response	
12	Requesting the insertion of the following section.  Purchase Orders	If any purchase order submitted by the owner/purchaser contains or invokes terms or conditions other than this Contract or the Terms and Conditions agreed to between VTC and the purchaser, then Seller/VTC may, without penalty reject said terms and conditions on the purchase order by striking them out.
	Customer Response	

**Crete, NE; Doane Substation Medium Voltage Switchgear (#8508670)**

Owner: City of Crete

Solicitor: Olsson, Inc. (Lincoln, NE)

Bid Opening Date: June 29, 2023 - 10:00 AM CDT

Olsson Project # 022-02597

Contractor				Harold K. Scholz Co. Ralston, NE		Malloy Electric Sioux Falls, SD	
Line Item	Item	Unit	Qty	Unit Price	Extension	Unit Price	Extension
<b>Base Bid:</b>							
1	15kV Switchgear	LS	1	\$962,125.00	<b>\$962,125.00</b>	\$1,215,068.49	<b>\$1,215,068.49</b>
1A	15kV Switchgear (if contractor has more than one approved manufacturer)	LS	1	\$0.00	\$0.00	\$1,324,657.53	<b>\$1,324,657.53</b>
<b>Alternate Bid:</b>							
2	35kV Switchgear	LS	1	\$0.00	\$0.00	\$1,997,364.38	<b>\$1,997,364.38</b>
2A	35kV Switchgear (if contractor has more than one approved manufacturer)	LS	1	\$0.00	\$0.00	\$0.00	\$0.00
<b>Lead Time</b>				52-54 Weeks		lesser bid 92-94 weeks higher bid 76-78 weeks	

**Crete, NE; Doane Substation Transformer (#8512839)**

Owner: City of Crete

Solicitor: Olsson, Inc. (Lincoln, NE)

Bid Opening Date: June 29, 2023 - 10:30 AM CDT

Olsson Project # 022-02597

Contractor				Virginia Transformer Roanoke, VA		Malloy Electric Sioux Falls, SD	
Line Item	Item	Unit	Qty	Unit Price	Extension	Unit Price	Extension
<b>Base Bid:</b>							
1	Transformer	LS	1	\$876,669.00	\$876,669.00	\$1,450,666.67	\$1,450,666.67
1A	Transformer (if contractor has more than one approved manufacturer)	LS	1	\$0.00	\$0.00	\$0.00	\$0.00
<b>Base Bid Total:</b>				<b>\$876,669.00</b>		<b>\$1,450,666.67</b>	
<b>Lead Time</b>				45-50 weeks		72 weeks	
<b>Notes</b>						Drawing Submittal ready in 22 weeks	

## Fence Permit

Fence permits are required forms can be found on line or in the building inspectors office in City Hall.

## Location

Fences in any front yard, beyond the house itself, may not be taller than 4 feet including post and must be of an open weave or see-through design to allow for traffic visibility. Fences in rear or side yards may not be higher than 6' and must include a gate for access of utility personnel. Fences on corner lots must meet visibility triangles at street corners and driveway entrances. Corner lot fences have 2 front yards. Property lines need to be located by survey or other professional means to the satisfaction of the building inspector. Fences may be installed to the inside of the property line and be no closer than 18" from sidewalk which ever is more restrictive.

### Open Weave Example



## Easements

A 5' clearance on the sides and back shall be maintained around all Transformers. A 10' clearance is required in front. A 3' clearance shall be maintained around pedestals on all sides. If the clearance cannot be achieved then all fence panels shall be made removable without the use of tools. You are required to submit a locate request for buried cables and gas lines by calling 811 before digging.

Pedestal Transformer



## Materials

Fences are required to be constructed of approved materials rated for exterior use including wood, brick, masonry block, stone, tubular steel, wrought iron, vinyl, composite or recycled materials, chain-link or other manufactured material or combination of materials commonly used for fencing. Materials not listed must be approved by the Zoning Administrator. Some areas have covenant regulations dictating whether fences can be installed and the type of fence. Check with local home owner association in regards to their

bylaws. Swimming pools are required to have a fence installed. Contact the building inspector about information pertaining to swimming pool fences.

## Prohibited Materials include

Scrap materials such as scrap lumber, scrap metal, metal roof panels, corrugated or sheet metal, pallet wood, tarps, plywood, barbed and razor wire, hog wire, chicken wire, horseman wire mesh, v-mesh, field fence, woven field fence, welded utility fence, electrified wire fence or any similar or like wire fencing material is not permitted in residential R-1 through R-4 or commercial zones C-1 through C-3. Barbed or razor wire may be permitted as security fence at top of allowed fence material. Fences built with valid permits prior to the effective date of this chapter or fences on properties annexed to the City after the effective date of this chapter are exempt.

## Design

All fences shall have the finished side facing out with post and supports to the inside.


### Shadow Box Example




## Temporary Fence

Temporary fencing for gardens, construction fencing and silt fencing do not require a permit and need to be removed at completion of construction or when not being used.

### Corner lot example



## Visibility Triangle



Dimensions of Vision Clearance Triangle	
Street Road	Length of Triangle
Alley	20 feet
Non-Residential Drive	25 feet
Local	25 feet
Collector	40 feet
Arterial	55 feet

# CITY OF CRETE FENCE BROCHURE

CRETE  
NEBRASKA







