

Board of Education Special Meeting

Tuesday, July 23, 2019 4:00 PM

1. Call to Order
2. Flag Salute
3. Open Meeting Act
4. Roll Call
5. Review Agenda
6. Motion to approve the agenda as presented Passed with a motion by Suzanne Brodine and a second by Dana Steiner.
7. Suzanne Brodine: Yea, Morgan Fouts: Yea, JC Ourada: Yea, Dana Steiner: Yea
8. Approve Fire Alarm Proposal from Electronic Contracting Company for the Elementary Building of \$46,239.00
9. Motion to approve the fire alarm proposal from Electronic Contracting Company for the Elementary Building in the amount of \$46,239.00 Passed with a motion by JC Ourada and a second by Morgan Fouts.
10. Suzanne Brodine: Yea, Morgan Fouts: Yea, JC Ourada: Yea, Dana Steiner: Yea
11. Adjournment
12. Motion to adjourn Passed with a motion by JC Ourada and a second by Dana Steiner.
13. Suzanne Brodine: Yea, Morgan Fouts: Yea, JC Ourada: Yea, Dana Steiner: Yea



PROPOSAL

Electronic Contracting Company
6501 North 70th Street
Lincoln, NE 68507

Ph: (402) 466-8274 Fax: (402) 466-0819

Proposal #072019-01

Proposal Submitted To: Elm Creek Public School	Phone: 402-216-7421	Date: July 20, 2019
Street: 230 East Calkins Ave	City, State, Zip Code: Elm Creek, NE 68836	
Project: Fire Alarm Systems Upgrade		ATTN: Tom Reeser

Electronic Contracting Company Respectfully Submits The Following Proposal:

Engineer and draft fire alarm system changes and pull fire alarm permit with the state fire marshal.

New Building:

Replace Siemens FS-250 fire alarm head end equipment with new system equipment. Reuse all existing devices and wiring with new system.

Old Building:

Replace existing IXL panel with new system annunciator panel and power supplies. Replace IXL addressable devices and select conventional devices where conventional zone devices can be eliminated with new system addressable devices. Wire devices to new system using existing & new cabling and program for system changes.

Test system with AHJ.

Notes:

- Previous troubleshooting labor is not included as part of this proposal.**
- Existing fire alarm system deficiencies will not be corrected as part of this proposal.**
- Fire alarm cabling will be plenum rated and ran free air above suspended ceiling.**

Total \$46,239.00

Payment to be made as follows: Net 30 Days.

All applicable taxes and rush shipping will be added to quoted price.

NOTE: This proposal may be withdrawn if not accepted in 90 Days.

Nick Flury

Authorized Signature

Submitted By: Nick Flury

Acceptance of Proposal: The above prices and conditions are hereby accepted. You are authorized to do the work as specified.

Authorized Signature

Date